DIN EN 61850-7-4:2010-11 (E)

Communication networks and systems for power utility automation - Part 7-4: Basic communication structure - Compatible logical node classes and data object classes (IEC 61850-7-4:2010); English version EN 61850-7-4:2010

Inhalt

Seite

INTRODUCTION 10
1 Scope 11
2 Normative references 12
3 Terms and definitions 13
4 Abbreviated terms 13
5 Logical node classes 19
5.1 Logical node groups 19
5.2 Interpretation of logical node tables 20
5.3 System logical nodes LN group: L 21
5.3.1 LN relationships 21
5.3.2 LN: Physical device information Name: LPHD 22
5.3.3 LN: common logical node Name: Common LN 22
5.3.4 LN: Logical node zero Name: LLN0 24
5.3.5 LN: Physical communication channel supervision Name: LCCH 24
5.3.6 LN: GOOSE subscription Name: LGOS 25
5.3.7 LN: Sampled value subscription Name: LSVS 25
5.3.8 LN: Time management Name: LTIM 26
5.3.9 LN: Time master supervision Name: LTMS 26
5.3.10 LN: Service tracking Name: LTRK 27
5.4 Logical nodes for automatic control LN Group: A 27
5.4.1 Modelling remarks 27
5.4.2 LN: Neutral current regulator Name: ANCR 28
5.4.3 LN: Reactive power control Name: ARCO 29
5.4.4 LN: Resistor control Name: ARIS 29
5.4.5 LN: Automatic tap changer controller Name: ATCC 30
5.4.6 LN: Voltage control Name: AVCO 32
5.5 Logical nodes for control LN Group: C 32
5.5.1 Modelling remarks 32
5.5.2 LN: Alarm handling Name: CALH 32
5.5.3 LN: Cooling group control Name: CCGR 33
5.5.4 LN: Interlocking Name: CILO 34
5.5.5 LN: Point-on-wave switching Name: CPOW 34
5.5.6 LN: Switch controller Name: CSWI 34
5.5.7 LN: Synchronizer controller Name: CSYN 35
5.6 Logical nodes for functional blocks LN group F 37
5.6.1 Modelling remarks 37
5.6.2 LN: Counter Name: FCNT 37
5.6.3 LN: Curve shape description Name: FCSD 37

5.6.4 LN: Generic filter Name: FFIL 38
5.6.5 LN: Control function output limitation Name: FLIM 38
5.6.6 LN: PID regulator Name: FPID 39
5.6.7 LN: Ramp function Name: FRMP 40
5.6.8 LN: Set-point control function Name: FSPT 40
5.6.9 LN: Action at over threshold Name: FXOT 41
5.6.10 LN: Action at under threshold Name: FXUT 41
5.7 Logical nodes for generic references LN Group: G 42
5.7.1 Modelling remarks 42
5.7.2 LN: Generic automatic process control Name: GAPC 42
5.7.3 LN: Generic process I/O Name: GGIO 43
5.7.4 LN: Generic log Name: GLOG 43
5.7.5 LN: Generic security application Name: GSAL 44
5.8 Logical nodes for interfacing and archiving LN Group: I 44
5.8.1 Modelling remarks 44
5.8.2 LN: Archiving Name: IARC 44
5.8.3 LN: Human machine interface Name: IHMI 45
5.8.4 LN: Safety alarm function Name: ISAF 45
5.8.5 LN: Telecontrol interface Name: ITCI 46
5.8.6 LN: Telemonitoring interface Name: ITMI 46
5.8.7 LN: Teleprotection communication interfaces Name: ITPC 46
5.9 Logical nodes for mechanical and non-electric primary equipment LN group K 48
5.9.1 Modelling remarks 48
5.9.2 LN: Fan Name: KFAN 48
5.9.3 LN: Filter Name: KFIL 48
5.9.4 LN: Pump Name: KPMP 49
5.9.5 LN: Tank Name: KTNK 49
5.9.6 LN: Valve control Name: KVLV 50
5.10 Logical nodes for metering and measurement LN Group: M 51
5.10.1 Modelling remarks 51
5.10.2 LN: Environmental information Name: MENV 51
5.10.3 LN: Flicker measurement name Name: MFLK 52
5.10.4 LN: Harmonics or interharmonics Name: MHAI 53
5.10.5 LN: Non-phase-related harmonics or interharmonics Name: MHAN 54
5.10.6 LN: Hydrological information Name: MHYD 56
5.10.7 LN: DC measurement Name: MMDC 56
5.10.8 LN: Meteorological information Name: MMET 56
5.10.9 LN: Metering Name: MMTN 57
5.10.10 LN: Metering Name: MMTR 58
5.10.11 LN: Non-phase-related measurement Name: MMXN 58
5.10.12 LN: Measurement Name: MMXU 58
5.10.13 LN: Sequence and imbalance Name: MSQI 60
5.10.14 LN: Metering statistics Name: MSTA 61
5.11 Logical nodes for protection functions LN Group: P 61
5.11.1 Modelling remarks 61
5.11.2 LN: Differential Name: PDIF 62
5.11.3 LN: Direction comparison Name: PDIR 63
5.11.4 LN: Distance Name: PDIS 64
5.11.5 LN: Directional overpower Name: PDOP 64

5.11.6 LN: Directional underpower Name: PDUP 65
5.11.7 LN: Rate of change of frequency Name: PFRC 65
5.11.8 LN: Harmonic restraint Name: PHAR 66
5.11.9 LN: Ground detector Name: PHIZ 66
5.11.10 LN: Instantaneous overcurrent Name: PIOC 67
5.11.11 LN: Motor restart inhibition Name: PMRI 67
5.11.12 LN: Motor starting time supervision Name: PMSS 68
5.11.13 LN: Over power factor Name: POPF 68
5.11.14 LN: Phase angle measuring Name: PPAM 68
5.11.15 LN: Rotor protection Name: PRTR 69
5.11.16 LN: Protection scheme Name: PSCH 69
5.11.17 LN: Sensitive directional earthfault Name: PSDE 70
5.11.18 LN: Transient earth fault Name: PTEF 71
5.11.19 LN: Thyristor protection Name: PTHF 71
5.11.20 LN: Time overcurrent Name: PTOC 71
5.11.21 LN: Overfrequency Name: PTOF 72
5.11.22 LN: Overvoltage Name: PTOV 73
5.11.23 LN: Protection trip conditioning Name: PTRC 73
5.11.24 LN: Thermal overload Name: PTTR 74
5.11.25 LN: Undercurrent Name: PTUC 74
5.11.26 LN: Underfrequency Name: PTUF 75
5.11.27 LN: Undervoltage Name: PTUV 75
5.11.28 LN: Underpower factor Name: PUPF 76
5.11.29 LN: Voltage controlled time overcurrent Name: PVOC 76
5.11.30 LN: Volts per Hz Name: PVPH 77
5.11.31 LN: Zero speed or underspeed Name: PZSU 78
5.12 Logical nodes for power quality events LN Group: Q 78
5.12.1 Modelling remarks 78
5.12.2 LN: Frequency variation Name: QFVR 78
5.12.3 LN: Current transient Name: QITR 79
5.12.4 LN: Current unbalance variation Name: QIUB 79
5.12.5 LN: Voltage transient Name: QVTR 80
5.12.6 LN: Voltage unbalance variation Name: QVUB 80
5.12.7 LN: Voltage variation Name: QVVR 81
5.13 Logical nodes for protection related functions LN Group: R 81
5.13.1 Modelling remarks 81
5.13.2 LN: Disturbance recorder channel analogue Name: RADR 82
5.13.3 LN: Disturbance recorder channel binary Name: RBDR 82
5.13.4 LN: Breaker failure Name: RBRF 83
5.13.5 LN: Directional element Name: RDIR 83
5.13.6 LN: Disturbance recorder function Name: RDRE 84
5.13.7 LN: Disturbance record handling Name: RDRS 85
5.13.8 LN: Fault locator Name: RFLO 85
5.13.9 LN: Differential measurements Name: RMXU 86
5.13.10 LN: Power swing detection/blocking Name: RPSB 86
5.13.11 LN: Autoreclosing Name: RREC 87
5.13.12 LN: Synchronism-check Name: RSYN 87
5.14 Logical nodes for supervision and monitoring LN Group: S 88
5.14.1 Modelling remarks 88

5.14.2 LN: Monitoring and diagnostics for arcs Name: SARC 89
5.14.3 LN: Circuit breaker supervision Name: SCBR 89
5.14.4 LN: Insulation medium supervision (gas) Name: SIMG 90
5.14.5 LN: Insulation medium supervision (liquid) Name: SIML 91
5.14.6 LN: Tap changer supervision Name: SLTC 92
5.14.7 LN: Supervision of operating mechanism Name: SOPM 92
5.14.8 LN: Monitoring and diagnostics for partial discharges Name: SPDC 93
5.14.9 LN: Power transformer supervision Name: SPTR 94
5.14.10 LN: Circuit switch supervision Name: SSWI 94
5.14.11 LN: Temperature supervision Name: STMP 95
5.14.12 LN: Vibration supervision Name: SVBR 96
5.15 Logical nodes for instrument transformers and sensors LN Group: T 97
5.15.1 Modelling remarks 97
5.15.2 LN: Angle Name: TANG 97
5.15.3 LN: Axial displacement Name: TAXD 97
5.15.4 LN: Current transformer Name: TCTR 98
5.15.5 LN: Distance Name: TDST 98
5.15.6 LN: Liquid flow Name: TFLW 99
5.15.7 LN: Frequency Name: TFRQ 99
5.15.8 LN: Generic sensor Name: TGSN 100
5.15.9 LN: Humidity Name: THUM 100
5.15.10 LN: Media level Name: TLVL 101
5.15.11 LN: Magnetic field Name: TMGF 101
5.15.12 LN: Movement sensor Name: TMVM 101
5.15.13 LN: Position indicator Name: TPOS 102
5.15.14 LN: Pressure sensor Name: TPRS 102
5.15.15 LN: Rotation transmitter Name: TRTN 103
5.15.16 LN: Sound pressure sensor Name: TSND 103
5.15.17 LN: Temperature sensor Name: TTMP 104
5.15.18 LN: Mechanical tension / stress Name: TTNS 104
5.15.19 LN: Vibration sensor Name: TVBR 105
5.15.20 LN: Voltage transformer Name: TVTR 105
5.15.21 LN: Water acidity Name: TWPH 106
5.16 Logical nodes for switchgear LN Group: X 106
5.16.1 Modelling remarks 106
5.16.2 LN: Circuit breaker Name: XCBR 106
5.16.3 LN: Circuit switch Name: XSWI 107
5.17 Logical nodes for power transformers LN Group: Y 108
5.17.1 Modelling remarks 108
5.17.2 LN: Earth fault neutralizer (Petersen coil) Name: YEFN 108
5.17.3 LN: Tap changer Name: YLTC 109
5.17.4 LN: Power shunt Name: YPSH 109
5.17.5 LN: Power transformer Name: YPTR 109
5.18 Logical nodes for further power system equipment LN Group: Z 110
5.18.1 Modelling remarks 110
5.18.2 LN: Auxiliary network Name: ZAXN 110
5.18.3 LN: Battery Name: ZBAT 111
5.18.4 LN: Bushing Name: ZBSH 111
5.18.5 LN: Power cable Name: ZCAB 111

5.18.6 LN: Capacitor bank Name: ZCAP 112
5.18.7 LN: Converter Name: ZCON 112
5.18.8 LN: Generator Name: ZGEN 112
5.18.9 LN: Gas insulated line Name: ZGIL 113
5.18.10 LN: Power overhead line Name: ZLIN 113
5.18.11 LN: Motor Name: ZMOT 114
5.18.12 LN: Reactor Name: ZREA 114
5.18.13 LN: Resistor Name: ZRES 115
5.18.14 LN: Rotating reactive component Name: ZRRC 115
5.18.15 LN: Surge arrestor Name: ZSAR 116
5.18.16 LN: Semi-conductor controlled rectifier Name: ZSCR 116
5.18.17 LN: Synchronous machine Name: ZSMC 116
5.18.18 LN: Thyristor controlled frequency converter Name: ZTCF 118
5.18.19 LN: Thyristor controlled reactive component Name: ZTCR 118
6 Data object name semantics 118
Annex A (normative) Interpretation of mode and behaviour 157
Annex B (normative) Local / Remote concept 159
Annex C (informative) Deprecated logical node classes 161
Annex D (informative) Relationship between this standard and IEC 61850-5 162
Annex E (informative) Algorithms used in logical nodes for automatic control 163
Annex F (normative) Statistical calculation 168
Annex G (normative) Functional relationship of data objects of autorecloser RREC 173
Annex H (normative) SCL enumerations 174
Bibliography 180

Figure 1 – Overview of this standard 12
Figure 2 – LOGICAL NODE relationships 21
Figure E.1 – Example of curve based on an indexed gate position providing water flow 163
Figure E.2 – Example of curve based on an indexed guide vane position (x axis) vs. net head (y axis) giving an interpolated runner blade position (Z axis) 164
Figure E.3 – Example of a proportional-integral-derivate controller 165
Figure E.4 – Example of a power stabilisation system 166
Figure E.5 – Example of a ramp generator 166
Figure E.6 – Example of an interface with a set-point algorithm 167
Figure F.1 – Statistical calculation of a vector 169
Figure F.2 – Examples of statistical calculations 171
Figure G.1 – Diagram of autorecloser function 173

Table 1 – List of logical node groups 19
Table 2 – Interpretation of logical node tables 20
Table 3 – Relation between IEC 61850-5 and IEC 61850-7-4 for automatic control LNs 28
Table 4 – Relation between IEC 61850-5 and IEC 61850-7-4 for control LNs 32
Table 5 – Conditional attributes in FPID 40

Table 6 – Relation between IEC 61850-5 and IEC 61850-7-4 for metering and measurement LNs 51
Table 7 – Relation between IEC 61850-5 and IEC 61850-7-4 (this standard) for protection LNs 61
Table 8 – Relation between IEC 61850-5 and IEC 61850-7-4 for protection related LN 82
Table 9 – Relation between IEC 61850-5 and IEC 61850-7-4 for supervision and monitoring LNs 88
Table 10 – Description of data objects 118
Table A.1 – Values of mode and behaviour 157
Table A.2 – Definition of mode and behaviour 158
Table B.1 – Relationship between Loc/Rem data objects and control authority 160
Table D.1 – Relationship between IEC 61850-5 and this standard for some miscellaneous LNs 162