

ISO/IEC 30134-2:2026-01 (E)

Information technology - Data centres key performance indicators - Part 2: Power usage effectiveness (PUE)

Contents		Page
Foreword		v
Introduction		vi
1	Scope	1
2	Normative references	1
3	Terms, definitions, abbreviated terms and symbols	1
3.1	Terms and definitions	2
3.2	Abbreviated terms	3
3.3	Symbols	3
4	Applicable areas of the data centre	4
5	Determination of power usage effectiveness (PUE)	5
5.1	General	5
5.2	Total data centre energy consumption	6
5.3	Total data centre energy consumption in mixed-use buildings	7
6	Measurement of power usage effectiveness	8
6.1	Calculation and measurement of energy consumption	8
6.1.1	General	8
6.1.2	On-site electricity generation	8
6.1.3	Measurement period and frequency	8
6.1.4	Meter and measurement requirements	8
6.1.5	EDC measurement location	8
6.2	Categories of power usage effectiveness	8
6.2.1	General	8
6.2.2	Category 1 (PUE1) -- Basic resolution	9
6.2.3	Category 2 (PUE2) -- Intermediate resolution	9
6.2.4	Category 3 (PUE3) -- Advanced resolution	9
7	Application of PUE	10
8	Reporting of power usage effectiveness	10
8.1	Requirements	10
8.1.1	Standard construct for communicating PUE data	10
8.1.2	Example of reporting PUE values	10
8.1.3	Data for public reporting of PUE	10
8.2	Recommendations	11
8.2.1	Use of PUE category	11
8.2.2	Trend tracking data	11
9	PUE derivatives	12
9.1	General	12
9.1.1	Purpose of PUE derivatives	12
9.1.2	Using PUE derivatives	12
9.2	Interim PUE (iPUE)	12
9.3	Partial PUE (pPUE)	12
9.3.1	General	12

9.3.2	Zoning	13
9.3.3	Metering requirements for pPUE	14
9.3.4	Reporting of pPUE	14
9.3.5	Use of pPUE in energy management	15
9.4	Mixed use PUE (mPUE)	16
9.5	Designed PUE (dPUE)	16
Annex A (normative) Energy measurements		18
Annex B (informative) Calculation of PUE using various energy supplies		20
Annex C (normative) Interpretation of PUE and its derivatives		27
ISO/IEC 30134-2:2026(en) Annex D (informative) Calculating dPUE		29
Annex E (informative)mPUEmeasurementandcalculationmethodformixedbuilding		32
Bibliography		35