

ISO 7240-19:2007-08 (E)

Fire detection and alarm systems - Part 19: Design, installation, commissioning and service of sound systems for emergency purposes

| Contents | | Page |
|--------------------|--|-------------|
| Foreword | | v |
| Introduction | | vii |
| 1 | Scope | 1 |
| 2 | Normative references | 1 |
| 3 | Terms, abbreviated terms and definitions | 2 |
| 3.1 | Definitions | 2 |
| 3.2 | Abbreviated terms | 3 |
| 4 | Design requirements | 4 |
| 5 | Planning | 4 |
| 5.1 | Responsibilities | 4 |
| 5.2 | Qualifications | 4 |
| 5.3 | Documentation | 4 |
| 5.4 | System design | 5 |
| 5.5 | Category of s.s.c.i.e | 6 |
| 5.6 | Classification of priorities | 7 |
| 5.7 | Speech intelligibility | 7 |
| 5.8 | Warning signals | 8 |
| 5.9 | Emergency loudspeaker zones | 9 |
| 5.10 | Visual warning devices and tactile warning devices | 10 |
| 5.11 | Delay to outputs | 10 |
| 5.12 | Initiation | 11 |
| 5.13 | Manual alarm output | 11 |
| 5.14 | Sound system control and indicating equipment | 11 |
| 5.15 | Power supply | 12 |
| 5.16 | Supervision of transmission paths | 13 |
| 5.17 | Wiring | 13 |
| 5.18 | Interconnection to a fire detection and alarm system | 14 |
| 5.19 | Use for non-emergency purposes | 14 |
| 5.20 | Documentation | 15 |
| 6 | Equipment and material | 16 |
| 6.1 | Quality of components | 16 |
| 6.2 | Standards | 16 |
| 6.3 | Additional requirements | 16 |
| 6.4 | Sound system control and indicating equipment optional functions | 16 |
| 6.5 | Installation materials | 16 |
| 7 | Systems compatibility | 16 |
| 7.1 | Responsibility | 16 |
| 7.2 | Documentation | 17 |
| 7.3 | Certification | 17 |
| 8 | Approvals | 17 |
| 9 | Installation | 17 |

| | | |
|---|---|----|
| 9.1 | Responsibility | 17 |
| 9.2 | Qualifications | 17 |
| 9.3 | Certification | 18 |
| 10 | Commissioning | 18 |
| 10.1 | Responsibility | 18 |
| 10.2 | Qualifications | 18 |
| 10.3 | Procedure | 18 |
| 10.4 | Certification | 18 |
| 11 | Normal use | 18 |
| 11.1 | Access to system | 18 |
| 11.2 | Other responsibilities | 18 |
| 11.3 | Routine tests and regular controls | 19 |
| 11.4 | Documentation | 19 |
| 11.5 | Operating instructions | 19 |
| 12 | Service | 19 |
| 12.1 | Responsibility | 19 |
| 12.2 | Qualifications | 19 |
| 12.3 | Service plan | 19 |
| 12.4 | Documentation | 21 |
| 13 | Abnormal situations -- System disconnection | 22 |
| Annex A (normative) Measurement of speech intelligibility | | 23 |
| Annex B (informative) Explanation of access levels | | 26 |
| Annex C (informative) Power source calculations | | 28 |
| Annex D (informative) Commissioning report | | 30 |
| Annex E (informative) Inspection report | | 31 |
| Annex F (informative) Test report | | 32 |
| Bibliography | | 33 |