

# ISO 12239:2010-12 (E)

## Smoke alarms using scattered light, transmitted light or ionization

---

<b>Contents</b>		<b>Page</b>
Foreword .....		v
Introduction .....		vi
<b>1</b>	<b>Scope .....</b>	<b>1</b>
<b>2</b>	<b>Normative references .....</b>	<b>1</b>
<b>3</b>	<b>Terms and definitions .....</b>	<b>2</b>
<b>4</b>	<b>General requirements .....</b>	<b>4</b>
4.1	Compliance .....	4
4.2	Alarm condition .....	4
4.3	Mains-on visual indicator .....	5
4.4	Fault condition visual indicator -- Optional function .....	5
4.5	Smoke alarm signals .....	5
4.6	Test facility .....	5
4.7	Means of calibration .....	5
4.8	User-replaceable components .....	5
4.9	Primary power source .....	5
4.10	Secondary power source .....	6
4.11	Battery connections .....	6
4.12	User-replaceable battery .....	7
4.13	Electrical safety .....	7
4.14	Connection of external ancillary devices .....	7
4.15	Terminals for external conductors .....	7
4.16	Protection against the ingress of foreign bodies .....	7
4.17	Interconnectable smoke alarms -- Optional function .....	8
4.18	Alarm-silence facility -- Optional function .....	8
4.19	Radioactive material in type B smoke alarms .....	8
4.20	Smoke alarms with voice -- Optional function .....	8
4.21	Marking .....	9
4.22	Data .....	10
4.23	Additional requirements for software controlled smoke alarms .....	11
<b>5</b>	<b>Tests .....</b>	<b>12</b>
5.1	General .....	12
5.2	Directional dependence .....	16
5.3	Initial sensitivity .....	16
5.4	Repeatability .....	16
5.5	Air movement .....	17
5.6	Dazzling .....	17
5.7	Dry heat (operational) .....	18
5.8	Cold (operational) .....	19
5.9	Damp heat (operational) .....	20
5.10	Sulfur dioxide (SO <sub>2</sub> ) corrosion .....	21
5.11	Impact (operational) .....	22
5.12	Vibration, sinusoidal (operational) .....	23
5.13	Vibration, sinusoidal (endurance) .....	24
5.14	Extended temperature (operational) -- Optional function .....	25
5.15	Electromagnetic compatibility (EMC) immunity tests (operational) .....	25
5.16	Fire sensitivity .....	26

5.17	Battery-low condition .....	27
5.18	85 dBA Sound output -- Optional function .....	28
5.19	70 dBA Sound output -- Optional function .....	29
5.20	Sounder durability .....	30
5.21	Interconnectable smoke alarms .....	31
5.22	Alarm-silence facility .....	32
5.23	Variation in supply voltage .....	32
5.24	Polarity reversal .....	33
5.25	Secondary power source .....	34
5.26	Electrical safety .....	34
5.27	Sequence timing for smoke alarms with voice .....	35
6	Test report .....	36
Annex A (normative) Smoke tunnel for response-threshold value measurement .....		37
Annex B (normative) Test aerosol for response threshold value measurements .....		38
Annex C (normative) Smoke-measuring instruments .....		39
Annex D (normative) Apparatus for dazzling test .....		43
Annex E (normative) Apparatus for impact test .....		44
Annex F (normative) Fire test room .....		46
Annex G (normative) Smouldering pyrolysis wood fire (TF2) .....		48
Annex H (normative) Glowing smouldering cotton fire (TF3) .....		51
Annex I (normative) Flaming plastics (polyurethane) fire (TF4) .....		53
Annex J (normative) Flaming liquid (n-heptane) fire (TF5) .....		55
Annex K (informative) Information concerning the construction of the smoke tunnel .....		56
Annex L (informative) Information concerning the construction of the measuring ionization chamber .....		58