

# DIN EN 54-27:2015-05 (E)

## Fire detection and fire alarm systems - Part 27: Duct smoke detectors

---

<b>Contents</b>		<b>Page</b>
Foreword .....		5
Introduction .....		7
<b>1</b>	<b>Scope .....</b>	<b>8</b>
<b>2</b>	<b>Normative references .....</b>	<b>8</b>
<b>3</b>	<b>Terms, abbreviated terms and definitions .....</b>	<b>9</b>
3.1	Terms and definitions .....	9
3.2	Abbreviated terms .....	10
<b>4</b>	<b>Requirements .....</b>	<b>10</b>
4.1	General .....	10
4.2	Nominal activation conditions/sensitivity .....	10
4.2.1	Individual alarm indication .....	10
4.2.2	Additional visual indication (option with requirement) .....	10
4.2.3	Alarm resetting for stand-alone systems (option with requirement) .....	11
4.2.4	Connection of ancillary devices (option with requirement) .....	11
4.2.5	Response to slowly developing fires .....	11
4.2.6	Dazzling .....	11
4.3	Operational reliability .....	11
4.3.1	Repeatability .....	11
4.3.2	Reproducibility .....	11
4.3.3	On-site adjustment of response behaviour .....	11
4.3.4	Manufacturer's adjustments .....	12
4.3.5	Monitoring of detachable detectors .....	12
4.3.6	Software controlled detectors (when provided) .....	12
4.4	Tolerance to supply voltage -- Variation in supply parameters .....	13
4.5	Performance parameters under fire conditions -- Fire sensitivity .....	13
4.6	Durability of Nominal activation conditions/sensitivity .....	13
4.6.1	Temperature resistance .....	13
4.6.2	Humidity resistance .....	14
4.6.3	Corrosion resistance -- Sulfur dioxide (SO <sub>2</sub> ) corrosion (endurance) .....	14
4.6.4	Shock and vibration resistance .....	14
4.6.5	Electrical stability -- EMC, immunity tests (operational) .....	14
4.6.6	Air leakage .....	14
<b>5</b>	<b>Testing, assessment and sampling methods .....</b>	<b>15</b>
5.1	General .....	15
5.1.1	Atmospheric conditions for tests .....	15
5.1.2	Operating conditions for tests .....	15
5.1.3	Mounting arrangements .....	15
5.1.4	Tolerances .....	15
5.1.5	Response threshold value .....	16
5.1.6	Provision for tests .....	16
5.1.7	Reduced function tests .....	17
5.1.8	Test schedule .....	17
5.2	Nominal activation conditions/sensitivity .....	18
5.2.1	Individual alarm indication .....	18
5.2.2	Additional visual indication (when provided) .....	18
5.2.3	Alarm resetting for stand-alone system (when provided) .....	18

5.2.4	Connection of ancillary devices (when provided) .....	18
5.2.5	Response to slowly developing fires .....	18
5.2.6	Dazzling .....	18
5.3	Operational reliability .....	19
5.3.1	Repeatability .....	19
5.3.2	Reproducibility .....	20
5.3.3	On-site adjustment of response behaviour .....	20
5.3.4	Manufacturer's adjustments .....	20
5.3.5	Monitoring of detachable detectors .....	20
5.3.6	Software controlled devices .....	20
5.4	Tolerance to supply voltage .....	20
5.4.1	Variation in supply parameters .....	20
5.5	Performance parameters under fire conditions .....	21
5.5.1	Fire sensitivity .....	21
5.6	Durability of Nominal activation conditions/sensitivity .....	23
5.6.1	Temperature resistance .....	23
5.6.2	Humidity resistance .....	25
5.6.3	Corrosion resistance -- Sulfur dioxide (SO <sub>2</sub> ) corrosion (endurance) .....	27
5.6.4	Shock and vibration resistance .....	28
5.6.5	Electrical stability .....	32
5.6.6	Air leakage .....	33
6	Assessment and verification of constancy of performance (AVCP) .....	34
6.1	General .....	34
6.2	Type testing .....	34
6.2.1	General .....	34
6.2.2	Test samples, testing and compliance criteria .....	35
6.2.3	Test reports .....	35
6.3	Factory production control (FPC) .....	35
6.3.1	General .....	35
6.3.2	Requirements .....	36
6.3.3	Product specific requirements .....	38
6.3.4	Initial inspection of factory and FPC .....	39
6.3.5	Continuous surveillance of FPC .....	39
6.3.6	Procedure for modifications .....	40
6.3.7	One-off products, pre-production products, (e.g. prototypes) and products produced in very low quantities .....	40
7	Classification .....	40
8	Marking, labelling and packaging .....	41
9	Data .....	41
Annex A (normative)	Aerosol tunnel arrangement for response measurements .....	42
Annex B (normative)	Test aerosol for response threshold value measurements .....	43
Annex C (normative)	Smoke measuring instruments .....	44
Annex D (normative)	Apparatus for dazzling test .....	48
Annex E (normative)	Fire test room and working volume arrangements for fire tests .....	49
Annex F (normative)	Smouldering (pyrolysis) wood fire (TF2D) .....	51
Annex G (normative)	Flaming plastics (polyurethane) fire (TF4D) .....	54
Annex H (normative)	Low temperature black smoke (decaline) liquid fire (TF8D) .....	56
Annex I (informative)	Information concerning the construction of the tunnel for fire tests .....	59

<b>Annex J (informative) Information concerning the construction of the measuring ionization chamber .....</b>	<b>61</b>
<b>Annex K (informative) Information about DSD used as a stand-alone system .....</b>	<b>64</b>
<b>Annex L (informative) Power supply .....</b>	<b>65</b>
<b>Annex M (informative) Information concerning test procedures and requirements for the response to slowly developing fires .....</b>	<b>66</b>
<b>Annex ZA (informative) Clauses of this European Standard addressing the provisions of the EU Construction Products Regulation .....</b>	<b>70</b>
<b>ZA.1 Scope and relevant characteristics .....</b>	<b>70</b>
<b>ZA.2 Procedure for assessment and verification of constancy of performance (AVCP) of duct smoke detectors .....</b>	<b>72</b>
<b>ZA.2.1 System of AVCP .....</b>	<b>72</b>
<b>ZA.2.2 Declaration of performance (DoP) .....</b>	<b>73</b>
<b>ZA.3 CE marking and labelling .....</b>	<b>78</b>
<b>Bibliography .....</b>	<b>81</b>