

DIN EN 54-12:2015-10 (E)

Fire detection and fire alarm systems - Part 12: Smoke detectors - Line detectors using an optical beam

Contents		Page
Foreword		5
1	Scope	7
2	Normative references	7
3	Terms and definitions	8
4	Requirements	9
4.1	Compliance	9
4.2	Operational reliability	9
4.2.1	Individual alarm indication	9
4.2.2	Connection of ancillary devices	9
4.2.3	Manufacturer's adjustments	9
4.2.4	On-site adjustment of response value	9
4.2.5	Protection against ingress of foreign bodies	10
4.2.6	Monitoring of detachable detectors and connections	10
4.2.7	Requirements for software controlled detectors (when provided)	10
4.3	Nominal activation conditions/sensitivity	11
4.3.1	Reproducibility	11
4.3.2	Repeatability	11
4.3.3	Tolerance to beam misalignment	11
4.3.4	Rapid changes in attenuation	12
4.3.5	Response to slowly developing fires	12
4.3.6	Optical path length dependence	12
4.3.7	Stray light	12
4.4	Tolerance to supply voltage - Variation in supply parameters	12
4.5	Performance parameters under fire conditions - Fire sensitivity	12
4.6	Durability of nominal activation conditions/sensitivity	12
4.6.1	Temperature resistance	12
4.6.2	Humidity resistance	13
4.6.3	Vibration resistance	13
4.6.4	Electrical stability - Electromagnetic Compatibility (EMC), Immunity tests (operational) ...	13
4.6.5	Corrosion resistance - Sulphur dioxide (SO ₂) corrosion (endurance)	13
5	Testing, assessment and sampling methods	13
5.1	General	13
5.1.1	Atmospheric conditions for tests	13
5.1.2	Operating conditions for tests	14
5.1.3	Mounting arrangements	14
5.1.4	Tolerances	14
5.1.5	Measurement of response value	14
5.1.6	Provision for tests	15
5.1.7	Test schedule	15
5.2	Operational reliability	16
5.2.1	Individual alarm indication	16
5.2.2	Connection of ancillary devices	16
5.2.3	Manufacturer's adjustments	16
5.2.4	On-site adjustment of response value	16
5.2.5	Protection against ingress of foreign bodies	17
5.2.6	Monitoring of detachable detectors and connections	17

5.2.7	Additional requirements for software controlled detectors	17
5.3	Normal activation conditions/sensitivity	17
5.3.1	Reproducibility	17
5.3.2	Repeatability	17
5.3.3	Tolerance to beam misalignment	18
5.3.4	Rapid changes in attenuation	19
5.3.5	Response to slowly developing fires	19
5.3.6	Optical path length dependence	19
5.3.7	Stray light	20
5.4	Tolerance to supply voltage -- Variation of supply parameters	21
5.4.1	Object of the test	21
5.4.2	Test procedure	21
5.4.3	Test requirements	21
5.5	Performance parameters under fire conditions	21
5.5.1	Fire sensitivity	21
5.6	Durability of nominal activation conditions/sensitivity	23
5.6.1	Temperature resistance	23
5.6.2	Humidity resistance	25
5.6.3	Vibration resistance	27
5.6.4	Electrical stability - Electromagnetic compatibility (EMC), immunity tests (operational) ...	29
5.6.5	Corrosion resistance -- Sulphur dioxide (SO ₂) corrosion (endurance)	30
6	Assessment and verification of constancy of performance (AVCP)	30
6.1	General	30
6.2	Type testing	31
6.2.1	General	31
6.2.2	Test samples, testing and compliance criteria	32
6.2.3	Test reports	32
6.3	Factory production control (FPC)	32
6.3.1	General	32
6.3.2	Requirements	33
6.3.3	Product specific requirements	35
6.3.4	Initial inspection of factory and FPC	36
6.3.5	Continuous surveillance of FPC	36
6.3.6	Procedure for modifications	36
6.3.7	One-off products, pre-production products, (e.g. prototypes) and products produced in very low quantities	37
7	Classification and designation	37
8	Marking, labelling and packaging	37
Annex A (normative) Bench for response value measurements		39
A.1	Technical characteristics of the attenuators	39
A.2	Measuring bench	40
Annex B (normative) Fire test room		41
Annex C (normative) Smouldering (pyrolysis) wood fire (TF2)		43
C.1	Fuel	43
C.2	Hotplate	43
C.3	Arrangement	43
C.4	Heating rate	44
C.5	End of test condition	44
C.6	Test validity criteria	44
Annex D (normative) Glowing smouldering cotton fire (TF3)		46
D.1	Fuel	46
D.2	Arrangement	46

D.3	Ignition	46
D.4	End of test condition	47
D.5	Test validity criteria	47
Annex E (normative) Flaming plastics (polyurethane) fire (TF4)		49
E.1	Fuel	49
E.2	Arrangement	49
E.3	Ignition	49
E.4	End of test condition	49
E.5	Test validity criteria	49
Annex F (normative) Flaming liquid (n-heptane) fire (TF5)		51
F.1	Fuel	51
F.2	Arrangement	51
F.3	Ignition	51
F.4	End of test condition	51
F.5	Test validity criteria	51
Annex G (normative) Apparatus for stray light		53
G.1	Installation	53
G.2	The light source	54
Annex H (informative) Information concerning the requirements for the response to slowly developing fires		56
Annex I (informative) Data supplied with line detectors using an optical beam		60
Annex ZA (informative) Clauses of this European Standard addressing the provisions of the EU Construction Products Regulation		61
Bibliography		71