

DIN EN 15004-1:2019-06 (E)

Fixed firefighting systems - Gas extinguishing systems - Part 1: Design, installation and maintenance (ISO 14520-1:2015, modified)

Contents		Page
European foreword		5
Introduction		7
1	Scope	8
2	Normative references	9
3	Terms and definitions	10
4	Use and limitations	13
4.1	General	13
4.2	Extinguishants	14
4.2.1	General	14
4.2.2	Environmental properties	15
4.3	Electrostatic discharge	15
4.4	Compatibility with other extinguishants	15
4.5	Temperature limitations	15
5	Safety	15
5.1	Hazard to personnel	15
5.2	Safety precautions	16
5.2.1	General	16
5.2.2	For normally occupied areas	16
5.2.3	For normally unoccupied areas	18
5.2.4	For unoccupiable areas	18
5.3	Occupiable areas	18
5.4	Electrical hazards	19
5.5	Electrical earthing	20
5.6	Electrostatic discharge	20
6	System design	20
6.1	General	20
6.2	Extinguishant supply	21
6.2.1	Quantity	21
6.2.2	Quality	21
6.2.3	Container arrangement	21
6.2.4	Storage containers	21
6.3	Distribution	22
6.3.1	General	22
6.3.2	Piping	23
6.3.3	Fittings	24
6.3.4	Pipe and valve supports	24
6.3.5	Valves	25
6.3.6	Nozzles	25
6.3.7	Pressure reducing orifice assembly	26
6.4	Detection, actuation and control systems	26
6.4.1	General	26
6.4.2	Automatic detection	27
6.4.3	Operating devices	27
6.4.4	Control equipment	28

6.4.5	Operating alarms and indicators	28
6.4.6	Stop device	28
7	Extinguishant system design	28
7.1	General	28
7.2	Specifications, plans and approvals	29
7.2.1	Specifications	29
7.2.2	Working documents	29
7.3	System flow calculations	29
7.3.1	General	29
7.3.2	Balanced and unbalanced system	29
7.3.3	Friction losses	31
7.3.4	Pressure drop	31
7.3.5	Valves and fittings	32
7.3.6	Piping length	32
7.3.7	Drawings	32
7.3.8	Liquefied gases -- Specific requirements	32
7.4	Enclosures	32
7.5	Extinguishant concentration requirements	33
7.5.1	Flame extinguishment	33
7.5.2	Inerting	34
7.6	Total flooding quantity	34
7.6.1	General	34
7.6.2	Liquefied gases	34
7.6.3	Non-liquefied gas	35
7.7	Altitude adjustment	35
7.8	Duration of protection	36
7.9	System performance	36
7.9.1	Discharge time	36
7.9.2	Extended discharge	37
8	Commissioning and acceptance	37
8.1	General	37
8.2	Tests	37
8.2.1	General	37
8.2.2	Enclosure check	37
8.2.3	Review of mechanical components	37
8.2.4	Review of enclosure integrity	39
8.2.5	Review of electrical components	39
8.2.6	Preliminary functional tests	40
8.2.7	System functional operational test	40
8.2.8	Remote monitoring operations (if applicable)	40
8.2.9	Control panel primary power source	41
8.2.10	Completion of functional tests	41
8.3	Completion certificate and documentation	41
9	Inspection, maintenance, testing and training	41
9.1	General	41
9.2	Inspection	41
9.2.1	General	41
9.2.2	Container	42
9.2.3	Hose	42
9.2.4	Enclosures	42
9.3	Maintenance	42
9.3.1	General	42
9.3.2	User's programme of inspection	43
9.3.3	Service schedule	43
9.4	Training	43
	Annex A (normative) Working documents	44

Annex B (normative) Determination of flame-extinguishing concentration of gaseous extinguishants by the cup burner method	46
Annex C (normative) Fire extinguishment/area coverage fire test procedure for engineered and pre-engineered extinguishing units	53
Annex D (normative) Method of evaluating inerting concentration of a fire extinguishant	83
Annex E (normative) Door fan test for determining of minimum hold time	85
Annex F (informative) System performance verification	104
Annex G (informative) Safe personnel exposure guidelines	105
Annex H (informative) Flow calculation implementation method and flow calculation verification and testing for approvals	112
Bibliography	116