DIN EN 14972-9:2020-06 (E)

Fixed firefighting systems - Water mist systems - Part 9: Test protocol for machinery in enclosures not exceeding 260 m<(hoch)3> for open nozzle systems

Contents

Page

European foreword ... 3

1 Scope ... 4

2 Normative references ... 4

3 Terms and definitions ... 4

4 General requirements ... 4

5 Test enclosure requirements ... 5

6 Machinery mock-up requirement ... 6

7 Test equipment requirements ... 7

8 Instrumentation requirements ... 8

9 Fire test requirements ... 9
9.1 General ... 9
9.2 Unshielded 1 MW diesel spray fire ... 9
9.3 Shielded 1 MW diesel spray fire ... 10
9.4 Shielded 1 m² diesel pool fire ... 10
9.5 Shielded 2 MW diesel spray fire, system performance under limited natural ventilation ... 11
9.6 Shielded 2 MW diesel spray fire, system performance at smaller enclosure volumes ... 11
9.7 Unshielded 1 MW heptane spray fire ... 12
9.8 Shielded 1 MW heptane spray fire ... 12
9.9 Shielded 1 m² heptane pool fire ... 13
9.10 Shielded 2 MW heptane spray fire, system performance under limited natural ventilation ... 13
9.11 Shielded 2 MW heptane spray fire, system performance at smaller enclosure volumes ... 14

10 Test report ... 14