

DIN EN 14972-9:2020-06 (E)

Fixed firefighting systems - Water mist systems - Part 9: Test protocol for machinery in enclosures not exceeding 260 m³ for open nozzle systems

Contents		Page
European foreword.....		3
1	Scope.....	4
2	Normative references.....	4
3	Terms and definitions.....	4
4	General requirements.....	4
5	Test enclosure requirements.....	5
6	Machinery mock-up requirement.....	6
7	Test equipment requirements.....	7
8	Instrumentation requirements.....	8
9	Fire test requirements.....	9
9.1	General.....	9
9.2	Unshielded 1 MW diesel spray fire.....	9
9.3	Shielded 1 MW diesel spray fire.....	10
9.4	Shielded 1 m² diesel pool fire.....	10
9.5	Shielded 2 MW diesel spray fire, system performance under limited natural ventilation.....	11
9.6	Shielded 2 MW diesel spray fire, system performance at smaller enclosure volumes.....	11
9.7	Unshielded 1 MW heptane spray fire.....	12
9.8	Shielded 1 MW heptane spray fire.....	12
9.9	Shielded 1 m² heptane pool fire.....	13
9.10	Shielded 2 MW heptane spray fire, system performance under limited natural ventilation.....	13
9.11	Shielded 2 MW heptane spray fire, system performance at smaller enclosure volumes.....	14
10	Test report.....	14