

DIN EN 12259-14:2020-07 (E)

Fixed firefighting systems - Components for sprinkler and water spray systems - Part 14: Sprinklers for residential applications

Contents		Page
European foreword		6
1	Scope	7
2	Normative references	7
3	Terms and definitions	7
4	Construction and performance	10
4.1	General	10
4.2	Dimensions and pressure rating	10
4.3	Nominal operating temperature	11
4.4	Operating temperatures	11
4.5	Water flow and distribution	12
4.6	Function	13
4.7	Fire Test	13
4.8	Strength of sprinkler body and deflector	13
4.9	Strength of release element	14
Figure 1 -- Graph of service load and bulb strength distribution curves		14
4.10	Leak resistance and hydrostatic strength	15
4.11	Heat exposure	15
4.12	Corrosion	15
4.13	Water hammer	16
4.14	Thermal response	16
4.15	Resistance to vibration	16
4.16	Resistance to impact	16
4.17	Resistance to low temperature	16
4.18	Resistance to heat	16
4.19	Test conditions	16
5	Marking	17
5.1	General	17
5.2	Identification number	17
5.3	Nominal operating temperature and year of manufacture	17
5.4	Manufacturing location	17
5.5	Heat sensitive element supplier	17
5.6	Protective covers	17
5.7	Sidewall sprinklers	18
5.8	Concealed sprinklers	18
5.9	Removable recessed housing	18
6	Instruction charts	18
6.1	General	18
6.2	Installation Instructions	18
Annex A(normative) Conditions for tests		20
Annex B(normative) Water flow test		21
Figure B.1-- Water flow test apparatus		22

Annex C(normative) Water distribution test	23
C.1 Water distribution test - Horizontal surface	23
C.1.1 General	23
C.1.2 Upright, pendant, flush, recessed and concealed sprinklers	23
Figure C.1 -- Horizontal surface water collection for upright and pendant sprinklers	24
C.1.3 Sidewall Sprinklers	24
Figure C.2 -- Horizontal surface water collection for sidewall sprinklers	25
C.2 Water distribution test - vertical surface	26
C.2.1 Test method	26
Figure C.3 -- Vertical water collection	27
C.3 Water impingement test	28
Annex D(normative) Fire test	29
D.1 Extent of testing	29
Figure D.1 -- Fire test arrangement - pendant, upright, flush, recessed pendant, and concealed sprinklers	30
Figure D.2 -- Fire test arrangement - sidewall sprinklers, test arrangement No. 1	31
Figure D.3 -- Fire test arrangement - sidewall sprinklers, test arrangement No. 2	32
D.2 Test arrangement	33
D.2.1 Test room	33
Figure D.4 -- Corner fire test ignition and fuel package	34
Table D.1 -- Plywood burning characteristics	35
D.2.2 Fire source	35
Table D.2 -- Polyether foam burning characteristics	36
D.2.3 Sprinkler installation	36
D.3 Test method	37
D.4 Supplementary test	38
Annex E(normative) Function test	39
E.1 Function test	39
E.2 Verification function test	39
Figure E.1 -- Example of functional test oven	40
Annex F(normative) Strength of sprinkler body and deflector	41
F.1 Strength of sprinkler bod	41
Figure F.1 -- Example of a tensile/compression test machine	41
F.2 Flow endurance test	42
F.3 Deflector strength test	42
Annex G(normative) Strength of release elements test	43
G.1 Glass bulbs	43
G.2 Fusible links	45
Annex H(normative) Leak resistance tests	46

H.1	Leak Test	46
H.2	Hydrostatic Strength Test	46
Table H.1 -- Test pressures for the leakage and hydrostatic tests		46
Annex I(normative) Heat exposure		47
I.1	High temperature test	47
Table I.1 -- High temperature test conditions		47
I.2	Additional testing of glass bulb sprinklers	47
I.3	Additional testing of residential sprinklers using o-rings	48
Annex J(normative) Glass bulb sprinkler thermal shock test		49
Annex K(normative) Exposure and corrosion tests		50
K.1	Stress corrosion	50
K.1.1	Sample preparation	50
K.1.2	Apparatus	50
K.1.3	Procedure	50
K.2	Sulphur dioxide corrosion	50
K.2.1	Reagents for apparatus of 5 l volume	50
K.2.2	Apparatus	51
K.2.3	Procedure	51
Figure K.1 -- Typical vessel for sulphur dioxide corrosion test		52
K.3	Salt mist corrosion	52
K.3.1	Reagents	52
K.3.2	Apparatus	52
K.3.3	Procedure	52
K.4	Moist Air	53
K.4.1	Performance criteria	53
K.4.2	Procedure	53
Annex L(normative) Water hammer test		54
Annex M(normative) Thermal response test		55
M.1	Oven heat test	55
M.2	Room heat test	56
M.2.1	Flush, recessed or concealed sprinklers	56
M.2.2	Sprinkler location and orientation	56
M.2.3	Room dimensions and water supply	57
M.2.4	Fire source and distance to sprinkler	57
Figure M.1 -- Typical sand burner apparatus		58
Figure M.2 -- Plan view of room heat test for residential sprinklers		59
Annex N(normative) Vibration test		60
N.1	Sample preparation and performance criteria	60
N.2	Procedure	60
Table N.1 -- Vibration test		60
Annex O(normative) Impact test		61
Annex P(normative) Resistance to low temperature test		62
Annex Q(normative) Resistance to high temperature test		63
Bibliography		64