## ISO 20338:2019 (E)

# Oxygen reduction systems for fire prevention — Design, installation, planning and maintenance

### Contents

Foreword

#### Introduction

- 1 Scope
- 2 Normative references
- 3 Terms and definitions

#### 4 System requirements

- 4.1 General
- 4.2 Personnel safety
- 4.3 Effectiveness and application
- 4.4 Alarm organization and emergency plan

#### 5 Design

- 5.1 Qualification of the designer
- 5.2 Fire protection concept
- 5.3 Structural specifications for the protected area
- 5.4 Oxygen concentration
- 5.5 Oxygen reduction to prevent fire
- 5.6 Safety margins
- 5.7 Oxygen reduced air quantity
- 5.7.1 Continuous oxygen reduction
- 5.7.2 Emergency plan
- 5.7.3 Oxygen reduced air
- 5.7.3.1 System using containers
- 5.7.3.2 System using vaporizer
- 5.7.3.3 System using oxygen-reduced air production equipment
- 5.7.4 Fault signals
- 5.8 Technical areas
- 5.8.1 Technical area for control panel
- 5.8.2 Technical area for reduced oxygen air generation

#### 6 Distribution pipework

- 6.1 Pipework
- 6.2 Pipe supports
- 6.3 Components in the pipework
- 7 Monitoring the oxygen concentration
- 8 Alarms and notifications

#### 9 Control equipment

- 9.1 Function
- 9.2 Requirements
- 9.3 Electrical power supply
- 9.4 Electrical cabling installations
- 9.5 Data recording
- 10 System operation
  - 10.1 Instruction and training of personnel

- 10.2 Inspections
- 10.3 Operations log
- 10.4 Further obligations
- 11 Maintenance
- 12 Documentation
- 13 Installation
  - 13.1 Qualification of the installer
  - 13.2 General specifications Installation
- Annex A (normative) Ignition thresholds for oxygen reduction using nitrogen-enriched air in fire prevention
  - A.1 Ignition thresholds
  - A.2 Tests to ascertain ignition thresholds of unfamiliar materials
  - A.2.1 Cup burner tests
  - A.2.2 Ignition threshold tests
  - A.2.2.1 General
  - A.2.2.2 Test procedure
  - A.2.2.3 Test criteria
  - A.2.2.4 Test documentation

Page count: 24