

ISO 6182-1:2021-05 (E)

Fire protection - Automatic sprinkler systems - Part 1: Requirements and test methods for sprinklers

Contents		Page
Foreword		vii
Introduction		viii
1	Scope	1
2	Normative references	1
3	Terms and definitions	1
3.1	General	1
3.2	Types of sprinklers according to type of responsive element	4
3.3	Types of sprinklers according to type of water distribution	4
3.4	Types of sprinklers according to position	5
3.5	Special types of sprinklers	6
3.6	Types of sprinklers according to sprinkler sensitivity	7
4	Product consistency	8
4.1	Quality control programme	8
4.2	Leak resistance testing	8
4.3	Glass bulb integrity test	8
5	Product assembly	8
5.1	General	8
5.2	Dynamic O-ring seals	8
5.3	Rated pressure	8
5.4	Dry sprinklers	9
5.5	Escutcheons	9
6	Requirements	9
6.1	General	9
6.1.1	Electrically activated sprinkler and monitoring of activation	9
6.1.2	Orifice size	9
6.1.3	Nominal thread sizes	9
6.2	Maximum coverage areas and spacing	10
6.3	Temperature ratings and colour coding	10
6.4	Service load and strength of sprinkler body (see 7.4)	11
6.5	Strength of heat-responsive element (see 7.5)	11
6.5.1	Glass bulb elements	11
6.5.2	Fusible elements	12
6.6	Leak resistance and hydrostatic strength (see 7.6)	12
6.7	Thirty-day leakage resistance (see 7.7)	12
6.8	Vacuum resistance (see 7.8)	13
6.9	Water hammer (see 7.9)	13
6.10	Vibration (see 7.10)	13
6.11	Deflector strength (see 7.11)	13
6.12	Water shield rotation (see 7.12)	13
6.13	Impact (see 7.13)	13
6.14	Protective covers (see 7.14)	13
6.15	Rough usage (see 7.15)	14
6.16	Dry sprinkler air tightness (see 7.16)	14
6.17	Operating temperature (see 7.17)	14
6.18	Sensitivity — response time index (RTI) (see 7.18)	14
6.18.1	Pre-exposure RTI	14
6.18.2	Post-exposure RTI	15

6.19	Sensitivity test of flush, concealed and recessed sprinklers (see 7.19).....	15
6.19.1	General.....	15
6.19.2	Room response test (see 7.19.2).....	15
6.19.3	Plunge test (see 7.19.3).....	15
6.20	Lodgement (see 7.20).....	16
6.21	Heat exposure (see 7.21).....	17
6.21.1	Glass bulb sprinklers.....	17
6.21.2	All sprinklers.....	17
6.21.3	Coated sprinklers.....	17
6.22	Sprinkler coatings (see 7.22).....	17
6.22.1	Evaporation of wax and bitumen.....	17
6.22.2	Resistance to low temperatures.....	17
6.23	Thermal shock for glass bulb sprinklers (see 7.23).....	17
6.24	Resistance to heat (see 7.24).....	17
6.25	Freezing test (see 7.25).....	17
6.26	Corrosion (see 7.26).....	18
6.26.1	Stress corrosion for copper-based alloy components (see 7.26.1).....	18
6.26.2	Stress corrosion for stainless steel components (see 7.26.2).....	18
6.26.3	Sulphur dioxide/carbon dioxide corrosion (see 7.26.3).....	18
6.26.4	Hydrogen sulphide corrosion (see 7.26.4).....	18
6.26.5	Salt spray loading (see 7.26.5).....	18
6.26.6	Moist air exposure (see 7.26.6).....	19
6.26.7	Dry-type sprinkler deposit loading (see 7.26.7).....	19
6.26.8	Dezincification of brass parts (see 7.26.8).....	19
6.27	Water flow constant (see 7.27).....	19
6.28	Water distribution (see 7.28).....	20
6.28.1	General.....	20
6.28.2	Spray, flat spray, conventional and dry sprinkler water distribution (see 7.28.2).....	21
6.28.3	Domestic sprinkler water distribution (see 7.28.3).....	22
6.28.4	Extended coverage light hazard sprinkler water distribution (see 7.28.4).....	22
6.28.5	Extended coverage ordinary hazard sprinkler water distribution (see 7.28.5).....	23
6.28.6	K202 and K242 pendent ESFR sprinkler water distribution (see 7.28.6).....	23
6.28.7	Thrust force measurements for K202 and K242 pendent ESFR sprinklers (see 7.28.7).....	28
6.29	Lateral discharge (see 7.29).....	28
6.30	Water shield angle of protection (see 7.30).....	28
6.31	Fire performance (see 7.31).....	29
6.31.1	General.....	29
6.31.2	Spray sprinkler fire performance (see 7.31.2).....	30
6.31.3	Domestic sprinkler fire performance (see 7.31.3).....	30
6.31.4	Extended coverage light hazard sprinkler fire performance (see 7.31.4).....	31
6.31.5	Extended coverage ordinary hazard sprinkler fire performance (see 7.31.5).....	31
6.31.6	Nominal K-202 and K-242 pendent ESFR fire performance (see 7.31.6).....	31
6.31.7	Standard coverage storage, extended coverage storage and ESFR (Other than K202 & K242 Pendent) sprinkler fire test performance (see 7.31.7).....	32
6.32	Electrical characteristics.....	33
Test methods		33
7.1	General.....	33
7.2	Preliminary examination.....	33
7.3	Visual examination.....	33
7.4	Service load and strength of sprinkler body test (see 6.4).....	34
7.4.1	Test option 1.....	34
7.4.2	Test option 2.....	34
7.4.3	Test option 3.....	35
7.5	Strength of heat-responsive element test (see 6.5).....	35
7.5.1	Glass bulbs.....	35
7.5.2	Fusible elements.....	35
7.6	Leak resistance and hydrostatic strength tests (see 6.6).....	36
7.7	Thirty-day leakage test (see 6.7).....	36
7.8	Vacuum test (see 6.8).....	36
7.9	Water hammer test (see 6.9).....	36
7.10	Vibration test (see 6.10).....	37

7.11	Deflector strength test (see 6.11)	37
7.12	Water shield rotation test (see 6.12)	37
7.13	Impact (see 6.13)	37
7.14	Protective cover impact test for glass bulb sprinklers (see 6.14)	38
7.15	Rough usage test (see 6.15)	39
7.16	Dry sprinkler air tightness test (see 6.16)	40
7.17	Operating temperature tests (see 6.17)	41
	7.17.1 Liquid test	41
	7.17.2 Air test	42
7.18	Sensitivity test — response time index (RTI) (see 6.18)	43
	7.18.1 Plunge test	43
	7.18.2 Response time index (RTI) calculation	44
7.19	Sensitivity test for flush, concealed and recessed sprinklers (see 6.19)	44
	7.19.1 General	44
	7.19.2 Room response test	44
	7.19.3 Plunge test	49
7.20	Lodgement test (see 6.20)	52
7.21	Heat exposure test (see 6.21)	55
	7.21.1 Glass bulb sprinklers (see 6.21.1)	55
	7.21.2 All sprinklers (see 6.21.2)	55
	7.21.3 Coated sprinklers (see 6.21.3)	55
7.22	Sprinkler coatings (see 6.22)	56
	7.22.1 Evaporation of wax and bitumen test (see 6.22.1)	56
	7.22.2 Low temperature test (see 6.22.2)	56
7.23	Thermal shock test for glass bulb sprinklers (see 6.23)	56
7.24	Resistance to heat test (see 6.24)	56
7.25	Freezing (see 6.25)	57
7.26	Corrosion tests (see 6.26)	57
	7.26.1 Stress corrosion test for copper-based alloy components (see 6.26.1)	57
	7.26.2 Stress corrosion for stainless steel components (see 6.26.2)	57
	7.26.3 Sulphur dioxide/carbon dioxide corrosion test (see 6.26.3)	58
	7.26.4 Hydrogen sulphide corrosion test (see 6.26.4)	58
	7.26.5 Salt spray loading test (see 6.26.5)	59
	7.26.6 Moist air exposure (see 6.26.6)	59
	7.26.7 Dry-type sprinkler deposit loading test (see 6.26.7)	59
	7.26.8 Dezincification of brass components (see 6.26.8)	60
7.27	Water flow constant (see 6.27)	61
7.28	Water distribution tests (see 6.28)	62
	7.28.1 General	62
	7.28.2 Spray, flat spray, conventional and dry sprinklers (see 6.28.2)	62
	7.28.3 Domestic sprinklers (see 6.28.3)	70
	7.28.4 Extended coverage light hazard sprinklers (see 6.28.4)	74
	7.28.5 Extended coverage ordinary hazard sprinklers (see 6.28.5)	81
	7.28.6 K202 and K242 pendent ESFR sprinklers (see 6.28.6)	81
	7.28.7 Thrust force test (see 6.28.7)	86
7.29	Lateral discharge test (see 6.29)	87
	7.29.1 General	87
	7.29.2 Upright and pendent sprinklers	87
	7.29.3 Sidewall sprinklers	88
	7.29.4 Exposure to heat and flame	88
	7.29.5 Consumption of heptane	88
7.30	Water shield angle of protection (see 6.30)	88
7.31	Fire performance (see 6.31)	89
	7.31.1 General	89
	7.31.2 Spray sprinkler fire performance	89
	7.31.3 Domestic sprinkler fire performance (see 6.31.3)	92
	7.31.4 Extended coverage light hazard sprinkler fire performance (see 6.31.4)	99
	7.31.5 Extended coverage ordinary hazard sprinkler fire performance (see 6.31.5)	102

7.31.6	Actual delivered density (nominal K-202 and K-242 pendent ESFR fire performance) (see 6.31.6).....	103
7.31.7	Standard coverage storage, extended coverage storage and ESFR (other than K202 & K242 pendent) sprinkler fire test performance (see 6.31.7).....	104
7.32	Electrical characteristics	106
7.32.1	Starting current and response time (see 6.32.1).....	106
7.32.2	Monitoring current (see 6.32.2).....	106
7.32.3	Wires (6.32.3).....	106
8	Marking	106
8.1	Sprinklers	106
8.2	Sprinkler housings and concealed-sprinkler cover plates.....	108
8.3	Protective covers.....	108
9	Manufacturer's installation instructions	108
	Annex A (normative) Tolerance limit calculation methods	111
	Annex B (informative) Analysis of the strength test for fusible element	113
	Annex C (normative) Tolerances	114
	Annex D (informative) Standard test commodities and fire test configurations	115
	Annex E (informative) Fire test arrangements for extended coverage ordinary hazard	119
	Annex F (informative) Statistical tolerance limits	122
	Bibliography	125