

# ISO 14520-1:2023-02 (E)

## Gaseous fire-extinguishing systems - Physical properties and system design - Part 1: General requirements

---

<b>Contents</b>		<b>Page</b>
Foreword .....		vi
Introduction .....		viii
<b>1</b>	<b>Scope .....</b>	<b>1</b>
<b>2</b>	<b>Normative references .....</b>	<b>2</b>
<b>3</b>	<b>Terms and definitions .....</b>	<b>3</b>
<b>4</b>	<b>Use and limitations .....</b>	<b>6</b>
4.1	General .....	6
4.2	Extinguishants .....	6
4.2.1	General .....	6
4.2.2	Environmental properties .....	7
4.3	Electrostatic discharge .....	7
4.4	Compatibility with other extinguishants .....	7
4.5	Temperature limitations .....	7
<b>5</b>	<b>Safety .....</b>	<b>8</b>
5.1	Hazard to personnel .....	8
5.2	Safety precautions .....	8
5.2.1	General .....	8
5.2.2	For normally occupied areas .....	9
5.2.3	For normally unoccupied areas .....	10
5.2.4	For unoccupiable areas .....	10
5.3	Occupiable areas .....	10
5.4	Electrical hazards .....	11
5.5	Electrical earthing .....	12
5.6	Electrostatic discharge .....	12
<b>6</b>	<b>System design .....</b>	<b>12</b>
6.1	General .....	12
6.2	Extinguishant supply .....	12
6.2.1	Quantity .....	12
6.2.2	Quality .....	12
6.2.3	Container arrangement .....	12
6.2.4	Storage containers .....	13
6.3	Distribution .....	14
6.3.1	General .....	14
6.3.2	Piping .....	15
6.3.3	Fittings .....	15
6.3.4	Pipe and valve supports .....	15
6.3.5	Valves .....	16
6.3.6	Nozzles .....	16
6.3.7	Pressure reducing orifice assembly .....	17
6.4	Detection, actuation and control systems .....	17
6.4.1	General .....	17
6.4.2	Automatic detection .....	17
6.4.3	Operating devices .....	18
6.4.4	Control equipment .....	18

6.4.5	Operating alarms and indicators .....	19
6.4.6	Hold switches .....	19
7	Extinguishant system design .....	19
7.1	General .....	19
7.2	Specifications, plans and approvals .....	19
7.2.1	Specifications .....	19
7.2.2	Working documents .....	19
7.3	System flow calculations .....	20
7.3.1	General .....	20
7.3.2	A balanced and unbalanced system .....	20
7.3.3	Friction losses .....	21
7.3.4	Pressure drop .....	21
7.3.5	Elevation changes .....	22
7.3.6	Valves and fittings .....	22
7.3.7	Piping length .....	22
7.3.8	Drawings .....	22
7.3.9	Liquefied gases -- Specific requirements .....	22
7.4	Enclosures .....	22
7.5	Effects of noise .....	22
7.6	Extinguishant concentration requirements .....	23
7.6.1	Flame extinguishment .....	23
7.6.2	Inerting .....	24
7.7	Total flooding quantity .....	25
7.7.1	General .....	25
7.7.2	Liquefied gases .....	25
7.7.3	Non-liquefied gas .....	25
7.8	Altitude adjustment .....	26
7.9	Duration of protection .....	26
7.10	System performance .....	27
7.10.1	Discharge time .....	27
7.10.2	Extended discharge .....	27
8	Commissioning and acceptance .....	27
8.1	General .....	27
8.2	Tests .....	27
8.2.1	General .....	27
8.2.2	Enclosure check .....	27
8.2.3	Review of mechanical components .....	28
8.2.4	Review of enclosure integrity .....	29
8.2.5	Review of electrical components .....	29
8.2.6	Preliminary functional tests .....	30
8.2.7	System functional operational test .....	30
8.2.8	Remote monitoring operations (if applicable) .....	31
8.2.9	Control panel primary power source .....	31
8.2.10	Completion of functional tests .....	31
8.3	Completion certificate and documentation .....	31
9	Inspection, maintenance, testing and training .....	31
9.1	General .....	31
9.2	Inspection .....	32
9.2.1	General .....	32
9.2.2	Container .....	32
9.2.3	Hose .....	32
9.2.4	Enclosures .....	32
9.3	Maintenance .....	33
9.3.1	General .....	33
9.3.2	User's programme of inspection .....	33
9.3.3	Service schedule .....	33
9.4	Training .....	33

<b>Annex A (normative) Working documents .....</b>	<b>34</b>
<b>Annex B (normative) Determination of flame-extinguishing concentration of gaseous extinguishants by the cup burner method .....</b>	<b>36</b>
<b>Annex C (normative) Fire extinguishment/area coverage fire test procedure for engineered and pre-engineered extinguishing units .....</b>	<b>42</b>
<b>Annex D (informative) Method of evaluating inerting concentration of a fire extinguishant .....</b>	<b>71</b>
<b>Annex E (normative) Door fan test for determining of minimum hold time .....</b>	<b>74</b>
<b>Annex F (informative) System performance verification .....</b>	<b>90</b>
<b>Annex G (normative) Safe personnel exposure guidelines .....</b>	<b>91</b>
<b>Annex H (informative) Flow calculation implementation method and flow calculation verification and testing for approvals .....</b>	<b>99</b>
<b>Annex I (informative) Scaling factors for Class B fuels other than heptane .....</b>	<b>103</b>
<b>Annex J (normative) Criteria for assessment of new extinguishants for inclusion in the ISO 14520 series .....</b>	<b>104</b>
<b>Bibliography .....</b>	<b>106</b>