

DIN EN 12259-15:2025-06 (E)

Fixed firefighting systems - Components for sprinkler and water spray systems - Part 15: Spray pattern sprinklers with a k-factor of at least K160, extended coverage sprinklers of at least K80 and control mode special application sprinklers

Contents		Page
European foreword		3
Introduction		4
1	Scope	5
2	Normative references	5
3	Terms and definitions	5
4	Assessment methods and criteria	6
4.1	Tolerances	6
4.2	Connections	6
4.3	Durability of coated sprinklers	6
4.4	High temperature exposure	6
4.5	Conductivity (C-Factor)	7
4.6	Sensitivity (Air oven)	7
4.7	Leak resistance	9
4.8	Release of the sprinkler at minimum operating pressure (for spray pattern, EC and ECS sprinklers)	9
4.9	Nominal operating temperature	9
4.10	Function (only for CMSA)	10
4.11	Size of water passageways	11
4.12	Sprinkler temperature identification	11
4.13	Water distribution	12
4.14	Actual Delivered Density	22
4.15	Extinguishing performance	27
4.16	Discharge coefficient	28
4.17	Sensitivity (Response time index)	31
4.18	Frame strength	31
4.19	Strength of release element - fusible link type	32
4.20	Strength of release element - bulb type	33
4.21	Water hammer	36
4.22	Strength of deflector	36
4.23	Vibration resistance	36
4.24	Impact test	37
4.25	Freezing	37
4.26	High ambient temperature exposure (90-day test)	38
4.27	Thermal shock	38
4.28	Corrosion	38
5	Marking	38
6	Manufacturer's installation instructions	39
Annex A (normative)	Tolerances	41
Annex B (normative)	Extinguishing performance	42

B.1	General	42
B.2	Values for performance under fire	42
	Annex C (informative) Actual delivered density (ADD)	78
	Bibliography	80