DIN EN 14825:2013-12 (E)

Air conditioners, liquid chilling pack ages and heat pumps, with electrically driven compressors, for space heating and cooling - Testing and rating at part load conditions and calculation of seasonal performance

Contents

Page

Foreword 5

Introduction 7

1 Scope 8

2 Normative references 8

3 Terms, definitions, symbols, abbreviated terms and units 8
3.1 Terms and definitions 8
3.2 Symbols, abbreviated terms and units 17

4 Part load conditions in cooling mode 19
4.1 General 19
4.2 Air-to-air units 19
4.3 Water-to-air units and brine-to-air units 20
4.4 Air-to-water units 20
4.5 Water-to-water and brine-to-water units 21

5 Part load conditions in heating mode 22
5.1 General 22
5.2 Air-to-air units 23
5.3 Water-to-air and brine-to-air units 24
5.4 Air-to-water units 25
5.4.1 General 25
5.4.2 Low temperature application 26
5.4.3 Medium temperature application 29
5.4.4 High temperature application 32
5.4.5 Very high temperature application 35
5.5 Water-to-water and brine-to-water units 37
5.5.1 General 37
5.5.2 Low temperature application 38
5.5.3 Medium temperature application 41
5.5.4 High temperature application 44
5.5.5 Very high temperature application 47

6 Calculation methods for reference SEER and reference SEERon 49
6.1 General formula for calculation of reference SEER 49
6.2 Calculation of the reference annual cooling demand (QC) 49
6.3 Calculation of the reference annual electricity consumption (QCE) 50
6.4 Calculation of reference SEERon 50
6.5 Calculation procedure for determination of EERbin(Tj) values at part load conditions B, C, D 51
6.5.1 General 51
6.5.2 For air-to-air & water-to-air units 51
6.5.3 Air-to-water, water-to-water & brine-to-water units 52

7 Calculation methods for reference SCOP, reference SCOPon and reference SCOPnet 52
7.1 General formula for calculation of reference SCOP 52

7.2 Calculation of the reference annual heating demand (QH) 53
7.3 Calculation of the annual electricity consumption (QHE) 53
7.4 Calculation of reference SCOPon and reference SCOPnet 53
7.5 Calculation procedure for determination of COPbin(Tj) values at part load conditions A, B, C, D 54
7.5.1 General 54
7.5.2 For air-to-air, brine-to-air and water-to-air units 55
7.5.3 For air-to-water, water-to-water and brine-to-water units 55

8 Test methods for testing capacities, EERbin(Tj) and COPbin(Tj) values during active mode at part load conditions 56
8.1 General 56
8.2 Basic principles 56
8.3 Uncertainties of measurement 57
8.4 Test procedures for units with fixed capacity 58
8.4.1 General 58
8.4.2 Air-to-air and water-to-air units - Determination of the degradation coefficient Cd 58
8.4.3 Air-to-water units and water-to-water units - Determination of the degradation factor Cc . 59
8.5 Test procedure for staged and variable capacity units (air-to-air, air-to-water, water-to-air, water/brine-to-water) 60
8.5.1 Air-to-air & water-to-air units 60
8.5.2 Air-to-water and water/brine-to-water units 60

9 Test methods for electric power consumption during thermostat-off mode, standby mode and crankcase heater mode 60
9.1 Measurement of electric power consumption during thermostat-off mode 60
9.2 Measurement of the electric power consumption during standby mode 61
9.3 Measurement of the electric power consumption during crankcase heater mode 61
9.4 Measurement of the electric power consumption during off mode 61

10 Test report 61

11 Technical data sheet 62

Annex A (normative) Applicable climate bin hours and hours for active mode, thermostat-off, standby, off mode for air conditioners below and equal to 12 kW 63

A.1 Climate bins 63
A.1.1 Bin limit temperature 63
A.1.2 Cooling 63
A.1.3 Heating 63
A.2 Hours for active mode, thermostat-off, standby, off mode 65
A.2.1 Cooling 65
A.2.2 Heating 65
A.3 Hours used for crankcase heater mode 65
A.3.1 Cooling 65
A.3.2 Heating 66

Annex B (informative) Calculation example for reference SEERon and reference SEER - Application to a reverse cycle air-to-air unit with variable capacity 67

B.1 Calculation of SEERon 67
B.2 Calculation of SEER 68
B.2.1 Calculation of reference annual cooling demand (QC) according to Formula (2) 68
B.2.2 Calculation of reference SEER according to Formula (1) 69

Annex C (informative) Calculation example for reference SCOPon and reference SCOPnet of a fixed capacity air-to-water heat pump used for floor heating 70

Annex D (informative) Adaption of water temperature for fixed capacity units 74

Annex E (informative) Determination of reference annual cooling/heating demands and determination of hours for active mode, thermostat-off, standby, off mode and crankcase heater mode 77

E.1 General 77
E.2 Determination of reference annual cooling/heating demands and hours for active mode, thermostat-off, standby, off mode 77
E.3 Hours used for crankcase heater mode 79

Annex F (informative) Compensation method for air-to-water and water/brine-to-water units 80

F.1 General 80
F.2 Compensation system for reduced capacity test in cooling mode 80
F.3 Compensation system for reduced capacity test in heating mode 80

Annex G (normative) Template for technical data sheet 82

Annex ZA (informative) Relationship between this European Standard and the requirements of Commission Regulation (EC) No 206/2012 85

Bibliography 86