

ISO 23953-2:2015-11 (E)

Refrigerated display cabinets - Part 2: Classification, requirements and test conditions

Contents		Page
Foreword		v
1	Scope	1
2	Normative references	1
3	Terms, definitions, symbols and abbreviated terms	1
3.1	General	1
3.2	Compression-type refrigeration systems	2
3.3	Indirect refrigeration-type systems	3
4	Requirements	3
4.1	Construction	3
4.1.1	General	3
4.1.2	Materials	5
4.1.3	Thermal insulation	5
4.1.4	Refrigerating system	6
4.1.5	Electrical components	6
4.1.6	Temperature display	6
4.2	Operating characteristics	7
4.2.1	Absence of odour and taste	7
4.2.2	Classification according to temperature	8
4.2.3	Defrosting	8
4.2.4	Water vapour condensation	8
4.2.5	Energy consumption	8
4.2.6	Specific Energy Consumption	9
5	Tests	9
5.1	General	9
5.2	Tests outside test room	9
5.2.1	Seal test for doors and lids on low temperature applications	9
5.2.2	Linear dimensions, areas	9
5.3	Tests inside test room	10
5.3.1	General conditions	10
5.3.2	Preparation of test cabinet and general test procedures	19
5.3.3	Temperature test	45
5.3.4	Water vapour condensation test	50
5.3.5	Electrical energy consumption test	51
5.3.6	Heat extraction rate measurement when condensing unit is remote from cabinet	51
6	Test report	60
6.1	General	60
6.2	Tests outside test room	60
6.2.1	Seal test of doors and lids	60
6.2.2	Linear dimensions, areas and volumes	60
6.2.3	Test for absence of odour and taste	61
6.3	Tests inside test room	61
6.3.1	General test conditions	61
6.3.2	Cabinet preparation	61
6.3.3	Temperature test	62
6.3.4	Water vapour condensation test	62

6.3.5	Electrical energy consumption test	63
6.3.6	Heat extraction rate measurement when the condensing unit is remote from the cabinet .	63
7	Marking	65
7.1	Load limit	65
7.2	Marking plate	66
7.3	Information to be supplied by the manufacturer	66
Annex A	(normative) Total display area (TDA)	68
Annex B	(informative) Comparison between laboratory and in-store conditions	76
Annex C	(informative) Test for absence of odour and taste	78
Annex D	(normative) Performance and energy rating of commercial refrigerated display cabinets ..	80
Bibliography	89