DIN EN 1366-10:2011-07 (E)

Fire resistance tests for service installations - Part 10: Smoke control dampers

Contents

Page

Foreword 5

Introduction 6

1 Scope 7

2 Normative references 7

3 Terms and definitions 7

4 Test equipment 11
4.1 General 11
4.2 Connecting duct for multi compartment fire resisting smoke control damper: maintenance of opening test and EN 1366-2 test 11
4.3 Volume flow measuring station for multi compartment fire resisting smoke control damper: maintenance of opening test and EN 1366-2 test 12
4.4 Plenum for High Operating Temperature (HOT) test 12
4.5 Cycling equipment 12
4.6 Condensing unit 12
4.7 Gas temperature measuring devices 12
4.8 Exhaust fan system 13
4.9 Perforated plate 13
4.10 Flow measurement nozzles (fire test) 14
4.11 Ambient leakage measuring device 14
4.12 Pressure sensors for differential pressure control 14
4.13 Welded connecting tube 14
4.14 Extract fan connecting duct 14
4.15 Extraction fan 14
4.16 Thermocouples 15
4.17 Oxygen measuring equipment 15
4.18 Observation windows 15

5 Test specimen 15
5.1 Cross-section 15
5.2 Design 15
5.2.1 General 15
5.2.2 Supporting constructions 15
5.2.3 Inclusion of grilles 16

6 Test methods 16
6.1 General 16
6.2 Initiation regimes for elevated temperature and fire tests 16
6.2.1 Smoke control damper for systems with automatic activation 16
6.2.2 Smoke control damper for systems with manual intervention: 17
6.3 Cycling test requirements (to form part of the sequences of testing defined below) 17
6.3.1 General 17
6.3.2 Smoke control damper to be used in dedicated Smoke control systems, operated only in the case of emergency 17
6.3.3 Differential pressure conditions 18
6.4 Single compartment smoke control dampers mounted on the surface of a duct 18
6.4.1 Sequence 18
6.4.2 Ambient leakage 18

6.4.3 Cycling test ... 18
6.4.4 Elevated temperature test ... 18
6.5 Multi compartment fire resisting smoke control dampers ... 19
6.5.1 Fire resistance test according to EN 1366-2 (for units mounted within or on the face of a compartment structure) ... 19
6.5.2 Maintenance of opening test (for units mounted within a compartment structure) ... 20
6.5.3 Horizontal duct test for surface mounted smoke control dampers on a horizontal duct ... 21
6.5.4 Vertical duct test for surface mounted smoke control dampers ... 22
6.6 Multi compartment fire resisting smoke control dampers (HOT Classification) ... 23
6.6.1 Fire resistance test (for units mounted within or on the face of a compartment structure) 23
6.6.2 High operating test (HOT 400/30 - cycling and maintenance of opening test) ... 24

7 Test procedure ... 24
7.1 Pre-test calibration ... 24
7.1.1 Oxygen-measuring instrument ... 24
7.1.2 Perforated plate ... 24
7.1.3 Leakage measurement at ambient temperature ... 25
7.2 Fire test ... 25
7.2.1 Extraction fan ... 25
7.2.2 Ignition of furnace ... 25
7.2.3 Furnace conditions ... 26
7.2.4 Temperatures and pressures ... 26
7.2.5 Oxygen measurements ... 26
7.2.6 General observations ... 26
7.2.7 Reduction of cross-section/ maintenance of opening ... 26
7.2.8 Leakage calculations ... 26
7.3 Termination of test ... 26

8 Test report ... 28

9 Direct field of application of test results ... 28
9.1 General ... 28
9.2 Smoke control damper sizes ... 28
9.3 Pressure difference ... 29
9.4 Elevated temperatures ... 29
9.5 Cycling tests ... 29
9.5.1 Smoke control dampers meeting the cycling requirements for modulating applications .. 29
9.5.2 Smoke control dampers meeting the cycling requirements for use with combined smoke control and general HVAC applications and for smoke control systems that are cycle checked every day ... 29
9.5.3 Smoke control dampers meeting the cycling requirements for smoke control dampers that are operated only in the case of emergency ... 29
9.6 Initiation method ... 29
9.7 Application to duct constructions other than that tested ... 30
9.7.1 Single compartment smoke control dampers ... 30
9.7.2 Multi compartment smoke control dampers ... 30

10 Duct surface ... 31

11 Duct surface ... 32

Annex A (normative) Cycling test ... 51

A.1 General ... 51
A.2 Purpose of the test ... 51
A.3 Method of Application ... 51
A.3.1 General ... 51
A.3.2 Smoke Control Damper with single blade ... 51
A.3.3 Smoke control damper with multi blades of smaller area ... 53
A.3.4 Report ... 53
A.4 Background for the torque value (informative) ... 53
A.4.1 Threshold rates of the working condition of the system ... 53

A.4.2 Previous experience 54

Annex B (normative) Leakage calculation from oxygen measurement 55

B.1 General 55

Annex C (normative) Maintenance of opening calculation 57

C.1 Calculation of the theoretical total mass Mmax of hot gases during the fire test 57
C.1.1 Basis 57
C.1.2 Method 57
C.1.3 Summary 58
C.2 Calculation of the actual total mass Mactual of hot gases during the fire test 60
C.2.1 Basis 60
C.2.2 Method 60
C.2.3 Summary 61
C.3 Graphical representation of typical integral calculation from data 62

Bibliography 63