

DIN EN 12101-3:2015-12 (E)

Smoke and heat control systems - Part 3: Specification for powered smoke and heat control ventilators (Fans)

Contents		Page
European foreword		7
Introduction		8
1	Scope	10
2	Normative references	10
3	Terms and definitions, symbols and abbreviations	11
4	Requirements	13
4.1	Response delay (response time)	13
4.1.1	Opening under wind load within a given time	13
4.1.2	Opening under snow load within a given time	13
4.2	Operational reliability	13
4.2.1	General	13
4.2.2	Application categories	13
4.2.3	Motor rating	14
4.3	Effectiveness of smoke / hot gas extraction	14
4.3.1	General	14
4.3.2	Gas flow and pressure maintenance during smoke and heat extraction test	15
4.4	Resistance to fire	15
4.5	Ability to open under environmental conditions	15
4.5.1	Opening under wind load within a given time	15
4.5.2	Opening under snow load within a given time	15
4.6	Durability of operational reliability	15
5	Testing, assessment and sampling methods	15
5.1	General	15
5.2	Test of response delay (response time) opening under wind, snow load within a given time	16
5.2.1	Wind load	16
5.2.2	Snow load	16
5.3	Operational reliability	17
5.3.1	Application categories	17
5.3.2	Motor rating	17
5.4	Effectiveness of smoke / hot gas extraction - Gas flow and pressure maintenance during smoke and heat extraction test	17
5.5	Resistance to fire	17
5.6	Ability to open under environmental conditions: opening under wind, snow load within a given time	17
5.7	Durability of operational reliability	17
6	Assessment and verification of constancy of performance - AVCP	17
6.1	General	17
6.2	Type Testing	17
6.2.1	General	17
6.2.2	Test samples, testing and compliance criteria	18
6.2.3	Test reports	19
6.3	Factory production control (FPC)	19
6.3.1	General	19

6.3.2	Requirements	20
6.3.3	Product specific requirements	27
6.3.4	Initial inspection of factory and of FPC	27
6.3.5	Continuous surveillance of FPC	28
6.3.6	Procedure for modifications	28
6.3.7	One-off products, pre-production products (e.g. prototypes) and products produced in very low quantity	28
7	Marking, labelling and packaging	29
Annex A (normative) Criteria to determine family of fans in order to select the sizes to be tested		31
A.1	Reduction of numbers of tests for PSHC ventilators forming a product range	31
A.2	Motors	33
A.2.1	General	33
A.2.2	Motor Type 1: Motor out of airstream and Impeller not mounted on shaft	34
A.2.3	Motor Type 2: Centrifugal fans with impeller mounted on the motor shaft	35
A.2.4	Motor Type 3: Fans with motor inside the airstream without cooling	35
A.2.5	Motor Type 4: Motors out of airstream but within fan casing	36
A.2.5.1	General	36
A.2.5.2	Motor Type 4.1	36
A.2.5.3	Motor Type 4.2	37
A.3	Combined testing	37
A.3.1	General rule	37
A.3.2	Specific rule for an axial fan	38
A.4	Determination of highest stresses in impellers	38
A.4.1	PSHC Ventilators with geometrically similar impellers	38
A.4.2	Fans with impellers that are not geometrically similar	40
A.4.2.1	Axial impellers	40
A.4.2.1.1	Centrifugal force	40
A.4.2.1.2	Fastenings or welds	42
A.4.2.1.3	Hub/back-plate/shroud stresses	43
A.4.2.2	Centrifugal impellers	45
A.4.2.2.1	Centrifugal force	45
A.4.2.2.2	Blade bending moment	46
A.4.2.2.3	Comparative blade stresses	46
A.4.2.2.4	Blade joint stress	48
A.5	Assessment of changes in a fan family	48
A.5.1	Assessment of motor change	48
A.5.2	Assessment of fan component change	49
Annex B (normative) Criteria to determine a family of motors in order to select the sizes to be tested		51
B.1	Reduction of numbers of tests for a motor family	51
B.2	Assessment of changes in a motor family	51
B.2.1	Assessment for changing a family of motors in a family of fans	51
B.2.2	Assessment for changing components in a family of motors	51
B.2.3	Assessment of changes using Annex D	56
B.2.4	Normative list of motor components	56
Annex C (normative) Test method for the determination of fire resistance of powered smoke and heat control ventilators (fans)		61
C.1	Principle	61
C.2	Apparatus	61
C.3	Preparation	63
C.3.1	Axial Fan running (tip) clearance	63
C.3.2	Measuring of running clearance	63
C.3.3	Installation in furnace depending on the intended application categories	64
C.4	Procedure	66
C.4.1	General conditions	66
C.4.2	Warm up period	66

C.4.3	Heat up period	66
C.4.4	High temperature test	66
C.4.5	High temperature test in accordance with temperature time curve	67
C.5	Compliance criteria	67
C.6	Test report	67
C.6.1	Prepare a test report after completion of each test including the following information: ...	67
Annex D (normative)	Test methods for electric motors to determine the impact of the changes on the product characteristics	70
D.1	Principle	70
D.2	Tests in association with a generator or another load	70
D.2.1	Modulated Frequency Method (MFM)	70
D.2.2	Apparatus for testing with a generator	71
D.2.2.1	Test installation	71
D.2.2.2	Specifications for bearing load	71
D.2.2.3	Temperature measurements	72
D.2.2.4	Electrical measurements	72
D.2.3	Test specimens	72
D.2.4	Test procedure	72
D.2.4.1	General conditions	72
D.2.4.2	Warm up period	72
D.2.4.3	High temperature test	73
D.3	Test report	73
Annex E (normative)	Test method for assessing the response delay and ability to open under environmental conditions	75
E.1	Objective of test	75
E.2	Test apparatus	75
E.3	Test specimen	75
E.4	Test procedure	75
E.5	Evaluation of test results	75
Annex F (informative)	Explanatory notes	76
F.1	General	76
F.2	Explanation for A.4.4.3	76
F.3	Origin of power coefficients in D.2.4.2	79
F.4	Consideration about frequency converter driving	80
F.5	Consideration regarding A.1, f) - scaling factors	82
F.6	Consideration regarding B.2.2: change of type of bearing	82
F.6.1	General	82
F.6.2	Bearing ability to pass the smoke venting test	82
F.6.3	Parameters to consider during the heat up test	83
F.6.4	How to select motor sizes	84
F.6.5	How to select motor size in vertical position	84
F.7	Consideration for changing material inside the fan	85
F.7.1	Material features	85
F.7.1.1	Mechanical properties	85
F.7.1.2	Technological properties	85
F.7.1.3	Physical properties	85
F.7.1.4	Tensile strength	86
F.7.1.5	Compression stress, shear stress and twisting	86
F.7.1.6	Hardness	86
F.7.1.7	Creep	86
F.7.1.8	Behaviour at low temperatures	86
F.7.1.9	Fatigue	86
F.7.2	Technological properties	87
F.7.2.1	Abrasive resistance	87
F.7.2.2	Formability	87
F.7.3	Physical properties	87

F.7.3.1	Density	87
F.7.3.2	Coefficient of thermal expansion	87
F.7.3.3	Thermal diffusivity	87
F.7.3.4	Elastic properties	87
F.8	Complementary information on Installation / Application	88
Annex G (informative) General guidance for installation and maintenance		91
G.1	Product, installation and maintenance information (documentation)	91
G.1.1	Product specification	91
G.1.2	Installation information	91
G.1.3	Maintenance information	91
Annex ZA (informative) Clauses of this European Standard addressing the provisions of the EU Construction Products Regulation		92
ZA.1	Scope and relevant characteristics	92
ZA.2	Procedure for AVCP of the powered heat and smoke control ventilators (fans)	93
ZA.2.1	System(s) of AVCP	93
ZA.2.2	Declaration of performance (DoP)	94
ZA.2.2.1	General	94
ZA.2.2.2	Content	95
ZA.2.2.3	Example of DoP	95
ZA.3	CE marking and labelling	97
Bibliography		100