DIN EN 1366-10:2017-07 (E)

Fire resistance tests for service installations - Part 10: Smoke control dampers (includes Amendment A1:2017)

Contents

Page

European foreword 5

Introduction 7

1 Scope 8

2 Normative references 8

3 Terms and definitions 8

4 Test equipment 13
4.1 General 13
4.2 Connecting duct for multi compartment fire resisting smoke control damper: maintenance of opening test and EN 1366-2 test 13
4.3 Volume flow measuring station for multi compartment fire resisting smoke control damper: maintenance of opening test and EN 1366-2 test 13
4.4 Plenum for High Operating Temperature (HOT) test 13
4.5 Cycling equipment 13
4.6 Condensing unit 14
4.7 Gas temperature measuring devices 14
4.8 Exhaust fan system 14
4.9 Perforated plate 14
4.10 Flow measurement nozzles (fire test) 15
4.11 Ambient leakage measuring device 15
4.12 Pressure sensors for differential pressure control 15
4.13 Welded connecting tube 15
4.14 Extract fan connecting duct 15
4.15 Extraction fan 16
4.16 Thermocouples 16
4.17 Oxygen measuring equipment 16
4.18 Observation windows 16

5 Test specimen 16
5.1 Cross-section 16
5.2 Design 16
5.2.1 General 16
5.2.2 Supporting constructions 16
5.2.3 Inclusion of grilles 17

6 Test methods 17
6.1 General 17
6.2 Initiation regimes for elevated temperature and fire tests 17
6.2.1 Smoke control damper for systems with automatic activation 17
6.2.2 Smoke control damper for systems with manual intervention: 18
6.3 Cycling test requirements (to form part of the sequences of testing defined below) 18
6.3.1 General 18
6.3.2 Smoke control damper to be used in dedicated Smoke control systems, operated only in the case of emergency 18
6.3.3 Differential pressure conditions 19

6.4 Single compartment smoke control dampers mounted on the surface of a duct 19
6.4.1 Sequence 19
6.4.2 Ambient leakage 19
6.4.3 Cycling test 19
6.4.4 Elevated temperature test 19
6.5 Multi compartment fire resisting smoke control dampers 20
6.5.1 Fire resistance test according to EN 1366-2 (for units mounted within or on the face of a compartment structure) 20
6.5.2 Maintenance of opening test (for units mounted within a compartment structure) 21
6.5.3 Horizontal duct test for surface mounted smoke control dampers on a horizontal duct 21
6.5.4 Vertical duct test for surface mounted smoke control dampers 22
6.6 Multi compartment fire resisting smoke control dampers (HOT Classification) 24
6.6.1 Fire resistance test (for units mounted within or on the face of a compartment structure) 24
6.6.2 High operating test (HOT 400/30 - cycling and maintenance of opening test) 25

7 Test procedure 25
7.1 Pre-test calibration 25
7.1.1 Oxygen-measuring instrument 25
7.1.2 Perforated plate 25
7.1.3 Leakage measurement at ambient temperature 26
7.2 Fire test 26
7.2.1 Extraction fan 26
7.2.2 Ignition of furnace 26
7.2.3 Furnace conditions 26
7.2.4 Temperatures and pressures 27
7.2.5 Oxygen measurements 27
7.2.6 General observations 27
7.2.7 Reduction of cross-section/ maintenance of opening 27
7.2.8 Leakage calculations 27
7.3 Termination of test 27

8 Test report 28

9 Direct field of application of test results 28
9.1 General 28
9.2 Smoke control damper sizes 28
9.3 Pressure difference 29
9.4 Elevated temperatures 29
9.5 Cycling tests 29
9.5.1 Smoke control dampers meeting the cycling requirements for modulating applications .. 29
9.5.2 Smoke control dampers meeting the cycling requirements for use with combined smoke control and general HVAC applications and for smoke control systems that are cycle checked every day 29
9.5.3 Smoke control dampers meeting the cycling requirements for smoke control dampers that are operated only in the case of emergency 29
9.6 Initiation method 29
9.7 Application to duct constructions other than that tested 30
9.7.1 Single compartment smoke control dampers 30
9.7.2 Multi compartment smoke control dampers 30

Annex A (normative) Cycling test 51

A.1 General 51
A.2 Purpose of the test 51
A.3 Method of Application 51
A.3.1 General 51
A.3.2 Smoke Control Damper with single blade 51
A.3.3 Smoke control damper with multi blades of smaller area 52
A.3.4 Report 53

A.4 Background for the torque value (informative) 53
A.4.1 Threshold rates of the working condition of the system 53
A.4.2 Previous experience 53

Annex B (normative) Leakage calculation from oxygen measurement 55

B.1 General 55

Annex C (normative) Maintenance of opening calculation 56

C.1 Calculation of the theoretical total mass Mmax of hot gases during the fire test 56
C.1.1 Basis 56
C.1.2 Method 56
C.1.3 Summary 57
C.2 Calculation of the actual total mass Mactual of hot gases during the fire test 58
C.2.1 Basis 58
C.2.2 Method 59
C.2.3 Summary 59
C.3 Graphical representation of typical integral calculation from data 61

Bibliography 62