

ISO 21927-3:2021 (E)

Smoke and heat control systems — Part 3: Specifications for powered smoke and heat exhaust ventilators

Contents

	Foreword
	Introduction
1	Scope
2	Normative references
3	Terms, definitions, symbols and abbreviated terms
4	Requirements
4.1	Response delay (response time)
4.1.1	Opening under wind load within a given time
4.1.2	Opening under snow load within a given time
4.2	Operational reliability
4.2.1	General
4.2.2	Application categories
4.2.3	Motor rating
4.3	Effectiveness of smoke/hot gas extraction
4.3.1	General
4.3.2	Gas flow and pressure maintenance during smoke and heat extraction test
4.4	Resistance to fire
4.5	Ability to open under environmental conditions
4.5.1	Opening under wind load within a given time
4.5.2	Opening under snow load within a given time
4.6	Durability of operational reliability
5	Testing, assessment and sampling methods
5.1	General
5.2	Test of response delay (response time) opening under wind / snow load within a given time
5.2.1	Wind load
5.2.2	Snow load
5.3	Operational reliability
5.3.1	Application categories
5.3.2	Motor rating
5.4	Effectiveness of smoke/hot gas extraction: gas flow and pressure maintenance during smoke and heat extraction test
5.5	Resistance to fire
5.6	Ability to open under environmental conditions: opening under wind or snow load within a given time
5.7	Durability of operational reliability
6	Marking, labelling and packaging
Annex A	(normative) Criteria to determine the family of fans in order to select the sizes to be tested
A.1	Reduction of numbers of tests for PSHC ventilators forming a product range
A.2	Motors
A.2.1	General
A.2.2	Type 1 motor: Motor out of airstream and impeller not mounted on shaft
A.2.3	Type 2 motor: Centrifugal fans with impeller mounted on the motor shaft
A.2.4	Type 3 motor: Fans with motor inside the airstream without cooling
A.2.5	Type 4 motor: Motors out of airstream but without fan casing

- A.2.5.1 General
- A.2.5.2 Motor Type 4.1
- A.2.5.3 Motor Type 4.2
- A.3 Combined testing
- A.3.1 General rule
- A.3.2 Specific rule for an axial fan
- A.4 Determination of highest stresses in impellers
- A.4.1 PSHC Ventilators with geometrically similar impellers
- A.4.2 Fans with impellers that are not geometrically similar
- A.4.2.1 Axial impellers
- A.4.2.1.1 Centrifugal force
- A.4.2.1.2 Fastenings or welds
- A.4.2.1.3 Hub/back-plate/shroud stresses
- A.4.2.2 Centrifugal impellers
- A.4.2.2.1 Centrifugal force
- A.4.2.2.2 Blade bending moment
- A.4.2.2.3 Comparative blade stresses
- A.4.2.2.4 Blade joint stress
- A.5 Assessment of changes in a fan family
- A.5.1 Assessment of motor change
- A.5.2 Assessment of fan component change

Annex B (normative) Criteria to determine a family of motors in order to select the sizes to be tested

- B.1 Reduction of numbers of tests for a motor family
- B.2 Assessment of changes in a motor family
- B.2.1 Assessment for changing a family of motors in a family of fans
- B.2.2 Assessment for changing components in a family of motors
- B.2.3 Assessment of changes using Annex D
- B.2.4 List of motor components

Annex C (normative) Test method for the determination of fire resistance of powered smoke and heat control ventilators (fans)

- C.1 Principle
- C.2 Apparatus
- C.3 Preparation
- C.3.1 Axial Fan running (tip) clearance
- C.3.2 Measuring of running clearance
- C.3.3 Installation in furnace depending on the intended application categories
- C.4 Procedure
- C.4.1 General conditions
- C.4.2 Warm up period
- C.4.3 Heat up period
- C.4.4 High temperature test
- C.4.5 High temperature test in accordance with temperature time curve
- C.5 Conformance criteria
- C.6 Test report
- C.6.1 Prepare a test report after completion of each test including the following information:

Annex D (normative) Test methods for electric motors to determine the impact of the changes on the product characteristics

- D.1 Principle
- D.2 Tests in association with a generator or another load
- D.2.1 Modulated frequency method (MFM)
- D.2.2 Apparatus for testing with a generator
- D.2.2.1 Test installation
- D.2.2.2 Specifications for bearing load
- D.2.2.3 Temperature measurements
- D.2.2.4 Electrical measurements
- D.2.3 Test specimens
- D.2.4 Test procedure
- D.2.4.1 General conditions
- D.2.4.2 Warm up period
- D.2.4.3 High temperature test
- D.3 Test report

Annex E (normative) Test method for assessing the response delay and ability to open under environmental conditions

- E.1 Objective of test**
- E.2 Test apparatus**
- E.3 Test specimen**
- E.4 Test procedure**
- E.5 Evaluation of test results**

Annex F (informative) Explanatory notes

- F.1 Explanation for A.4.4.3**
- F.2 Origin of power coefficients in D.2.4.2**
- F.3 Consideration about frequency converter driving**
- F.4 Considerations regarding A.1 f) — Scaling factors**
- F.5 Consideration regarding B.2.2: Change of type of bearing**
 - F.5.1 General**
 - F.5.2 Bearing ability to pass the smoke venting test**
 - F.5.3 Parameters to consider during the heat up test**
 - F.5.4 How to select motor sizes**
 - F.5.5 How to select motor size in vertical position**
- F.6 Consideration for changing material inside the fan**
 - F.6.1 Material features**
 - F.6.1.1 Mechanical properties**
 - F.6.1.2 Technological properties**
 - F.6.1.3 Physical properties**
 - F.6.1.4 Tensile strength**
 - F.6.1.5 Hardness**
 - F.6.1.6 Creep**
 - F.6.1.7 Behaviour at low temperatures**
 - F.6.1.8 Fatigue**
 - F.6.2 Technological properties**
 - F.6.2.1 Abrasive resistance**
 - F.6.2.2 Formability**
 - F.6.3 Physical properties**
 - F.6.3.1 Density**
 - F.6.3.2 Coefficient of thermal expansion**
 - F.6.3.3 Thermal diffusivity**
 - F.6.3.4 Elastic properties**
 - F.7 Complementary information on installation/application**

Annex G (informative) General guidance for installation and maintenance

- G.1 Product, installation and maintenance information (documentation)**
 - G.1.1 Product specification**
 - G.1.2 Installation information**
 - G.1.3 Maintenance information**

Page count: 70