# DIN 18014:2023-06 (E)

## Earthing systems for buildings - Planning, execution and documentation

## Contents

Page


**Foreword** ... 6

**1 Scope** ... 8

**2 Normative references** ... 8

**3 Terms and definitions** ... 9

**4 General requirements regarding earthing arrangements** ... 15
**4.1 Earthing arrangement functions** ... 15
**4.2 Planning and erection of earthing arrangements** ... 15

**5 Selection of earthing arrangements** ... 16
**5.1 General information, requirements and selection criteria** ... 16
**5.2 Types of earth electrodes** ... 16

**6 Execution of earthing arrangements** ... 17
**6.1 General** ... 17
**6.2 Ring earth electrode** ... 17
**6.3 Vertical earth electrode/earth rod** ... 24
**6.4 Radial earth electrode** ... 28
**6.5 Foundation earth electrode** ... 29
**6.5.1 General** ... 29
**6.5.2 Foundation earth electrode in the case of unreinforced foundations** ... 31
**6.5.3 Foundation earth electrode in the case of fibre-reinforced concrete** ... 32
**6.6 Earthing arrangement in the case of foundations with carbon-fibre reinforcement** ... 32
**6.7 Combining earth electrodes** ... 33
**6.8 Special designs** ... 33
**6.8.1 Earthing arrangements in the case of pad foundations** ... 33
**6.8.2 Earthing arrangements in the case of structures with partial basement** ... 37
**6.8.3 Earthing arrangements in the case of multiple mains connections** ... 40
**6.8.4 Charging equipment within the area influenced by the building's earthing arrangement** ... 44

**7 Requirements for a common bonding network (CBN)** ... 46
**7.1 General** ... 46
**7.2 Common bonding network without suitable conductive parts of the reinforcement** ... 48
**7.3 Conditions for when a common bonding network is deemed not necessary** ... 48

**8 Terminals** ... 49

**9 Electrically conductive connections** ... 50

**10 Selection of materials and components** ... 51
**10.1 General** ... 51
**10.2 Ring earth electrode or radial earth electrode** ... 52
**10.3 Vertical earth electrode/earth rod** ... 52
**10.4 Foundation earth electrode** ... 52
**10.5 Common equipotential bonding conductor** ... 52
**10.6 Earthing conductor** ... 52
**10.7 Terminals** ... 53

**11 Checking compliance and documentation** ... 53
**11.1 General** ... 53
**11.2 Documentation** ... 53
**11.3 Resistance measurement** ... 54

**Annex A** (informative) **Supplementary information on the functions of an earthing arrangement** ... 55
**A.1 Earthing arrangement** ... 55

**A.2 Common bonding network** ... 56

**Annex B** (informative) **"Basic consideration for planning an earthing arrangement" form** ... 57

**Annex C** (informative) **Form for the documentation of an earthing arrangement** ... 61

**Annex D** (informative) **Decision guidance on the selection, planning and execution of the earthing arrangement** ... 67

**Annex E** (informative) **Additional information on foundations with enhanced earthing contact resistance** ... 68

**Annex F** (informative) **Information on the typical values of the soil resistivity** ... 69

**Annex G** (informative) **Resistances to earth of various earth electrodes** ... 71

**Bibliography** ... 73

## Figures

**Figure 1 — Ring earth electrode in the case of a foundation with enhanced earthing contact resistance** ... 19

**Figure 2 — Spatial arrangement of the ring earth electrode and common bonding network** ... 20

**Figure 3 — Ring earth electrode and common bonding network in the case of thermal insulation (perimeter insulation) on the bottom side or the side walls of the foundation** ... 22

**Figure 4 — Ring earth electrode and common bonding network in the case of waterproof concrete ("white tank") in a reinforced foundation** ... 23

**Figure 5 — Ring earth electrode and common bonding network in the case of bituminous waterproofing ("black tank") in a reinforced foundation** ... 24

**Figure 6 — Vertical earth electrode/earth rod without common bonding network in the case of a foundation with enhanced earthing contact resistance and a building footprint ≤ 200 $m^2$** ... 27

**Figure 7 — Vertical earth electrode/earth rod with common bonding network in the case of a foundation with enhanced earthing contact resistance and a footprint of the foundation ≤ 200 $m^2$** ... 27

**Figure 8 — Equal arrangement of vertical earth electrodes/earth rods in the case of foundations with footprints > 200 $m^2$ (Table 1)** ... 28

**Figure 9 — Arrangement of the foundation earth electrode** ... 31

**Figure 10 — Foundation earth electrode in unreinforced foundation** ... 32

**Figure 11 — Combination of earth electrodes** ... 33

**Figure 12 — Connection of pad foundations to an earthing arrangement with vertical earth electrodes/earth rods** ... 34

**Figure 13 — Connection of pad foundations to an earthing arrangement in the form of a ring earth electrode** ... 35

**Figure 14 — Connection of pad foundations** ... 37

**Figure 15 — Earthing arrangement in the case of buildings with partial basements, consisting of a meshed ring earth electrode and common bonding network** ... 38

**Figure 16 — Building with partial basement and without an earthing arrangement in the adjoining building ..... 39**

**Figure 17 — Building with partial basement with an earthing arrangement in the adjoining building ..... 40**

**Figure 18 — Arrangement of a ring earth electrode in the case of a building with several mains connections and a common earthing arrangement ..... 41**

**Figure 19 — Arrangement of a ring earth electrode in terraced/semi-detached houses ..... 42**

**Figure 20 — Arrangement of vertical earth electrodes/earth rods/radial earth electrodes in terraced/semi-detached houses ..... 43**

**Figure 21 — Bridging of expansion joints with terminals (fixed earthing terminals) and flexible earthing conductors inside of structures ..... 44**

**Figure 22 — Designs of earthing arrangements in the case of charging equipment ..... 45**

**Figure 23 — Representation of a low-ohmic and low-impedance common bonding network ..... 47**

**Figure 24 — Demarcation of the scope of DIN 18014 ..... 48**

**Figure 25 — Examples for additional terminals, if required ..... 50**

**Figure D.1 — Decision guidance on the implementation of the earthing arrangement ..... 67**

**Figure F.1 — Fluctuations of the soil resistivity $\rho_E$ as a percentage depending on the time of year (without influence from precipitation) ..... 69**

**Figure F.2 — Impact of the length *l* of the extended surface earth electrode (m) on the resistance to earth ($R_A$) ..... 69**

## Tables

**Table 1 — Minimum number of vertical earth electrodes/earth rods depending on the footprint of the foundation ..... 25**

**Table 2 — Minimum number of radial earth electrodes depending on the footprint of the foundation ..... 28**

**Table B.1 — Basic consideration for planning an earthing arrangement in accordance with DIN 18014 (page 1) ..... 57**

**Table C.1 — Documentation of an earthing arrangement in accordance with DIN 18014 (page 1) ..... 61**

**Table C.2 — Documentation of an earthing arrangement in accordance with DIN 18014 (page 2) ..... 65**

**Table F.1 — Soil resistivity for frequencies of technical alternating currents (range of values measured more frequently) based on source: DIN EN 50522 (VDE 0101-2):2011-11, Annex J, Clause J.1 ..... 70**

**Table G.1 — Typical values for resistances to earth of various building footprints in the case of different soil resistivities — for ring earth electrodes in accordance with 6.2 and foundation earth electrodes in accordance with 6.5 ..... 71**

**Table G.2 — Typical values for resistances to earth of various building footprints in the case of different soil resistivities — vertical earth electrodes/earth rods in accordance with 6.3 ..... 71**

**Table G.3 — Typical values for resistances to earth of earthing arrangements for various building footprints in the case of different soil resistivities — radial earth electrodes in accordance with 6.4 ..... 72**