

ISO 16890-2:2016-12 (E)

Air filters for general ventilation - Part 2: Measurement of fractional efficiency and air flow resistance

Contents		Page
Foreword		vi
Introduction		vii
1	Scope	1
2	Normative references	1
3	Terms and definitions	2
4	Symbols and abbreviated terms	4
4.1	Symbols	4
4.2	Abbreviated terms	6
5	General test requirements	6
5.1	Test device requirements	6
5.2	Test device installation	6
5.3	Test rig requirements	6
6	Test materials	7
6.1	Liquid phase aerosol	7
6.1.1	DEHS test aerosol	7
6.1.2	DEHS/DES/DOS - formula	7
6.1.3	DEHS properties	7
6.1.4	Liquid phase aerosol generation	7
6.2	Solid phase aerosol	8
6.2.1	Potassium chloride (KCl) test aerosol	8
6.2.2	KCl - formula	8
6.2.3	KCl properties	8
6.2.4	Solid phase aerosol generation	9
6.3	Reference aerosols	10
6.3.1	Reference aerosol for 0,3 µm to 1,0 µm	10
6.3.2	Reference aerosol for 1,0 µm to 10,0 µm	10
6.3.3	Other reference aerosols	10
6.3.4	Matching criteria	11
6.4	Aerosol loading	11
7	Test equipment	11
7.1	Test rig	11
7.1.1	Dimensions	11
7.1.2	Construction materials	12
7.1.3	Test rig shape	12
7.1.4	Test rig air supply	13
7.1.5	Test rig isolation	13
7.1.6	D/S mixing orifice	13
7.1.7	Aerosol sampling	14
7.1.8	Test rig air flow rate measurement	16
7.1.9	Resistance to air flow measurement	16
7.1.10	Non 610 mm × 610 mm (24,0 inch × 24,0 inch) test devices	17
7.1.11	Dust injection testing	18
7.2	Aerosol particle counter	18

7.2.1	General	18
7.2.2	OPC sampled size range	18
7.2.3	OPC particle size ranges	18
7.2.4	Sizing resolution	19
7.2.5	Calibration	19
7.2.6	Air flow rate	19
7.2.7	Zero counting	19
7.2.8	Dual OPC(s)	19
7.3	Temperature, relative humidity	20
8	Qualification of test rig and apparatus	20
8.1	Schedule of qualification testing requirements	20
8.1.1	General	20
8.1.2	Qualification testing	20
8.1.3	Qualification documentation	20
8.2	Qualification testing	21
8.2.1	Test rig -- Pressure system testing	21
8.2.2	OPC -- Air flow rate stability test	22
8.2.3	OPC -- Zero test	22
8.2.4	OPC -- Sizing accuracy	23
8.2.5	OPC -- Overload test	23
8.2.6	Aerosol generator -- Response time	24
8.2.7	Aerosol generator -- Neutralizer	24
8.2.8	Test rig -- Air leakage test	25
8.2.9	Test rig -- Air velocity uniformity	26
8.2.10	Test rig -- Aerosol uniformity	27
8.2.11	Test rig -- Downstream mixing	28
8.2.12	Test rig -- Empty test device section pressure	29
8.2.13	Test rig -- 100 % efficiency test and purge time	30
8.2.14	Test rig -- Correlation ratio	30
8.3	Maintenance	30
8.3.1	General	30
8.3.2	Test rig -- Background counts	31
8.3.3	Test rig -- Reference filter test	32
8.3.4	Test rig -- Pressure reference test	33
8.3.5	Test rig -- Final filter resistance	33
9	Test methods	33
9.1	Air flow rate	33
9.2	Measurement of resistance to air flow	33
9.3	Measurement of fractional efficiency	33
9.3.1	Aerosol sampling protocol	33
9.3.2	Background sampling	33
9.3.3	Testing sequence for a single OPC	34
9.3.4	Testing sequence for dual OPC testing	36
10	Data reduction and calculations	38
10.1	Correlation ratio	38
10.1.1	Correlation ratio general	38
10.1.2	Correlation ratio data reduction	38
10.2	Penetration and fractional efficiency	40
10.2.1	Penetration and fractional efficiency general	40
10.2.2	Penetration data reduction	40
10.3	Data quality requirements	43
10.3.1	Correlation background counts	43
10.3.2	Efficiency background counts	43
10.3.3	Correlation ratio	43
10.3.4	Penetration	44
10.4	Fractional efficiency calculation	44
11	Reporting results	45

11.1	General	45
11.2	Required reporting elements	45
11.2.1	Report general	45
11.2.2	Report values	45
11.2.3	Report summary	45
11.2.4	Report details	47
Annex A (informative) Example		50
Annex B (informative) Resistance to air flow calculation		57
Bibliography		59