DIN 19294-1:2020-08 (E)

Devices for the disinfection of water using ultraviolet radiation - Part 1: Devices equipped with UV low pressure lamps - Requirements and testing

Contents

Page

Foreword 5

1 Scope 6

2 Normative references 6

3 Terms and definitions 7

4 Requirements for UV devices with UV low pressure lamps 10
4.1 General 10
4.2 Requirements for the UV device 10
4.2.1 Irradiation chamber 10
4.2.2 Sensor position 11
4.2.3 Device control and monitoring 12
4.2.4 Operation with controlled lamp power 13
4.2.5 Operating instructions 14
4.3 Requirements for device components 15
4.3.1 General 15
4.3.2 UV lamps 15
4.3.3 Lamp control gears 17
4.3.4 Lamp sleeves 18
4.3.5 Duty radiometers 19
4.3.6 Sensor attachment system 22

5 Test documents 24
5.1 General 24
5.2 Irradiation chamber 24
5.3 Device controller 25
5.4 UV lamps 25
5.5 Lamp control gears 26
5.6 Lamp sleeves 27
5.7 Duty radiometers 27
5.8 Sensor attachment system 28
5.9 Spare parts 29
5.10 Operating instructions 29

6 Requirements for the test set-up 29
6.1 Test rig 29
6.2 Testing at the operating location 31
6.3 Requirements for the test equipment 31
6.3.1 Test water 31
6.3.2 Transmittance-reducing substance 31
6.3.3 Water for producing the test water 31
6.3.4 Transmittance measurement 32
6.4 Measurement technology for the test set-up 32
6.4.1 UV-VIS spectrophotometer 32
6.4.2 Requirements for ultra pure water for calibrating the photometer 32
6.4.3 Flow rate measurement 32
6.4.4 Pressure measurement (optional) 32
6.4.5 Temperature measurement 33
6.4.6 Power consumption of the UV device 33

6.4.7 Power consumption of the lamps and lamp control gears during characterization 33
6.4.8 Irradiance measurement 34
6.5 Biodosimeter 34
6.5.1 General 34
6.5.2 UV inactivation curves 34
6.5.3 Inactivation procedure 34

7 Test procedure 38
7.1 General 38
7.2 Technical testing 39
7.2.1 Manufacturer's documents 39
7.2.2 Irradiation chamber 39
7.2.3 UV lamp test 40
7.2.4 Lamp control gear test 41
7.2.5 Lamp sleeve test 42
7.2.6 Lamp ranking and determination of the deviation from the mean value 43
7.2.7 Sensor attachment system test 44
7.2.8 Duty radiometers 44
7.3 Biodosimetric testing 46
7.3.1 General 46
7.3.2 Set-up and installation of the UV device 46
7.3.3 Recording of the correlation between the irradiance and the UV transmittance of the water 47
7.3.4 Determination of the test points (flow rate, minimum irradiance, UV transmittance) 47
7.3.5 Procedure 48
7.3.6 Consistency of the test conditions 48
7.3.7 General data recording using measurement technology during the procedure 49
7.4 Assessment of biodosimetry -- determination of the operation range 49
7.4.1 General 49
7.4.2 Calculation of the permissible operation range 49
7.4.3 Calculation of the operation range with just one test point 51

8 Structure and content of the test report 51
8.1 General 51
8.2 Specification of the UV device 51
8.3 UV device test set-up 51
8.4 Performance of the tests 52
8.5 Test equipment used 52
8.5.1 Measuring devices 52
8.5.2 Biodosimeter 52
8.5.3 Chemical-bacteriological investigation of the test water 52
8.6 Results of the tests 52
8.6.1 Results of the technical tests 52
8.6.2 Results of the general measurement technology 53
8.6.3 Correlation between irradiance and UV transmittance 53
8.6.4 Confirmation test of the UV sensitivity of the biodosimeter 53
8.6.5 Results of the biodosimetric investigations 53
8.6.6 Specification of the permissible operation and suitability range 54
8.7 Additional data/annex 55

Annex A (normative) Measurement of the radiant power of mercury low pressure lamps in the UV-C spectral range 56

A.1 General 56
A.2 Prerequisites for reproducible and comparable measurements 57
A.2.1 Climatic conditions during the measurement 57
A.2.2 Measuring devices 57
A.2.3 Alignment of the sensor onto the lamp 57
A.2.4 Reflections and dark measurements 57
A.2.5 Radiation source 57

Annex B (informative) Method for producing spores of Bacillus subtilis for use as a biodosimeter (example) 58

B.1 General 58
B.2 Sporulation nutrient solution modified in accordance with Schaffer 58

Annex C (normative) Measurement uncertainties 60

Annex D (normative) Laboratory irradiation apparatus for reproducible UV irradiation in the laboratory 61

Annex E (normative) Test chamber for the characterization of UV lamps 64

Annex F (informative) Conversion table SSK -- UVT-10 -- UVT-100 68

Annex G (informative) Conversion table UVT-100 -- UVT-50 -- UVT-10 -- SSK 71

Bibliography 73