DIN EN 13476-1:2007-08 (E)

Plastics piping systems for non-pressure underground drainage and sewerage_- Structured-wall piping systems of unplasticized poly(vinyl chloride) (PVC-U), polypropylene (PP) and polyethylene (PE)_- Part_1: General requirements and performance characteristics

Contents

		Page
Foreword		**4**
Introduction		**5**
	Scope	**6**
	Normative references	**6**
	Terms and definitions, symbols and abbreviations	**7**
3.1	Definitions	7
3.1.1	General definitions	7
3.1.2	Geometrical definitions	8
3.2	Symbols and abbreviations	9
4	**Material**	**10**
4.1	General	10
4.2	Utilisation of non-virgin material	10
4.3	Sealing ring retaining components	10
4.4	Sealing rings	10
4.5	Fused or welded joints	10
5	**Designation of wall construction**	**10**
6	**Appearance and colour**	**10**
6.1	Appearance	10
6.2	Colour	11
	Geometrical characteristics	**11**
	Types of fittings	**11**
8.1	General	11
8.2	Design length of fittings	14
	System performance related test methods and characteristics	**14**
10	**Marking, general**	**16**
10.1	Presentation	16
10.2	Marking process	16
10.3	Size	16
Annex A (informative) Characteristics of PVC-U, PP and PE pipes and fittings		**17**
A.1	General	17
A.2	Material characteristics	17
A.3	Chemical resistance	17
A.4	Abrasion resistance	18
A.5	Hydraulic roughness	18
Annex B (informative) Structural design		**19**
B.1	General	19
B.2	Structural design based on practical experience	19
B.3	Structural design based on a design calculations	21
B.4	Selection of fitting stiffness or class	21
Annex C (informative) Designation of pipes and corresponding fittings		**23**
Annex D (informative) Guidance in cleaning plastics pipes		**24**
D.1	Introduction	24
D.2	Cleaning and unblocking	24

D.2.1 Choosing the right equipment 24
D.2.2 Comparing techniques 24
D.3 Conclusions from independent jetting tests 25
D.3.1 Assessing efficiency and impact 25
D.3.2 Testing of plastic pipes 25
D.3.3 Clearing tests 25
D.4 Supplementary cleaning techniques 26
D.5 Recommended practice principles for jetting 26
Bibliography **28**