

ISO 16484-5:2010-12 (E)

Building automation and control systems - Part 5: Data communication protocol

CONTENTS

FOREWORD	vii
1 PURPOSE.....	1
2 SCOPE.....	1
3 DEFINITIONS	1
3.1 Terms Adopted from International Standards.....	1
3.2 Terms Defined for this Standard.....	2
3.3 Abbreviations and Acronyms Used in this Standard	5
4 BACnet PROTOCOL ARCHITECTURE.....	8
4.1 The BACnet Collapsed Architecture.....	9
4.2 BACnet Network Topology.....	11
4.3 Security.....	13
5 THE APPLICATION LAYER	14
5.1 The Application Layer Model.....	14
5.2 Segmentation of BACnet Messages	18
5.3 Transmission of BACnet APDUs.....	19
5.4 Application Protocol State Machines.....	23
5.5 Application Protocol Time Sequence Diagrams	37
5.6 Application Layer Service Conventions	45
6 THE NETWORK LAYER	47
6.1 Network Layer Service Specification	47
6.2 Network Layer PDU Structure	48
6.3 Messages for Multiple Recipients.....	53
6.4 Network Layer Protocol Messages	54
6.5 Network Layer Procedures	56
6.6 BACnet Routers.....	58
6.7 Point-To-Point Half-Routers.....	63
7 DATA LINK/PHYSICAL LAYERS: ISO 8802-3 ("Ethernet") LAN.....	68
7.1 The Use of ISO 8802-2 Logical Link Control (LLC).....	68
7.2 Parameters Required by the LLC Primitives	68
7.3 Parameters Required by the MAC Primitives.....	68
7.4 Physical Media	68
8 DATA LINK/PHYSICAL LAYERS: ARCNET LAN.....	70
8.1 The Use of ISO 8802-2 Logical Link Control (LLC).....	70
8.2 Parameters Required by the LLC Primitives	70
8.3 Mapping the LLC Services to the ARCNET MAC Layer.....	70
8.4 Parameters Required by the MAC Primitives.....	70
8.5 Physical Media	70
9 DATA LINK/PHYSICAL LAYERS: MASTER-SLAVE/TOKEN PASSING (MS/TP) LAN	72
9.1 Service Specification	72
9.2 Physical Layer	74
9.3 MS/TP Frame Format	76
9.4 Overview of the MS/TP Network.....	77
9.5 MS/TP Medium Access Control.....	78
9.6 Cyclic Redundancy Check (CRC)	94
9.7 Interfacing MS/TP LANs with Other BACnet LANs.....	95
9.8 Responding BACnet User Processing of Messages from MS/TP.....	95
9.9 Repeaters	96
10 DATA LINK/PHYSICAL LAYERS: POINT-TO-POINT (PTP).....	98
10.1 Overview	98
10.2 Service Specification	98
10.3 Point-to-Point Frame Format	103
10.4 PTP Medium Access Control Protocol.....	105
11 DATA LINK/PHYSICAL LAYERS: EIA/CEA-709.1 ("LonTalk") LAN	126
11.1 The Use of ISO 8802-2 Logical Link Control (LLC).....	126
11.2 Parameters Required by the LLC Primitives	126
11.3 Mapping the LLC Services to the LonTalk Application Layer	126

11.4	Parameters Required by the Application Layer Primitives.....	126
11.5	Physical Media	127
12	MODELING CONTROL DEVICES AS A COLLECTION OF OBJECTS	128
12.1	Accumulator Object Type.....	132
12.2	Analog Input Object Type	140
12.3	Analog Output Object Type.....	145
12.4	Analog Value Object Type	150
12.5	Averaging Object Type.....	155
12.6	Binary Input Object Type	158
12.7	Binary Output Object Type.....	163
12.8	Binary Value Object Type	169
12.9	Calendar Object Type	174
12.10	Command Object Type.....	176
12.11	Device Object Type	180
12.12	Event Enrollment Object Type	188
12.13	File Object Type	193
12.14	Group Object Type	195
12.15	Life Safety Point Object Type	197
12.16	Life Safety Zone Object Type	203
12.17	Loop Object Type	209
12.18	Multi-state Input Object Type.....	216
12.19	Multi-state Output Object Type.....	220
12.20	Multi-state Value Object Type	224
12.21	Notification Class Object Type.....	229
12.22	Program Object Type.....	232
12.23	Pulse Converter Object Type.....	237
12.24	Schedule Object Type.....	244
12.25	Trend Log Object Type	249
12.26	Access Door Object Type.....	257
12.27	Event Log Object Type.....	264
12.28	Load Control Object Type	270
12.29	Structured View Object Type	279
12.30	Trend Log Multiple Object Type.....	281
13	ALARM AND EVENT SERVICES.....	289
13.1	Change of Value Reporting	290
13.2	Intrinsic Reporting.....	292
13.3	Algorithmic Change Reporting.....	296
13.4	Alarm and Event Occurrence and Notification.....	304
13.5	AcknowledgeAlarm Service	306
13.6	ConfirmedCOVNotification Service	308
13.7	UnconfirmedCOVNotification Service	310
13.8	ConfirmedEventNotification Service.....	311
13.9	UnconfirmedEventNotification Service.....	314
13.10	GetAlarmSummary Service.....	316
13.11	GetEnrollmentSummary Service	318
13.12	GetEventInformation Service	321
13.13	LifeSafetyOperation Service.....	323
13.14	SubscribeCOV Service	325
13.15	SubscribeCOVProperty Service	327
14	FILE ACCESS SERVICES	330
14.1	AtomicReadFile Service.....	331
14.2	AtomicWriteFile Service	334
15	OBJECT ACCESS SERVICES.....	336
15.1	AddListElement Service.....	336
15.2	RemoveListElement Service.....	338
15.3	CreateObject Service	340
15.4	DeleteObject Service	342

15.5	ReadProperty Service	343
15.6	ReadPropertyConditional Service.....	345
15.7	ReadPropertyMultiple Service.....	350
15.8	ReadRange Service.....	353
15.9	WriteProperty Service	357
15.10	WritePropertyMultiple Service.....	359
16	REMOTE DEVICE MANAGEMENT SERVICES.....	362
16.1	DeviceCommunicationControl Service	362
16.2	ConfirmedPrivateTransfer Service	364
16.3	UnconfirmedPrivateTransfer Service	366
16.4	ReinitializeDevice Service.....	367
16.5	ConfirmedTextMessage Service.....	369
16.6	UnconfirmedTextMessage Service.....	371
16.7	TimeSynchronization Service.....	372
16.8	UTCTimeSynchronization Service.....	373
16.9	Who-Has and I-Have Services.....	374
16.10	Who-Is and I-Am Services	376
17	VIRTUAL TERMINAL SERVICES.....	378
17.1	Virtual Terminal Model.....	378
17.2	VT-Open Service.....	382
17.3	VT-Close Service.....	384
17.4	VT-Data Service	385
17.5	Default-terminal Characteristics	387
18	ERROR, REJECT, and ABORT CODES.....	391
18.1	Error Class - DEVICE	391
18.2	Error Class - OBJECT	391
18.3	Error Class - PROPERTY	391
18.4	Error Class - RESOURCES.....	392
18.5	Error Class - SECURITY	393
18.6	Error Class - SERVICES.....	393
18.7	Error Class - COMMUNICATION.....	394
18.8	Error Class - VT	395
18.9	Reject Reason	396
18.10	Abort Reason	396
19	BACnet PROCEDURES	398
19.1	Backup and Restore	398
19.2	Command Prioritization.....	401
19.3	Device Restart Procedure	404
20	ENCODING BACnet PROTOCOL DATA UNITS.....	405
20.1	Encoding the Fixed Part of BACnet APDUs.....	405
20.2	Encoding the Variable Part of BACnet APDUs	415
21	FORMAL DESCRIPTION OF APPLICATION PROTOCOL DATA UNITS	429
22	CONFORMANCE AND INTEROPERABILITY	477
22.1	Conformance to BACnet	477
22.2	BACnet Interoperability	478
23	EXTENDING BACnet TO ACCOMMODATE VENDOR PROPRIETARY INFORMATION	480
23.1	Extending Enumeration Values	480
23.2	Using the PrivateTransfer Services to Invoke Non-Standardized Services	481
23.3	Adding Proprietary Properties to a Standardized Object	481
23.4	Adding Proprietary Object Types to BACnet.....	481
23.5	Restrictions on Extending BACnet.....	482
24	NETWORK SECURITY	483
24.1	Security Architecture.....	483
24.2	Authentication Mechanisms	484
24.3	Data Confidentiality Mechanism	486
24.4	RequestKey Service.....	487
24.5	Authenticate Service.....	488

25	REFERENCES	491
	ANNEX A - PROTOCOL IMPLEMENTATION CONFORMANCE STATEMENT (NORMATIVE)	494
	ANNEX B - GUIDE TO SPECIFYING BACnet DEVICES (INFORMATIVE)	496
	ANNEX C - FORMAL DESCRIPTION OF OBJECT TYPE STRUCTURES (INFORMATIVE)	497
	ANNEX D - EXAMPLES OF STANDARD OBJECT TYPES (INFORMATIVE).....	512
	D.1 Example of an Accumulator Object.....	512
	D.2 Example of an Analog Input Object	512
	D.3 Example of an Analog Output Object.....	513
	D.4 Example of an Analog Value Object	513
	D.5 Example of an Averaging Object.....	514
	D.6 Example of a Binary Input Object	514
	D.7 Example of a Binary Output Object.....	515
	D.8 Example of a Binary Value Object	516
	D.9 Example of a Calendar Object	517
	D.10 Example of a Command Object.....	517
	D.11 Example of a Device Object	518
	D.12 Example of an Event Enrollment Object	520
	D.13 Example of a File Object	522
	D.14 Example of a Group Object	522
	D.15 Example of a Life Safety Point Object	522
	D.16 Example of a Life Safety Zone Object	523
	D.17 Example of a Loop Object.....	524
	D.18 Example of a Multi-state Input Object.....	525
	D.19 Example of a Multi-state Output Object.....	526
	D.20 Example of a Multi-state Value Object	527
	D.21 Example of a Notification Class Object.....	527
	D.22 Example of a Program Object.....	527
	D.23 Example of a Pulse Converter Object.....	529
	D.24 Example of a Schedule Object.....	529
	D.25 Example of a Trend Log Object	530
	D.23 Example of a Trend Log Object	533
	ANNEX E - EXAMPLES OF BACnet APPLICATION SERVICES (INFORMATIVE).....	535
	E.1 Alarm and Event Services	535
	E.2 File Access Services	539
	E.3 Object Access Services.....	541
	E.4 Remote Device Management Services	548
	E.5 Virtual Terminal Services.....	551
	E.6 Security Services	552
	ANNEX F - EXAMPLES OF APDU ENCODING (INFORMATIVE)	554
	F.1 Example Encodings for Alarm and Event Services	554
	F.2 Example Encodings for File Access Services.....	563
	F.3 Example Encodings for Object Access Services	565
	F.4 Example Encodings for Remote Device Management Services.....	579
	F.5 Example Encodings for Virtual Terminal Services	584
	F.6 Example Encodings for Security Services.....	586
	ANNEX G - CALCULATION OF CRC (INFORMATIVE).....	588
	G.1 Calculation of the Header CRC	588
	G.2 Calculation of the Data CRC	594
	ANNEX H - COMBINING BACnet NETWORKS WITH NON-BACnet NETWORKS (NORMATIVE)	599
	H.1 Mapping Non-BACnet Networks onto BACnet Routers.....	599
	H.2 Multiple 'Virtual' BACnet Devices in a Single Physical Device	599
	H.3 Using BACnet with the DARPA Internet Protocols.....	599
	H.4 Using BACnet with the IPX Protocol.....	600
	H.5 Using BACnet with EIB/KNX	602
	ANNEX I - COMMANDABLE PROPERTIES WITH MINIMUM ON AND OFF TIMES (INFORMATIVE).....	615
	ANNEX J - BACnet/IP (NORMATIVE)	617
	J.1 General	617

J.2	BACnet Virtual Link Layer	617
J.3	BACnet/IP Directed Messages	621
J.4	BACnet/IP Broadcast Messages	621
J.5	Addition of Foreign B/IP Devices to an Existing B/IP Network	622
J.6	Routing Between B/IP and non-BP/IP BACnet Networks	624
J.7	Routing Between Two B/IP BACnet Networks	625
J.8	Use of IP Multicast within BACnet/IP	627
J.9	Sources for Internet Information.....	628
ANNEX K	- BACnet INTEROPERABILITY BUILDING BLOCKS (BIBBs) (NORMATIVE).....	629
K.1	Data Sharing BIBBs	629
K.1.1	BIBB - Data Sharing - ReadProperty - A (DS-RP-A).....	629
K.1.2	BIBB-Data Sharing-ReadProperty-B (DS-RP-B).....	629
K.1.3	BIBB - Data Sharing-ReadPropertyMultiple-A (DS-RPM-A)	629
K.1.4	BIBB - Data Sharing-ReadPropertyMultiple-B (DS-RPM-B).....	629
K.1.5	BIBB - Data Sharing-ReadPropertyConditional-A (DS-RPC-A)	629
K.1.6	BIBB - Data Sharing-ReadPropertyConditional-B (DS-RPC-B).....	630
K.1.7	BIBB - Data Sharing-WriteProperty-A (DS-WP-A).....	630
K.1.8	BIBB - Data Sharing-WriteProperty-B (DS-WP-B).....	630
K.1.9	BIBB - Data Sharing-WritePropertyMultiple-A (DS-WPM-A)	630
K.1.10	BIBB - Data Sharing-WritePropertyMultiple-B (DS-WPM-B).....	630
K.1.11	BIBB - Data Sharing-COV-A (DS-COV-A)	630
K.1.12	BIBB - Data Sharing-COV-B (DS-COV-B).....	631
K.1.13	BIBB - Data Sharing-COVP-A (DS-COVP-A).....	631
K.1.14	BIBB - Data Sharing-COVP-B (DS-COVP-B)	631
K.1.15	BIBB - Data Sharing-COV-Unsolicited-A (DS-COVU-A).....	631
K.1.16	BIBB - Data Sharing-COV-Unsolicited-B (DS-COVU-B)	631
K.2	Alarm and Event Management BIBBs.....	631
K.2.1	BIBB - Alarm and Event-Notification-A (AE-N-A).....	632
K.2.2	BIBB - Alarm and Event-Notification Internal-B (AE-N-I-B)	632
K.2.3	BIBB - Alarm and Event-Notification External-B (AE-N-E-B).....	632
K.2.4	BIBB - Alarm and Event-ACK-A (AE-ACK-A).....	632
K.2.5	BIBB - Alarm and Event-ACK-B (AE-ACK-B)	632
K.2.6	BIBB - Alarm and Event-Alarm Summary-A (AE-ASUM-A).....	632
K.2.7	BIBB - Alarm and Event-Alarm Summary-B (AE-ASUM-B).....	633
K.2.8	BIBB - Alarm and Event-Enrollment Summary-A (AE-ESUM-A)	633
K.2.9	BIBB - Alarm and Event-Enrollment Summary-B (AE-ESUM-B).....	633
K.2.10	BIBB - Alarm and Event-Information-A (AE-INFO-A)	633
K.2.11	BIBB - Alarm and Event-Information-B (AE-INFO-B).....	633
K.2.12	BIBB - Alarm and Event-LifeSafety-A (AE-LS-A)	633
K.2.13	BIBB - Alarm and Event-LifeSafety-B (AE-LS-B).....	633
K.3	Scheduling BIBBs.....	634
K.3.1	BIBB - Scheduling-A (SCHED-A).....	634
K.3.2	BIBB - Scheduling-Internal-B (SCHED-I-B).....	634
K.3.3	BIBB - Scheduling-External-B (SCHED-E-B).....	634
K.4	Trending BIBBs.....	634
K.4.1	BIBB - Trending-Viewing and Modifying Trends-A (T-VMT-A).....	634
K.4.2	BIBB - Trending-Viewing and Modifying Trends Internal-B (T-VMT-I-B)	634
K.4.3	BIBB - Trending-Viewing and Modifying Trends External-B (T-VMT-E-B)	634
K.4.4	BIBB - Trending-Automated Trend Retrieval-A (T-ATR-A).....	635
K.4.5	BIBB - Trending-Automated Trend Retrieval-B (T-ATR-B).....	635
K.4.1	BIBB - Trending-Viewing and Modifying Trends-A (T-VMT-A).....	635
K.4.2	BIBB - Trending-Viewing and Modifying Trends Internal-B (T-VMT-I-B)	635
K.4.3	BIBB - Trending-Viewing and Modifying Trends External-B (T-VMT-E-B)	635
K.4.4	BIBB - Trending-Automated Trend Retrieval-A (T-ATR-A).....	635
K.4.5	BIBB - Trending-Automated Trend Retrieval-B (T-ATR-B).....	636
K.5	Device and Network Management BIBBs.....	636
K.5.1	BIBB - Device Management-Dynamic Device Binding-A (DM-DDB-A).....	636

K.5.2	BIBB - Device Management-Dynamic Device Binding-B (DM-DDB-B)	636
K.5.3	BIBB - Device Management-Dynamic Object Binding-A (DM-DOB-A)	636
K.5.4	BIBB - Device Management-Dynamic Object Binding-B (DM-DOB-B)	637
K.5.5	BIBB - Device Management-DeviceCommunicationControl-A (DM-DCC-A)	637
K.5.6	BIBB - Device Management-DeviceCommunicationControl-B (DM-DCC-B)	637
K.5.9	BIBB - Device Management-Text Message-A (DM-TM-A)	637
K.5.10	BIBB - Device Management-Text Message-B (DM-TM-B)	637
K.5.11	BIBB - Device Management-TimeSynchronization-A (DM-TS-A)	637
K.5.12	BIBB - Device Management-TimeSynchronization-B (DM-TS-B)	638
K.5.13	BIBB - Device Management-UTCTimeSynchronization-A (DM-UTC-A)	638
K.5.14	BIBB - Device Management-UTCTimeSynchronization-B (DM-UTC-B)	638
K.5.15	BIBB - Device Management-ReinitializeDevice-A (DM-RD-A)	638
K.5.16	BIBB - Device Management-ReinitializeDevice-B (DM-RD-B)	638
K.5.17	BIBB - Device Management-Backup and Restore-A (DM-BR-A)	638
K.5.18	BIBB - Device Management-Backup and Restore-B (DM-BR-B)	639
K.5.19	BIBB - Device Management-Restart-A (DM-R-A)	639
K.5.20	BIBB - Device Management-Restart-B (DM-R-B)	639
K.5.21	BIBB - Device Management-List Manipulation-A (DM-LM-A)	639
K.5.22	BIBB - Device Management-List Manipulation-B (DM-LM-B)	639
K.5.23	BIBB - Device Management-Object Creation and Deletion-A (DM-OCD-A)	640
K.5.24	BIBB - Device Management-Object Creation and Deletion-B (DM-OCD-B)	640
K.5.25	BIBB - Device Management-Virtual Terminal-A (DM-VT-A)	640
K.5.26	BIBB - Device Management-Virtual Terminal-B (DM-VT-B)	640
K.5.27	BIBB - Network Management-Connection Establishment-A (NM-CE-A)	640
K.5.28	BIBB - Network Management-Connection Establishment-B (NM-CE-B)	640
K.5.29	BIBB - Network Management-Router Configuration-A (NM-RC-A)	641
K.5.30	BIBB - Network Management-Router Configuration-B (NM-RC-B)	641
ANNEX L	- DESCRIPTIONS AND PROFILES OF STANDARDIZED BACnet DEVICES (NORMATIVE)	642
L.1	BACnet Operator Workstation (B-OWS)	642
L.2	BACnet Building Controller (B-BC)	642
L.3	BACnet Advanced Application Controller (B-AAC)	643
L.4	BACnet Application Specific Controller (B-ASC)	643
L.5	BACnet Smart Actuator (B-SA)	644
L.6	BACnet Smart Sensor (B-SS)	644
L.7	Profiles of the Standard BACnet Devices	645
ANNEX M	- GUIDE TO EVENT NOTIFICATION PRIORITY ASSIGNMENTS (INFORMATIVE)	646
M.1	Life Safety Message Group (0-31)	646
M.2	Property Safety Message Group (32-63)	647
M.3	Supervisory Message Group (64-95)	647
M.4	Trouble Message Group (96-127)	648
M.5	Miscellaneous Higher Priority Message Group (128-191)	649
M.5	Miscellaneous Lower Priority Message Group (192-255)	649
ANNEX N	- BACnet/WS WEB SERVICES INTERFACE (NORMATIVE)	650
HISTORY OF REVISIONS	682