

DIN EN 15316-2:2017-09 (E)

Energy performance of buildings - Method for calculation of system energy requirements and system efficiencies - Part 2: Space emission systems (heating and cooling), Module M3-5, M4-5

Contents		Page
European foreword		4
Introduction		5
1	Scope	7
2	Normative references	9
3	Terms and definitions	9
4	Symbols and abbreviations	10
4.1	Symbols	10
4.2	Subscripts	10
5	Description of the method	10
5.1	Output of the method	10
5.2	General description of the method	11
6	Calculation Method	11
6.1	Output data	11
6.2	Calculation time steps	12
6.3	Input data	12
6.4	Monthly and yearly calculation procedure	15
6.5	Hourly calculation procedure	20
7	Quality control	24
8	Compliance check	24
Annex A (normative) Template for choices, input data and references (Additional heating and cooling losses / auxiliary energy)		25
A.1	Introduction	25
A.2	Temperature variation for free heating surfaces (radiators), room heights 4 m (heating case)	26
A.3	Temperature Variation for component integrated heating surfaces (panel heaters) (room heights 4 m, heating case)	28
A.4	Temperature variation for air heating systems; room heights 4 m (heating case)	30
A.5	Temperature Variation for electrical heating (room heights 4 m, heating case)	31
A.6	Temperature Variation air heating (ventilation systems, room heights 4 m, heating case)	32
A.7	Temperature variation for room spaces with heights > 4 m (large indoor space buildings, heating case)	32
A.8	Temperature variation for room heaters fired by solid fuel	35
A.9	Temperature variation for water based cooling systems; room heights 4 m (cooling case)	36
A.10	Auxiliary Energy	37
A.11	Additional Information	38

Annex B (informative) Default choices, input data and references (additional heating and cooling losses / auxiliary energy)	40
B.1 Introduction	40
B.2 Temperature variation for free heating surfaces (radiators); room heights 4 m (heating case)	41
B.3 Temperature Variation for component integrated heating surfaces (panel heaters) (room heights 4 m, heating case)	43
B.4 Temperature variation for air heating systems; room heights 4 m (heating case)	45
B.5 Temperature Variation for electrical heating (room heights 4 m, heating case)	46
B.6 Temperature Variation air heating (ventilation systems, room heights 4 m, heating case)	47
B.7 Temperature variation for room spaces with heights > 4 m (large indoor space buildings, heating case)	47
B.8 Temperature variation for room heaters fired by solid fuel	50
B.9 Temperature variation for water based cooling systems; room heights 4 m (cooling case)	51
B.10 Auxiliary Energy	52
B.11 Additional Information	53
Bibliography	55