

ISO 19455-1:2019-11 (E)

Planning for functional performance testing for building commissioning - P art 1: Secondary hydronic pump, system and associated controls

Contents		Page
Foreword		iv
Introduction		v
1	Scope	1
2	Normative references	1
3	Terms and definitions	1
4	Planning for functional performance testing	3
4.1	Design of secondary hydronic pump system	3
4.2	Data acquisition	3
5	Functional performance testing method	8
5.1	General	8
5.2	Testing method for verifying relationship between water flow rate and number of operating units (test 1)	9
5.2.1	General	9
5.2.2	Step 1) Measurement of operational data	9
5.2.3	Step 2) Calculation of number of operating pumps	9
5.2.4	Step 3) Analysis of relationship between water flow rate and number of operation units	9
5.2.5	Step 4) Clarification of the design specification	9
5.2.6	Step 5) Comparison with the design values	10
5.3	Testing method for verifying relationship between water flow rate and pressure (test 2, 3)	10
5.3.1	General	10
5.3.2	Step 1) Measurement of operational data	10
5.3.3	Step 2) Analysis of relationship between water flow rate and pressure	11
5.3.4	Step 3) Clarification of the design specification	11
5.3.5	Step 4) Comparison with the design values	11
5.4	Testing method for verifying relationship between water flow rate and energy consumption (test 4)	11
5.4.1	General	11
5.4.2	Step 1) Measurement of operational data	12
5.4.3	Step 2) Analysis of relationship between water flow rate and energy consumption	12
5.4.4	Step 3) Clarification of the design specification	12
5.4.5	Step 4) Comparison with the design values	12
Annex A (informative)	Data acquisition planning	13
Bibliography		14