DIN EN 13141-4:2022-12 (E)

Ventilation for buildings - Performance testing of components/products for residential ventilation - Part 4: Aerodynamic, electrical power and acoustic performance of unidirectional ventilation units

Contents

Page

European foreword 4

Introduction 6

1 Scope 8

2 Normative references 8

3 Terms and definitions 9

4 Symbols and abbreviations 11

5 Performance testing of aerodynamic characteristics 13
5.1 External leakages 13
5.1.1 Test installation 13
5.1.2 Test procedure 13
5.2 Air flow/pressure performance 15
5.2.1 General 15
5.2.2 Test Installation 16
5.2.3 Test procedure 17
5.3 Air flow sensitivity 21
5.4 Indoor/outdoor airtightness 22

6 Energy 22
6.1 Performance testing of electrical power 22
6.1.1 Testing method 22
6.1.2 Electrical power input at reference and maximum air volume flow 22
6.1.3 Assessment of part load energy efficiency (optional) 22
6.2 Operable mode 22
6.3 Standby mode 22

7 Performance testing of acoustic characteristics 23
7.1 General 23
7.2 Noise radiated through the casing of the unit LWc 25
7.2.1 General 25
7.2.2 Test Installation 25
7.2.3 Measurements 26
7.3 Radiated sound power level in the indoor or outdoor space - LWi and LWo 27
7.3.1 General 27
7.3.2 Test Installation 27
7.3.3 Measurements 29
7.4 In-duct sound power level of the unit 29
7.4.1 General 29
7.4.2 Test Installation 29
7.4.3 Measurements 31
7.5 Airborne sound insulation 31
7.5.1 General 31
7.5.2 Test Installation 31
7.5.3 Measurements 32

8 Test results 32
8.1 Test report 32
8.2 Product specifications 32
8.3 Leakages 33
8.4 Air flow/pressure curve 33
8.5 Air flow sensitivity for non-ducted ventilation units 33
8.6 Indoor/outdoor airtightness for non-ducted ventilation units 33
8.7 Energy 33
8.8 Acoustic characteristics 33

Annex A (normative) Connection box(es) 36

Annex B (normative) Evaluation of maximum air volume flow and pressure 38

Annex C (normative) Examples for the evaluation of reference pressure 39

Annex D (informative) Assessment of part load energy efficiency 40

Bibliography 44