

<b>Warnvermerk / Warning notice</b>	DIN EN 15502-1:2022-02
<b>Datum / Date</b>	2022-12-09
<p><b>Heizkessel für gasförmige Brennstoffe — Teil 1: Allgemeine Anforderungen und Prüfungen</b>  <b>Gas-fired heating boilers — Part 1: General requirements and tests</b>  <b>Chaudières de chauffage central utilisant les combustibles gazeux — Partie 1: Exigences générales et essais</b></p> <p><b>In DIN EN 15502-1:2022-02 sind folgende Korrekturen auszuführen:</b></p> <p>In 9.1.2 ist der Satz „Die Raumtemperatur muss <math>20\text{ °C} \pm 1\text{ °C}</math> betragen.“ zu löschen.</p> <p>In 8.1.2.1 wird der Text:</p> <p>„welche eine Umgebungstemperatur von <math>(20 \pm 5)\text{ K}</math> hat.“</p> <p>wie folgt geändert:</p> <p>„welche eine Umgebungstemperatur von <math>(20 \pm 5)\text{ °C}</math> hat.“</p> <p><b>In DIN EN 15502-1:2022-02 the following changes shall be made:</b></p> <p>In 9.1.2, delete the following sentence:  “The temperature of the room shall be <math>20\text{°C} \pm 1\text{° C}</math>”</p> <p>Under 8.1.2.1, change the existing text:</p> <p>"which has an ambient temperature of <math>(20 \pm 5)\text{ K}</math>."</p> <p>as follows:</p> <p>"which has an ambient temperature of <math>(20 \pm 5)\text{ °C}</math>."</p> <p><b>HINWEIS:</b>  Wir weisen darauf hin, dass der vorliegende Fehler negative Auswirkungen haben kann. Es liegt in der Verantwortung des Anwenders, den Sachverhalt bei der Anwendung der Norm angemessen zu berücksichtigen, um einen etwaigen Schaden zu vermeiden.</p> <p><b>Bitte prüfen Sie unverzüglich, ob und inwieweit in Ihrem Fall eine Schadengefahr besteht und reagieren Sie entsprechend. Falls Sie das Dokument selbst nicht anwenden, jedoch den/die betroffenen Anwender kennen, leiten Sie diesen Warnvermerk unverzüglich an den/die Anwender weiter.</b></p> <p><b>INFORMATION:</b>  Please note that this error can have negative implications. When applying the standard, it is the user’s responsibility to take due account of this warning notice in order to avert potential damage.</p> <p><b>Please check without delay whether, and to what extent, there is a risk of damage in your case, and take the necessary action. If you do not apply the document yourself but are aware of any users who may be affected, please forward this warning notice on to them without delay.</b></p>	

- Leerseite -