

ISO/IEC 19395:2015-01 (E)

Information technology - Sustainability for and by information technology - Smart data centre resource monitoring and control

| Contents | | Page |
|-----------------------|-------------------------------------------------------------------|------|
| Foreword | | iv |
| Introduction | | v |
| 1 | Scope | 1 |
| 2 | Conformance | 2 |
| 3 | Normative references | 2 |
| 4 | Terms, definitions and acronyms | 3 |
| 5 | Domains | 4 |
| 5.1 | Introduction | 4 |
| 5.2 | Base Domain | 5 |
| 5.2.1 | CIM_System | 5 |
| 5.2.2 | CIM_BaseMetricDefinition | 5 |
| 5.2.3 | CIM_BaseMetricValue | 5 |
| 5.2.4 | CIM_MetricDefForME | 6 |
| 5.2.5 | CIM_MetricInstance | 6 |
| 5.2.6 | CIM_RegisteredProfile | 6 |
| 5.2.7 | CIM_SystemDevice | 6 |
| 5.2.8 | CIM_Component | 7 |
| 5.2.9 | Metrics for fluid measurements | 7 |
| 5.2.10 | CIM_NumericSensor | 10 |
| 5.2.11 | CIM_EnabledLogicalElementCapabilities | 10 |
| 5.2.12 | CIM_ElementCapabilities | 10 |
| 5.3 | IT Domain | 10 |
| 5.4 | Power Domain | 13 |
| 5.5 | Fluid Domain | 13 |
| 5.5.1 | SDC_FluidConnection | 15 |
| 5.5.2 | SDC_FluidElement | 15 |
| 5.5.3 | SDC_FluidMeasurementPoint | 16 |
| 5.5.4 | SDC_FluidTransferPort | 16 |
| 5.5.5 | SDC_CoolingSystem | 16 |
| 5.5.6 | SDC_CoolingSettingData | 16 |
| 6 | Properties | 16 |
| 7 | Messages | 22 |
| 7.1 | Commands and responses | 23 |
| 7.1.1 | GET | 23 |
| 7.1.2 | SET | 23 |
| 7.2 | Event subscription and notification | 24 |
| 7.2.1 | Event subscription | 24 |
| 7.2.2 | Event notification | 25 |
| Annex A (normative) | ECMA-400 Edition 1 Resource configuration options | 26 |
| Annex B (informative) | Resource configuration of a CRAH system's fluid perspective | 30 |