

# ISO/IEC TS 29125:2017-04 (E)

## Information technology - Telecommunications cabling requirements for remote powering of terminal equipment

---

Contents	Page
FOREWORD.....	4
INTRODUCTION.....	6
1 Scope.....	7
2 Normative references.....	7
3 Terms, definitions and abbreviated terms.....	7
3.1 Terms and definitions.....	7
3.2 Abbreviated terms.....	8
4 Conformance.....	8
5 Cabling selection and performance.....	9
6 Installation conditions.....	9
6.1 General.....	9
6.2 Ambient temperature.....	9
6.3 Temperature rise and current capacity.....	9
6.4 Factors affecting temperature increase.....	11
6.4.1 General.....	11
6.4.2 Installation near equipment.....	11
6.4.3 Cable count within a bundle.....	11
6.4.4 Reducing temperature increase.....	12
6.4.5 Cable bundle suspended in air.....	13
6.4.6 Administration.....	14
7 Remote power delivery over balanced cabling.....	14
8 Connecting hardware.....	15
Annex A (informative) Mitigation considerations for installed cabling.....	17
A.1 General.....	17
A.2 Minimum cabling class.....	17
A.3 Bundle size and location.....	17
A.4 Mitigation options.....	17
Annex B (informative) Modelling temperature rise for cable types, bundle sizes and installation conditions.....	18
B.1 Model basics.....	18
B.2 Power dissipated ( $P$ ).....	18
B.3 Temperature difference from ambient temperature to bundle surface ( $\Delta T_U$ ).....	19
B.3.1 Model equations.....	19
B.3.2 Typical values for constant $\rho_U$ .....	19
B.4 Temperature difference from bundle surface to bundle centre ( $\Delta T_{th}$ ).....	19
B.4.1 Model equations.....	19
B.4.2 Typical values for constant $\rho_{th}$ .....	19
B.5 Temperature variation within the bundle ( $\Delta T(x)$ ).....	20
B.6 Alternative presentation of the model.....	20
B.7 Adaptation model used to derive temperature rise vs. cables in a bundle.....	20
B.8 Calculations.....	21
B.9 Example.....	21
B.10 Coefficients for air and conduit.....	22
Annex C (informative) Transmission parameters related to remote powering.....	23
C.1 DC loop resistance.....	23

C.2	DC resistance unbalance (within pair).....	23
C.3	DC resistance unbalance (pair to pair).....	24
Annex D (informative)	Illustrations of heating of various bundle sizes and configurations.....	26
D.1	Limiting cable bundle size.....	26
D.2	Separating into smaller bundles.....	27
Annex E (informative)	Test protocol.....	28
E.1	Background.....	28
E.2	Test set-up.....	28
Annex F (informative)	Detailed test procedure.....	30
F.1	General.....	30
F.2	Test set-up.....	30
F.2.1	Thermocouple placement.....	30
F.2.2	Measurement of cable bundle in air.....	31
F.2.3	Measurement of cable bundle in conduit.....	32
Bibliography.....		34

Figure 1 – Examples of end point powering systems using signal pairs (top) and spare pairs (bottom).....	14
Figure 2 – Examples of mid-span powering systems.....	15
Figure B.1 – Temperature rise profile.....	18
Figure D.1 – 91-cable bundle.....	26
Figure D.2 – Three bundles of 37 cables.....	26
Figure D.3 – Three bundles of 37 cables with separation.....	27
Figure E.1 – 37-cable bundle and temperature location.....	28
Figure E.2 – "Perfect bundle" and thermocouple configuration.....	29
Figure E.3 – Conductor configuration.....	29
Figure F.1 – Placement of thermocouple.....	30
Figure F.2 – Securing of the thermocouple.....	31
Figure F.3 – Test set-up for cable bundles in air.....	32
Figure F.4 – Test set-up for cable bundles in conduit.....	33

Table 1 – Maximum current per conductor versus temperature rise in a 37-cable bundle in air and conduit (all 4 pairs energized).....	10
Table 2 – Calculated worst case current per conductor versus temperature rise in a bundle of 37 4-pair cables (all pairs energized).....	11
Table 3 – Temperature rise versus cable bundle size (500 mA per conductor).....	12
Table 4 – Temperature rise for a type of cable versus the number of energized pairs in a 37-cable bundle (500 mA per conductor).....	13
Table B.1 – Bundling coefficients for different types of cables and cords (all 4 pairs energized).....	22
Table C.1 – Maximum DC loop resistance of channels.....	23
Table C.2 – DC resistance unbalance of cables, connecting hardware and channels.....	24
Table C.3 – DC resistance unbalance (pair to pair).....	25