

ISO/IEC TS 29125:2017-04 (E)

Information technology - Telecommunications cabling requirements for remote powering of terminal equipment

Contents	Page
FOREWORD.....	4
INTRODUCTION.....	6
1 Scope.....	7
2 Normative references.....	7
3 Terms, definitions and abbreviated terms.....	7
3.1 Terms and definitions.....	7
3.2 Abbreviated terms.....	8
4 Conformance.....	8
5 Cabling selection and performance.....	9
6 Installation conditions.....	9
6.1 General.....	9
6.2 Ambient temperature.....	9
6.3 Temperature rise and current capacity.....	9
6.4 Factors affecting temperature increase.....	11
6.4.1 General.....	11
6.4.2 Installation near equipment.....	11
6.4.3 Cable count within a bundle.....	11
6.4.4 Reducing temperature increase.....	12
6.4.5 Cable bundle suspended in air.....	13
6.4.6 Administration.....	14
7 Remote power delivery over balanced cabling.....	14
8 Connecting hardware.....	15
Annex A (informative) Mitigation considerations for installed cabling.....	17
A.1 General.....	17
A.2 Minimum cabling class.....	17
A.3 Bundle size and location.....	17
A.4 Mitigation options.....	17
Annex B (informative) Modelling temperature rise for cable types, bundle sizes and installation conditions.....	18
B.1 Model basics.....	18
B.2 Power dissipated (P).....	18
B.3 Temperature difference from ambient temperature to bundle surface (ΔT_U).....	19
B.3.1 Model equations.....	19
B.3.2 Typical values for constant ρ_U	19
B.4 Temperature difference from bundle surface to bundle centre (ΔT_{th}).....	19
B.4.1 Model equations.....	19
B.4.2 Typical values for constant ρ_{th}	19
B.5 Temperature variation within the bundle ($\Delta T(x)$).....	20
B.6 Alternative presentation of the model.....	20
B.7 Adaptation model used to derive temperature rise vs. cables in a bundle.....	20
B.8 Calculations.....	21
B.9 Example.....	21
B.10 Coefficients for air and conduit.....	22
Annex C (informative) Transmission parameters related to remote powering.....	23
C.1 DC loop resistance.....	23

C.2	DC resistance unbalance (within pair).....	23
C.3	DC resistance unbalance (pair to pair).....	24
Annex D (informative)	Illustrations of heating of various bundle sizes and configurations.....	26
D.1	Limiting cable bundle size.....	26
D.2	Separating into smaller bundles.....	27
Annex E (informative)	Test protocol.....	28
E.1	Background.....	28
E.2	Test set-up.....	28
Annex F (informative)	Detailed test procedure.....	30
F.1	General.....	30
F.2	Test set-up.....	30
F.2.1	Thermocouple placement.....	30
F.2.2	Measurement of cable bundle in air.....	31
F.2.3	Measurement of cable bundle in conduit.....	32
Bibliography.....		34

Figure 1 – Examples of end point powering systems using signal pairs (top) and spare pairs (bottom).....	14
Figure 2 – Examples of mid-span powering systems.....	15
Figure B.1 – Temperature rise profile.....	18
Figure D.1 – 91-cable bundle.....	26
Figure D.2 – Three bundles of 37 cables.....	26
Figure D.3 – Three bundles of 37 cables with separation.....	27
Figure E.1 – 37-cable bundle and temperature location.....	28
Figure E.2 – "Perfect bundle" and thermocouple configuration.....	29
Figure E.3 – Conductor configuration.....	29
Figure F.1 – Placement of thermocouple.....	30
Figure F.2 – Securing of the thermocouple.....	31
Figure F.3 – Test set-up for cable bundles in air.....	32
Figure F.4 – Test set-up for cable bundles in conduit.....	33

Table 1 – Maximum current per conductor versus temperature rise in a 37-cable bundle in air and conduit (all 4 pairs energized).....	10
Table 2 – Calculated worst case current per conductor versus temperature rise in a bundle of 37 4-pair cables (all pairs energized).....	11
Table 3 – Temperature rise versus cable bundle size (500 mA per conductor).....	12
Table 4 – Temperature rise for a type of cable versus the number of energized pairs in a 37-cable bundle (500 mA per conductor).....	13
Table B.1 – Bundling coefficients for different types of cables and cords (all 4 pairs energized).....	22
Table C.1 – Maximum DC loop resistance of channels.....	23
Table C.2 – DC resistance unbalance of cables, connecting hardware and channels.....	24
Table C.3 – DC resistance unbalance (pair to pair).....	25