ISO 18095:2018-02 (E)

Condition monitoring and diagnostics of power transformers

Contents

Page

Foreword vi

Introduction vii

1 Scope 1

2 Normative references 1

3 Termsanddefinitions 1

4 Abbreviated terms 1

5 Approach to selecting appropriate condition monitoring techniques 2
5.1 Implementing condition monitoring of transformers 2
5.2 Components, failure modes and detection techniques 2

6 Power transformer types 3
6.1 Oil-filled transformers 3
6.2 Dry-type transformers 4
6.3 Gas-insulated transformers (GITs) 6

7 Power transformer failure mode analysis 6
7.1 Components 6
7.2 Categories of failure mode 7
7.2.1 General 7
7.2.2 Dielectric failures 7
7.2.3 Thermal 7
7.2.4 Mechanical 7
7.2.5 External 8
7.3 Failure modes 8
7.4 Influences on rate of failure mode progression 9
7.4.1 General 9
7.4.2 Loading 9
7.4.3 Environment 9
7.4.4 Design 10
7.4.5 Maintenance 10
7.4.6 Protection 10

8 Range of techniques 10

9 Overview of techniques for condition monitoring power transformers 12
9.1 Mains current/voltage/load 12
9.1.1 Fault mechanism 12
9.1.2 Technique 12
9.1.3 Faults detected/components covered 12
9.2 Visual 12
9.2.1 Fault mechanism 12
9.2.2 Technique 13
9.2.3 Faults detected/components covered 13
9.3 Oil condition 13
9.3.1 Fault mechanism 13
9.3.2 Technique 15

9.3.3 Faults detected/components covered 15
9.4 Temperature including thermography 17
9.4.1 Fault mechanism 17
9.4.2 Technique 17
9.4.3 Faults detected/components covered 17
9.5 Partial discharge (PD) 17
9.5.1 Fault mechanism 17
9.5.2 Techniques 18
9.5.3 Faults detected/components covered 19

9.6 Dissolved gas analysis (DGA) 19
9.6.1 Fault mechanism 19
9.6.2 Technique 19
9.6.3 Faults detected/components covered 20
9.7 Noise 20
9.7.1 Fault mechanism 20
9.7.2 Technique 21
9.7.3 Faults detected/components covered 21
9.8 Ultrasound 21
9.8.1 Fault mechanism 21
9.8.2 Technique 21
9.8.3 Faults detected/components covered 21
9.9 Vibration 22
9.9.1 Fault mechanism 22
9.9.2 Technique 22
9.9.3 Faults detected/components covered 22
9.10 Power factor/tan-delta and capacitance 22
9.10.1 Fault mechanism 22
9.10.2 Technique 23
9.10.3 Faults detected/components covered 24
9.11 Resistance 25
9.11.1 Fault mechanism 25
9.11.2 Technique 25
9.11.3 Faults detected/components covered 25
9.12 Dielectric frequency response (DFR), polarization/depolarisation current (PDC), recovery voltage method (RVM) 25
9.12.1 Fault mechanism 25
9.12.2 Technique 26
9.12.3 Faults detected 26
9.13 Frequency response analysis (FRA) 26
9.13.1 Fault mechanism 26
9.13.2 Technique 27
9.13.3 Faults detected 27
9.14 Ten (10) kV single-phase excitation current 28
9.14.1 Fault mechanism 28
9.14.2 Technique 28
9.14.3 Faults detected/components covered 28
9.15 Leakage reactance flux 28
9.15.1 Fault mechanism 28
9.15.2 Technique 29
9.15.3 Faults detected/components covered 29
9.16 Bushing capacitance measurement 29
9.16.1 Fault mechanism 29
9.16.2 Technique 29
9.16.3 Faults detected/components covered 31
9.17 Novel techniques 31
9.17.1 Winding clamping force estimation (WCE) method 31
9.17.2 Online model-based voltage and current waveform analysis 32

10 Establishing the programme 32
10.1 Selection of techniques -- Individually and in combination 32
10.2 Selection of frequency of each monitoring technique 33

Annex A (informative)Factorsinfluencingthelifeofpaper-basedinsulationandtheroleof transformer oil analysis/dissolved gas analysis 34

Annex B (informative) Example of typical condition monitoring programme -- Output as a result of use of this document 38

Annex C (informative) Failure mode and symptoms analysis (FMSA) 39

Bibliography 44