

ISO 7240-17:2009-08 (E)

Fire detection and fire alarm systems - Part 17: Short-circuit isolators

Contents		Page
Foreword		iv
Introduction		vi
1	Scope	1
2	Normative references	1
3	Terms and definitions	2
4	Requirements	2
4.1	Compliance	2
4.2	Integral status indication	2
4.3	Connection of ancillary devices	2
4.4	Monitoring of detachable short-circuit isolators	3
4.5	Manufacturer's adjustments	3
4.6	On-site adjustments	3
4.7	Marking	3
4.8	Data	3
4.9	Additional requirements for software controlled short-circuit isolators	4
5	Tests	5
5.1	General	5
5.2	Reproducibility	7
5.3	Variation in supply voltage	8
5.4	Dry heat (operational)	8
5.5	Cold (operational)	9
5.6	Damp heat, cyclic (operational)	10
5.7	Damp heat, steady state (endurance)	10
5.8	Sulfur dioxide (SO ₂) corrosion (endurance)	11
5.9	Shock (operational)	12
5.10	Impact (operational)	13
5.11	Vibration, sinusoidal (operational)	14
5.12	Vibration, sinusoidal (endurance)	15
5.13	Electromagnetic compatibility (EMC), immunity tests (operational)	16
6	Test report	17
Annex A (informative) Examples for the functional test procedure		18
Annex B (informative) Apparatus for impact test		25
Bibliography		27