

ISO 7240-11:2011-06 (E)

Fire detection and alarm systems - Part 11: Manual call points

Contents		Page
Foreword		iv
Introduction		vi
1	Scope	1
2	Normative references	1
3	Terms and definitions	2
4	Requirements	3
4.1	Compliance	3
4.2	Marking and data	3
4.3	Frangible element	4
4.4	Indicators for alarm condition	5
4.5	Reset facility	5
4.6	Test facility	5
4.7	Construction and design	5
4.8	Requirements for software controlled manual call points	10
5	Tests	12
5.1	General	12
5.2	Operational performance	14
5.3	Function test	16
5.4	Test facility test (operational)	16
5.5	Reliability (endurance)	17
5.6	Variation of supply parameters	17
5.7	Dry heat (operational)	18
5.8	Dry heat (endurance)	19
5.9	Cold (operational)	20
5.10	Damp heat, cyclic (operational)	21
5.11	Damp heat, cyclic (endurance)	22
5.12	Damp heat, steady state (endurance)	22
5.13	SO ₂ corrosion (endurance)	23
5.14	Shock (operational)	24
5.15	Impact (operational)	25
5.16	Vibration, sinusoidal (operational)	26
5.17	Vibration, sinusoidal (endurance)	27
5.18	Electromagnetic compatibility (EMC) (operational)	28
5.19	Enclosure protection	29
5.20	Exposure to simulated solar radiation (endurance)	30
6	Test report	31
Annex A (normative) Test apparatus for test of operation		32
Annex B (informative) Test apparatus for test for non-operation		34
Annex C (informative) Apparatus for impact test		35
Bibliography		39