

ISO 7240-7:2011-08 (E)

Fire detection and alarm systems - Part 7: Point-type smoke detectors using scattered light, transmitted light or ionization

Contents		Page
Foreword		v
Introduction		vii
1	Scope	1
2	Normative references	1
3	Terms and definitions	2
4	General requirements	2
4.1	Compliance	2
4.2	Response threshold value of detectors using scattered or transmitted light	2
4.3	Individual alarm indication	3
4.4	Connection of ancillary devices	3
4.5	Monitoring of detachable detectors	3
4.6	Manufacturer's adjustments	3
4.7	On-site adjustment of response behaviour	3
4.8	Protection against the ingress of foreign bodies	4
4.9	Response to slowly developing fires	4
4.10	Marking	4
4.11	Data	5
4.12	Requirements for software-controlled detectors	5
5	Tests	6
5.1	General	6
5.2	Repeatability	9
5.3	Directional dependence	10
5.4	Reproducibility	11
5.5	Variation in supply parameters	11
5.6	Air movement	12
5.7	Dazzling	13
5.8	Dry heat (operational)	13
5.9	Cold (operational)	14
5.10	Damp heat, steady state (operational)	15
5.11	Damp heat, steady state (endurance)	16
5.12	Sulfur dioxide (SO ₂) corrosion (endurance)	17
5.13	Shock (operational)	18
5.14	Impact (operational)	19
5.15	Vibration, sinusoidal (operational)	20
5.16	Vibration, sinusoidal (endurance)	21
5.17	Electromagnetic compatibility (EMC) immunity tests (operational)	22
5.18	Fire sensitivity	22
6	Test report	24
Annex A (normative)	Smoke tunnel for response threshold value measurements	25
Annex B (normative)	Test aerosol for response threshold value measurements	26
Annex C (normative)	Smoke-measuring instruments	27

Annex D (normative) Apparatus for dazzling test	31
Annex E (normative) Apparatus for impact test	32
Annex F (normative) Fire test room	34
Annex G (normative) Smouldering (pyrolysis) wood fire (TF2)	36
Annex H (normative) Glowing smouldering cotton fire (TF3)	39
Annex I (normative) Flaming plastics (polyurethane) fire (TF4)	41
Annex J (normative) Flaming liquid (n-heptane) fire (TF5)	43
Annex K (informative) Information concerning the construction of the smoke tunnel	45
Annex L (informative) Compensation for detector drift	47
Annex M (informative) Information concerning the construction of the measuring ionization chamber (MIC)	51
Annex N (normative) Detectors with more than one smoke sensor	53
Bibliography	55