

# ISO 7240-7:2011-08 (E)

## Fire detection and alarm systems - Part 7: Point-type smoke detectors using scattered light, transmitted light or ionization

---

<b>Contents</b>		<b>Page</b>
Foreword .....		v
Introduction .....		vii
1	Scope .....	1
2	Normative references .....	1
3	Terms and definitions .....	2
4	General requirements .....	2
4.1	Compliance .....	2
4.2	Response threshold value of detectors using scattered or transmitted light .....	2
4.3	Individual alarm indication .....	3
4.4	Connection of ancillary devices .....	3
4.5	Monitoring of detachable detectors .....	3
4.6	Manufacturer's adjustments .....	3
4.7	On-site adjustment of response behaviour .....	3
4.8	Protection against the ingress of foreign bodies .....	4
4.9	Response to slowly developing fires .....	4
4.10	Marking .....	4
4.11	Data .....	5
4.12	Requirements for software-controlled detectors .....	5
5	Tests .....	6
5.1	General .....	6
5.2	Repeatability .....	9
5.3	Directional dependence .....	10
5.4	Reproducibility .....	11
5.5	Variation in supply parameters .....	11
5.6	Air movement .....	12
5.7	Dazzling .....	13
5.8	Dry heat (operational) .....	13
5.9	Cold (operational) .....	14
5.10	Damp heat, steady state (operational) .....	15
5.11	Damp heat, steady state (endurance) .....	16
5.12	Sulfur dioxide (SO <sub>2</sub> ) corrosion (endurance) .....	17
5.13	Shock (operational) .....	18
5.14	Impact (operational) .....	19
5.15	Vibration, sinusoidal (operational) .....	20
5.16	Vibration, sinusoidal (endurance) .....	21
5.17	Electromagnetic compatibility (EMC) immunity tests (operational) .....	22
5.18	Fire sensitivity .....	22
6	Test report .....	24
Annex A (normative)	Smoke tunnel for response threshold value measurements .....	25
Annex B (normative)	Test aerosol for response threshold value measurements .....	26
Annex C (normative)	Smoke-measuring instruments .....	27

<b>Annex D (normative) Apparatus for dazzling test .....</b>	<b>31</b>
<b>Annex E (normative) Apparatus for impact test .....</b>	<b>32</b>
<b>Annex F (normative) Fire test room .....</b>	<b>34</b>
<b>Annex G (normative) Smouldering (pyrolysis) wood fire (TF2) .....</b>	<b>36</b>
<b>Annex H (normative) Glowing smouldering cotton fire (TF3) .....</b>	<b>39</b>
<b>Annex I (normative) Flaming plastics (polyurethane) fire (TF4) .....</b>	<b>41</b>
<b>Annex J (normative) Flaming liquid (n-heptane) fire (TF5) .....</b>	<b>43</b>
<b>Annex K (informative) Information concerning the construction of the smoke tunnel .....</b>	<b>45</b>
<b>Annex L (informative) Compensation for detector drift .....</b>	<b>47</b>
<b>Annex M (informative) Information concerning the construction of the measuring ionization chamber (MIC) .....</b>	<b>51</b>
<b>Annex N (normative) Detectors with more than one smoke sensor .....</b>	<b>53</b>
<b>Bibliography .....</b>	<b>55</b>