

# ISO 7240-10:2012-05 (E)

## Fire detection and alarm systems - Part 10: Point-type flame detectors

---

<b>Contents</b>		<b>Page</b>
Foreword .....		iv
Introduction .....		vi
<b>1</b>	<b>Scope .....</b>	<b>1</b>
<b>2</b>	<b>Normative references .....</b>	<b>1</b>
<b>3</b>	<b>Terms and definitions .....</b>	<b>1</b>
<b>4</b>	<b>Abbreviated terms .....</b>	<b>2</b>
<b>5</b>	<b>General requirements .....</b>	<b>3</b>
<b>5.1</b>	<b>Compliance .....</b>	<b>3</b>
<b>5.2</b>	<b>Classification .....</b>	<b>3</b>
<b>5.3</b>	<b>Individual alarm indication .....</b>	<b>3</b>
<b>5.4</b>	<b>Connection of ancillary devices .....</b>	<b>3</b>
<b>5.5</b>	<b>Monitoring of detachable detectors .....</b>	<b>3</b>
<b>5.6</b>	<b>Manufacturer adjustments .....</b>	<b>3</b>
<b>5.7</b>	<b>On-site sensitivity adjustment .....</b>	<b>4</b>
<b>5.8</b>	<b>Ingress protection (IP) -- Optional function .....</b>	<b>4</b>
<b>5.9</b>	<b>Marking .....</b>	<b>4</b>
<b>5.10</b>	<b>Data .....</b>	<b>5</b>
<b>5.11</b>	<b>Requirements for software-controlled detectors .....</b>	<b>5</b>
<b>6</b>	<b>Tests .....</b>	<b>6</b>
<b>6.1</b>	<b>General .....</b>	<b>6</b>
<b>6.2</b>	<b>Reproducibility .....</b>	<b>9</b>
<b>6.3</b>	<b>Repeatability .....</b>	<b>10</b>
<b>6.4</b>	<b>Directional dependence .....</b>	<b>10</b>
<b>6.5</b>	<b>Fire sensitivity .....</b>	<b>11</b>
<b>6.6</b>	<b>Dazzling (operational) .....</b>	<b>14</b>
<b>6.7</b>	<b>Dry heat (operational) .....</b>	<b>15</b>
<b>6.8</b>	<b>Cold (operational) .....</b>	<b>16</b>
<b>6.9</b>	<b>Damp heat, cyclic (operational) .....</b>	<b>16</b>
<b>6.10</b>	<b>Damp heat, steady state (endurance) .....</b>	<b>17</b>
<b>6.11</b>	<b>Sulfur dioxide (SO<sub>2</sub>) corrosion (endurance) .....</b>	<b>18</b>
<b>6.12</b>	<b>Shock (operational) .....</b>	<b>19</b>
<b>6.13</b>	<b>Impact (operational) .....</b>	<b>20</b>
<b>6.14</b>	<b>Vibration, sinusoidal (operational) .....</b>	<b>21</b>
<b>6.15</b>	<b>Vibration, sinusoidal (endurance) .....</b>	<b>22</b>
<b>6.16</b>	<b>Variation of supply parameters (operational) .....</b>	<b>23</b>
<b>6.17</b>	<b>EMC immunity tests (operational) .....</b>	<b>23</b>
<b>6.18</b>	<b>IP -- Optional function .....</b>	<b>24</b>
<b>7</b>	<b>Test report .....</b>	<b>25</b>
	<b>Annex A (normative) Apparatus for response point determination .....</b>	<b>26</b>
	<b>Annex B (normative) Liquid (heptane) fire (TF5) .....</b>	<b>28</b>
	<b>Annex C (normative) Liquid (methylated spirit) fire (TF6) .....</b>	<b>29</b>

<b>Annex D (normative) Apparatus for dazzling test .....</b>	<b>30</b>
<b>Annex E (normative) Apparatus for impact test .....</b>	<b>31</b>
<b>Annex F (informative) Example of methane burner .....</b>	<b>33</b>