

# ISO 7240-12:2014-04 (E)

## Fire detection and alarm systems - Part 12: Line type smoke detectors using a transmitted optical beam

---

<b>Contents</b>		<b>Page</b>
Foreword .....		v
Introduction .....		vii
1	Scope .....	1
2	Normative references .....	1
3	Terms and definitions .....	2
4	Requirements .....	3
4.1	Compliance .....	3
4.2	Individual alarm indication .....	3
4.3	Connection of ancillary devices .....	4
4.4	Monitoring of detachable detectors and connections .....	4
4.5	Manufacturer's adjustments .....	4
4.6	On-site adjustment of response threshold value .....	4
4.7	Protection of optical components .....	4
4.8	Limit of compensation .....	5
4.9	Fault signalling .....	5
4.10	Software-controlled detectors .....	5
5	Test methods .....	6
5.1	General .....	6
5.2	Reproducibility .....	9
5.3	Repeatability .....	10
5.4	Alignment dependence .....	10
5.5	Variation of supply parameters .....	11
5.6	Rapid changes in attenuation .....	12
5.7	Slow changes in attenuation .....	12
5.8	Optical path length dependence .....	13
5.9	Fire sensitivity .....	13
5.10	Stray light .....	15
5.11	Dry heat (operational) .....	16
5.12	Cold (operational) .....	17
5.13	Damp heat, steady-state (operational) .....	19
5.14	Damp heat, steady-state (endurance) .....	20
5.15	Vibration, sinusoidal (endurance) .....	20
5.16	Electromagnetic compatibility (EMC), immunity tests (operational) .....	21
5.17	Sulfur dioxide, SO <sub>2</sub> , corrosion (endurance) .....	22
5.18	Impact (operational) .....	23
6	Test report .....	24
7	Marking .....	24
8	Data .....	25
Annex A (informative)	Compensation for detector drift .....	26
Annex B (normative)	Bench for response threshold value measurements .....	31

<b>Annex C (normative) Fire test room .....</b>	<b>33</b>
<b>Annex D (normative)Smoulderingpyrolysiswoodfire(TF2) .....</b>	<b>35</b>
<b>Annex E (normative)Glowingsmoulderingcottonfire(TF3) .....</b>	<b>38</b>
<b>Annex F (normative)Flamingplastics(polyurethane)fire(TF4) .....</b>	<b>40</b>
<b>Annex G (normative) Flaming liquid (n-heptane)fire(TF5) .....</b>	<b>42</b>
<b>Annex H (normative) Smoke-measuring instruments .....</b>	<b>43</b>
<b>Annex I (normative) Apparatus for stray light .....</b>	<b>46</b>
<b>Annex J (informative) Information concerning the construction of the measuring ionization chamber .....</b>	<b>48</b>