DIN EN 54-12:2015-10 (E)

Fire detection and fire alarm systems - Part 12: Smoke detectors - Line detectors using an optical beam

Contents

Page

Foreword 5

1 Scope 7

2 Normative references 7

3 Terms and definitions 8

4 Requirements 9
4.1 Compliance 9
4.2 Operational reliability 9
4.2.1 Individual alarm indication 9
4.2.2 Connection of ancillary devices 9
4.2.3 Manufacturer's adjustments 9
4.2.4 On-site adjustment of response value 9
4.2.5 Protection against ingress of foreign bodies 10
4.2.6 Monitoring of detachable detectors and connections 10
4.2.7 Requirements for software controlled detectors (when provided) 10
4.3 Nominal activation conditions/sensitivity 11
4.3.1 Reproducibility 11
4.3.2 Repeatability 11
4.3.3 Tolerance to beam misalignment 11
4.3.4 Rapid changes in attenuation 12
4.3.5 Response to slowly developing fires 12
4.3.6 Optical path length dependence 12
4.3.7 Stray light 12
4.4 Tolerance to supply voltage - Variation in supply parameters 12
4.5 Performance parameters under fire conditions - Fire sensitivity 12
4.6 Durability of nominal activation conditions/sensitivity 12
4.6.1 Temperature resistance 12
4.6.2 Humidity resistance 13
4.6.3 Vibration resistance 13
4.6.4 Electrical stability - Electromagnetic Compatibility (EMC), Immunity tests (operational) 13
4.6.5 Corrosion resistance - Sulphur dioxide (SO_2) corrosion (endurance) 13

5 Testing, assessment and sampling methods 13
5.1 General 13
5.1.1 Atmospheric conditions for tests 13
5.1.2 Operating conditions for tests 14
5.1.3 Mounting arrangements 14
5.1.4 Tolerances 14
5.1.5 Measurement of response value 14
5.1.6 Provision for tests 15
5.1.7 Test schedule 15
5.2 Operational reliability 16
5.2.1 Individual alarm indication 16
5.2.2 Connection of ancillary devices 16
5.2.3 Manufacturer's adjustments 16
5.2.4 On-site adjustment of response value 16
5.2.5 Protection against ingress of foreign bodies 17
5.2.6 Monitoring of detachable detectors and connections 17

5.2.7 Additional requirements for software controlled detectors ... 17
5.3 Normal activation conditions/sensitivity ... 17
5.3.1 Reproducibility ... 17
5.3.2 Repeatability ... 17
5.3.3 Tolerance to beam misalignment ... 18
5.3.4 Rapid changes in attenuation ... 19
5.3.5 Response to slowly developing fires ... 19
5.3.6 Optical path length dependence ... 19
5.3.7 Stray light ... 20
5.4 Tolerance to supply voltage -- Variation of supply parameters ... 21
5.4.1 Object of the test ... 21
5.4.2 Test procedure ... 21
5.4.3 Test requirements ... 21
5.5 Performance parameters under fire conditions ... 21
5.5.1 Fire sensitivity ... 21
5.6 Durability of nominal activation conditions/sensitivity ... 23
5.6.1 Temperature resistance ... 23
5.6.2 Humidity resistance ... 25
5.6.3 Vibration resistance ... 27
5.6.4 Electrical stability - Electromagnetic compatibility (EMC), immunity tests (operational) ... 29
5.6.5 Corrosion resistance -- Sulphur dioxide (SO2) corrosion (endurance) ... 30

6 Assessment and verification of constancy of performance (AVCP) ... 30
6.1 General ... 30
6.2 Type testing ... 31
6.2.1 General ... 31
6.2.2 Test samples, testing and compliance criteria ... 32
6.2.3 Test reports ... 32
6.3 Factory production control (FPC) ... 32
6.3.1 General ... 32
6.3.2 Requirements ... 33
6.3.3 Product specific requirements ... 35
6.3.4 Initial inspection of factory and FPC ... 36
6.3.5 Continuous surveillance of FPC ... 36
6.3.6 Procedure for modifications ... 36
6.3.7 One-off products, pre-production products, (e.g. prototypes) and products produced in very low quantities ... 37

7 Classification and designation ... 37

8 Marking, labelling and packaging ... 37

Annex A (normative) Bench for response value measurements ... 39

A.1 Technical characteristics of the attenuators ... 39
A.2 Measuring bench ... 40

Annex B (normative) Fire test room ... 41

Annex C (normative) Smouldering (pyrolysis) wood fire (TF2) ... 43

C.1 Fuel ... 43
C.2 Hotplate ... 43
C.3 Arrangement ... 43
C.4 Heating rate ... 44
C.5 End of test condition ... 44
C.6 Test validity criteria ... 44

Annex D (normative) Glowing smouldering cotton fire (TF3) ... 46

D.1 Fuel ... 46
D.2 Arrangement ... 46

D.3 Ignition 46
D.4 End of test condition 47
D.5 Test validity criteria 47

Annex E (normative) Flaming plastics (polyurethane) fire (TF4) 49

E.1 Fuel 49
E.2 Arrangement 49
E.3 Ignition 49
E.4 End of test condition 49
E.5 Test validity criteria 49

Annex F (normative) Flaming liquid (n-heptane) fire (TF5) 51

F.1 Fuel 51
F.2 Arrangement 51
F.3 Ignition 51
F.4 End of test condition 51
F.5 Test validity criteria 51

Annex G (normative) Apparatus for stray light 53

G.1 Installation 53
G.2 The light source 54

Annex H (informative) Information concerning the requirements for the response to slowly developing fires 56

Annex I (informative) Data supplied with line detectors using an optical beam 60

Annex ZA (informative) Clauses of this European Standard addressing the provisions of the EU Construction Products Regulation 61

Bibliography 71