DIN EN 15004-1:2019-06 (E)

Fixed firefighting systems - Gas extinguishing systems - Part 1: Design, installation and maintenance (ISO 14520-1:2015, modified)

Contents

Page

European foreword 5

Introduction 7

1 Scope 8

2 Normative references 9

3 Terms and definitions 10

4 Use and limitations 13
4.1 General 13
4.2 Extinguishants 14
4.2.1 General 14
4.2.2 Environmental properties 15
4.3 Electrostatic discharge 15
4.4 Compatibility with other extinguishants 15
4.5 Temperature limitations 15

5 Safety 15
5.1 Hazard to personnel 15
5.2 Safety precautions 16
5.2.1 General 16
5.2.2 For normally occupied areas 16
5.2.3 For normally unoccupied areas 18
5.2.4 For unoccupiable areas 18
5.3 Occupiable areas 18
5.4 Electrical hazards 19
5.5 Electrical earthing 20
5.6 Electrostatic discharge 20

6 System design 20
6.1 General 20
6.2 Extinguishant supply 21
6.2.1 Quantity 21
6.2.2 Quality 21
6.2.3 Container arrangement 21
6.2.4 Storage containers 21
6.3 Distribution 22
6.3.1 General 22
6.3.2 Piping 23
6.3.3 Fittings 24
6.3.4 Pipe and valve supports 24
6.3.5 Valves 25
6.3.6 Nozzles 25
6.3.7 Pressure reducing orifice assembly 26
6.4 Detection, actuation and control systems 26
6.4.1 General 26
6.4.2 Automatic detection 27
6.4.3 Operating devices 27
6.4.4 Control equipment 28

6.4.5 Operating alarms and indicators 28
6.4.6 Stop device 28

7 Extinguishant system design 28
7.1 General 28
7.2 Specifications, plans and approvals 29
7.2.1 Specifications 29
7.2.2 Working documents 29
7.3 System flow calculations 29
7.3.1 General 29
7.3.2 Balanced and unbalanced system 29
7.3.3 Friction losses 31
7.3.4 Pressure drop 31
7.3.5 Valves and fittings 32
7.3.6 Piping length 32
7.3.7 Drawings 32
7.3.8 Liquefied gases -- Specific requirements 32
7.4 Enclosures 32
7.5 Extinguishant concentration requirements 33
7.5.1 Flame extinguishment 33
7.5.2 Inerting 34
7.6 Total flooding quantity 34
7.6.1 General 34
7.6.2 Liquefied gases 34
7.6.3 Non-liquefied gas 35
7.7 Altitude adjustment 35
7.8 Duration of protection 36
7.9 System performance 36
7.9.1 Discharge time 36
7.9.2 Extended discharge 37

8 Commissioning and acceptance 37
8.1 General 37
8.2 Tests 37
8.2.1 General 37
8.2.2 Enclosure check 37
8.2.3 Review of mechanical components 37
8.2.4 Review of enclosure integrity 39
8.2.5 Review of electrical components 39
8.2.6 Preliminary functional tests 40
8.2.7 System functional operational test 40
8.2.8 Remote monitoring operations (if applicable) 40
8.2.9 Control panel primary power source 41
8.2.10 Completion of functional tests 41
8.3 Completion certificate and documentation 41

9 Inspection, maintenance, testing and training 41
9.1 General 41
9.2 Inspection 41
9.2.1 General 41
9.2.2 Container 42
9.2.3 Hose 42
9.2.4 Enclosures 42
9.3 Maintenance 42
9.3.1 General 42
9.3.2 User's programme of inspection 43
9.3.3 Service schedule 43
9.4 Training 43

Annex A (normative) Working documents 44

Annex B (normative) Determination of flame-extinguishing concentration of gaseous extinguishants by the cup burner method 46

Annex C (normative) Fire extinguishment/area coverage fire test procedure for engineered and pre-engineered extinguishing units 53

Annex D (normative) Method of evaluating inerting concentration of a fire extinguishant 83

Annex E (normative) Door fan test for determining of minimum hold time 85

Annex F (informative) System performance verification 104

Annex G (informative) Safe personnel exposure guidelines 105

Annex H (informative) Flow calculation implementation method and flow calculation verification and testing for approvals 112

Bibliography 116