

# ISO 6182-8:2019 (E)

## Fire protection — Automatic sprinkler systems — Part 8: Requirements and test methods for pre-action dry alarm valves

---

### Contents

	Foreword
1	Scope
2	Normative references
3	Terms and definitions
4	Requirements
4.1	Nominal sizes
4.2	Connections
4.3	Rated working pressure
4.4	Body and cover
4.5	Strength
4.6	Access for maintenance
4.7	Components
4.8	Leakage
4.9	Non-metallic components (excluding gaskets, diaphragms, seals and other elastomeric parts)
4.10	Sealing assembly elements
4.11	Clearances
4.12	Hydraulic friction loss
4.13	Endurance
4.14	Operational performance
4.15	Drains
4.16	Alarms
4.17	Valve impairment
5	Production testing and quality control
6	Tests
6.1	Samples
6.2	Spring and diaphragm test
6.3	Sealing element tests
6.3.1	Release test
6.4	Warm-water ageing test for non-metallic components (excluding gaskets, seals and other elastomeric components)
6.5	Air ageing test for non-metallic components (excluding gaskets, seals and other elastomeric components)
6.6	Hydraulic friction loss test
6.7	Valve leakage and deformation test
6.7.1	Body leakage test
6.7.2	Sealing assembly test (below to above sealing assembly)
6.7.3	Sealing assembly test (mechanical type valves)
6.7.4	Leakage test for mechanical type valves (above to below sealing assembly)
6.7.5	Leakage test for differential type valves (above to below sealing assembly)
6.8	Body strength test
6.9	Operational test
6.9.1	General
6.9.2	Pre-action valve operation test — Set-up
6.9.3	Pre-action valve operation test
6.9.4	Pre-action dry alarm valve set installation
6.9.4.1	Activated by a detection system

- 6.9.4.2 Sprinkler operation only (detection system not activated)
- 6.9.4.3 Operational test in the dry mode (sprinkler operation with detection fault)
- 6.10 Endurance test
- 6.11 Anti-reseating test
- 6.12 Quick release
- 6.13 Salt mist corrosion test

7 Marking

8 Manufacturer's installation instructions

Annex A (normative) Tolerances

Annex B (informative) Terms

Page count: 24