

# DIN EN 14972-9:2020-06 (E)

## Fixed firefighting systems - Water mist systems - Part 9: Test protocol for machinery in enclosures not exceeding 260 m<sup>3</sup> for open nozzle systems

---

	Contents	Page
European foreword.....	3	
1 Scope.....	4	
2 Normative references.....	4	
3 Terms and definitions .....	4	
4 General requirements .....	4	
5 Test enclosure requirements.....	5	
6 Machinery mock-up requirement.....	6	
7 Test equipment requirements .....	7	
8 Instrumentation requirements.....	8	
9 Fire test requirements .....	9	
9.1 General.....	9	
9.2 Unshielded 1 MW diesel spray fire .....	9	
9.3 Shielded 1 MW diesel spray fire.....	10	
9.4 Shielded 1 m <sup>2</sup> diesel pool fire .....	10	
9.5 Shielded 2 MW diesel spray fire, system performance under limited natural ventilation.....	11	
9.6 Shielded 2 MW diesel spray fire, system performance at smaller enclosure volumes.....	11	
9.7 Unshielded 1 MW heptane spray fire.....	12	
9.8 Shielded 1 MW heptane spray fire .....	12	
9.9 Shielded 1 m <sup>2</sup> heptane pool fire .....	13	
9.10 Shielded 2 MW heptane spray fire, system performance under limited natural ventilation.....	13	
9.11 Shielded 2 MW heptane spray fire, system performance at smaller enclosure volumes.....	14	
10 Test report.....	14	