DIN EN 54-7:2006-09 (E)

Fire detection and fire alarm systems - Part 7: Smoke detectors - Point detectors using scattered light, transmitted light or ionization

Contents

Page

Introduction 5

1 Scope 6

2 Normative references 6

3 Terms and definitions 7

4 Requirements 7
4.1 Compliance 7
4.2 Individual alarm indication 7
4.3 Connection of ancillary devices 7
4.4 Monitoring of detachable detectors 7
4.5 Manufacturer's adjustments 7
4.6 On-site adjustment of response behaviour 8
4.7 Protection against the ingress of foreign bodies 8
4.8 Response to slowly developing fires 8
4.9 Marking 8
4.10 Data 9
4.11 Additional requirements for software controlled detectors 9

5 Tests 10
5.1 General 10
5.2 Repeatability 13
5.3 Directional dependence 14
5.4 Reproducibility 14
5.5 Variation in supply parameters 15
5.6 Air movement 15
5.7 Dazzling 16
5.8 Dry heat (operational) 17
5.9 Cold (operational) 17
5.10 Damp heat, steady state (operational) 18
5.11 Damp heat, steady state (endurance) 19
5.12 Sulphur dioxide (SO_2) corrosion (endurance) 20
5.13 Shock (operational) 20
5.14 Impact (operational) 21
5.15 Vibration, sinusoidal (operational) 22
5.16 Vibration, sinusoidal (endurance) 23
5.17 Electromagnetic Compatibility (EMC), Immunity tests (operational) 24
5.18 Fire sensitivity 25

Annex A (normative) Smoke tunnel for response threshold value measurements 27

Annex B (normative) Test aerosol for response threshold value measurements 28

Annex C (normative) Smoke measuring instruments 29

Annex D (normative) Apparatus for dazzling test 34

Annex E (informative) Apparatus for impact test 35

Annex F (normative) Fire test room **37**

Annex G (normative) Smouldering (pyrolysis) wood fire (TF2) **39**

Annex H (normative) Glowing smouldering cotton fire (TF3) **41**

Annex I (normative) Flaming plastics (polyurethane) fire (TF4) **43**

Annex J (normative) Flaming liquid (n-heptane) fire (TF5) **45**

Annex K (informative) Information concerning the construction of the smoke tunnel **47**

Annex L (informative) Information concerning the requirements for the response to slowly developing fires **49**

Annex M (informative) Information concerning the construction of the measuring ionization chamber **53**

Annex N (normative) Additional requirements and test methods for smoke detectors with more than one smoke sensor **55**

Annex ZA (informative) Clauses of this European Standard addressing essential requirements or other provisions of EU Directives **57**

Bibliography **63**