ISO 7240-10:2007-02 (E)

Fire detection and alarm systems - Part 10: Point-type flame detectors

Contents

Page

Foreword iv

Introduction vi

1 Scope 1

2 Normative references 1

3 Terms and definitions 2

4 General requirements 3
4.1 Compliance 3
4.2 Classification 3
4.3 Individual alarm indication 3
4.4 Connection of ancillary devices 3
4.5 Monitoring of detachable detectors 3
4.6 Manufacturer's adjustments 3
4.7 On-site sensitivity adjustment 4
4.8 Marking 4
4.9 Data 5
4.10 Requirements for software-controlled detectors 5

5 Tests 6
5.1 General 6
5.2 Reproducibility 9
5.3 Repeatability 10
5.4 Directional dependence 10
5.5 Fire sensitivity 11
5.6 Dazzling (operational) 14
5.7 Dry heat (operational) 15
5.8 Cold (operational) 16
5.9 Damp heat, cyclic (operational) 17
5.10 Damp heat, steady state (endurance) 18
5.11 Sulfur dioxide (SO2) corrosion (endurance) 18
5.12 Shock (operational) 19
5.13 Impact (operational) 20
5.14 Vibration, sinusoidal (operational) 21
5.15 Vibration, sinusoidal (endurance) 22
5.16 Variation of supply parameters (operational) 23
5.17 Electromagnetic compatibility (EMC) immunity tests (operational) 24

6 Test report 24

Annex A (normative) Marine test requirements 25

Annex B (normative) Apparatus for response point determination 42

Annex C (normative) Liquid (heptane) fire (TF5) 44

Annex D (normative) Liquid (methylated spirit) fire (TF6) 45

Annex E (normative) Apparatus for dazzling test 46

Annex F (normative) Apparatus for impact test 47

Annex G (informative) Example of methane burner 49