

DIN EN 12102:2008-09 (E)

Air conditioners, liquid chilling packages, heat pumps and dehumidifiers with electrically driven compressors for space heating and cooling - Measurement of airborne noise - Determination of the sound power level

Contents		Page
Foreword		4
1	Scope	5
2	Normative references	6
3	Definitions and symbols	7
3.1	General	7
3.2	Symbols	7
3.2.1	Non ducted units	7
3.2.2	Ducted units	7
3.3	Standard operating conditions	7
4	Measuring instruments	8
5	Operation of the unit	9
6	Installation	11
6.1	General points	11
6.2	Ducted units	11
6.2.1	Installation	11
6.2.2	Duct end correction	11
6.2.3	Bend correction	12
6.2.4	Pressure and airflow measurements	13
6.2.5	Casing radiated test	14
6.3	Wall mounted	14
6.4	Ceiling Mounted	14
6.5	Window-type	14
6.6	Multisplits	14
6.7	Single ducts	14
6.7.1	Casing radiated test:	14
6.7.2	Ducted outlet	15
7	Acoustic measurement methods	15
7.1	Frequency range	15
7.2	To choose a method	15
7.2.1	General	15
7.2.2	Available test facilities	15
7.2.3	Target of measurement	16
7.3	Reverberation room methods	16
7.3.1	General	16
7.3.2	Non ducted units	16
7.3.3	Ducted units	17
7.4	Installation of the free field over a reflecting plane method	17
7.4.1	General	17
7.4.2	Reference surface	17
7.4.3	Measuring surface	18
8	Uncertainty of measurement results	20

9	Test report	20
9.1	General	20
9.2	Unit specification	20
9.3	Operating conditions, installation and environmental conditions	20
9.4	Measurement instruments	20
9.5	Measured values and results	21
Annex A (normative) Energy labelling application		22
A.1	General	22
A.2	Test procedure	22
A.3	Tolerances permitted on declared values	22
Annex B (normative) Specific measurement for variable capacity units		23
B.1	General requirements	23
B.2	Test mode	23
B.3	Measurements process	23
Bibliography		24