DIN EN 14624:2012-04 (E)

Performance of portable leak detectors and of room monitors for halogenated refrigerants

Contents

Page

Foreword 4

1 Scope 5

2 Normative references 5

3 Terms and definitions 5

4 Symbols and abbreviations 7

5 Types of portable leak detectors and room monitors 7

6 General requirements for all portable leak detectors and room monitors 7
6.1 Gas type 7
6.2 Capabilities 7
6.3 Output signal 8
6.4 Response time 8
6.5 Recovery time (clean up time) 8
6.6 Repeatability 8
6.7 Calibration 8

7 Specific requirements for locating portable leak detectors 8
7.1 General 8
7.2 Lowest detectable leakage rate threshold when the leak detector is stationary 9
7.3 Lowest detectable leakage rate threshold value when the detector probe is moving 9
7.4 Leak detection in a contaminated environment 9

8 Specific requirements for room monitors 10
8.1 General 10
8.2 Lowest detectable concentration (lower detection limit) 10
8.3 Highest tolerable concentration (upper detection limit) 10
8.4 Upper and lower alarm thresholds 10
8.5 Response time for alarm trigger 10

9 Calibration leaks 10
9.1 General 10
9.2 Calibration gases 10

10 Test apparatus 11
10.1 General 11
10.2 Apparatus no. 1: detector probe stationary at the orifice of a calibration leak 11
10.3 Apparatus no. 2: detector probe moved with defined speed and distance in front of a calibration leak 11
10.4 Apparatus no. 3: Chamber with monitored concentration 12

11 Performance tests 12
11.1 Performance test of locating leak detector 12
11.1.1 Test no. 1: Static detection 12
11.1.2 Test no. 2: dynamic detection limit 13
11.1.3 Test no. 3: detection limit in contaminated environment 13
11.1.4 Test no. 4: recovery time 13

11.2 Performance tests of room monitor 13
11.2.1 General 13
11.2.2 Test a) to determine the upper and lower detection limits 13
11.2.3 Test b) to determine response time 14
11.2.4 Test c) to determine recovery time from exposure to a large concentration 14

12 Instrument characteristics and reporting of test results 15
12.1 Characteristics of locating leak detector 15
12.2 Characteristics of room monitors 15

13 Technical data 16
13.1 Locating leak detectors 16
13.2 Measuring leak detectors 16
13.3 All portable leak detectors 16
13.4 Room monitor 16

Annex A (informative) Conversion factors of leakage rate units 18

Annex B (informative) Correlation between test gas concentration and leakage rate 19

Annex C (informative) Guidelines for monitoring a machinery room or space for gas leaks 23