

DIN EN 13215:2017-03 (E)

Condensing units for refrigeration - Rating conditions, tolerances and presentation of manufacturer's performance data

Contents		Page
European foreword.....		4
1	Scope.....	5
2	Normative references.....	5
3	Terms and definitions	5
4	Symbols and abbreviations	6
5	Parameters for the presentation of performance data.....	7
6	General requirements	7
7	Performance data.....	8
7.1	General.....	8
7.2	Part load performance data	8
7.3	Tabular or graphical form	8
7.4	Determination of the power absorbed by the condensing unit	8
7.4.1	Condensing units including the compressor motor	8
7.4.2	Motors with a specific factory assembled or factory specified means for variable speed.....	8
7.4.3	Externally driven compressors without motor.....	8
8	Rating conditions	9
8.1	General.....	9
8.2	Standard reference points	9
8.3	Air cooled condensing units.....	10
8.3.1	General.....	10
8.3.2	Data for <i>SEPR</i> calculation	10
8.4	Water cooled condensing units.....	10
9	Tolerances	10
10	Correction factors	11
10.1	Superheat.....	11
10.2	Compressors speed	11
Annex A (normative) Calculation of <i>SEPR</i>.....		12
A.1	General.....	12
A.2	Condensing unit without capacity control.....	12
A.3	Condensing unit with stepwise capacity control	12
A.4	Calculation of <i>SEPR</i>.....	13
Annex ZA (informative) Relationship between this European Standard and the eco-design requirements of Commission Regulation (EU) No 2015/1095 aimed to be covered.....		16
Bibliography.....		18

Tables

Table 1 — Symbols and abbreviations.....	6
Table 2 — Indices.....	7
Table 3 — Parameters for the presentation of performance data.....	7
Table 4 — Standard reference points.....	9
Table 5 — Actual performance in relation to published data	11
Table A.1 — Required input for <i>SEPR</i> calculation.....	13
Table A.2 — Ambient temperatures and duration for <i>SEPR</i> determination	14
Table ZA.1 — Correspondence between this European Standard and Commission Regulation (EU) No 2015/1095 of 5 May 2015 implementing Directive 2009/125/EC of the European Parliament and of the Council with regard to ecodesign requirements for professional refrigerated storage cabinets, blast cabinets, condensing units and process chillers and Commission’s standardization request M/495 (Ecodesign).....	16