DIN EN 13215:2020-12 (E)

Condensing units for refrigeration - Rating conditions, tolerances and presentation of manufacturer's performance data (includes Amendment : 2020)

Contents

Page

European foreword 4

1 Scope 5

2 Normative references 5

3 Terms and definitions 5

4 Symbols and abbreviations 6

5 Parameters for the presentation of performance data 7

6 General requirements 7

7 Performance data 8
7.1 General 8
7.2 Part load performance data 8
7.3 Tabular or graphical form 8
7.4 Determination of the power absorbed by the condensing unit 8
7.4.1 Condensing units including the compressor motor 8
7.4.2 Motors with a specific factory assembled or factory specified means for variable speed 9
7.4.3 Externally driven compressors without motor 9

8 Rating conditions 9
8.1 General 9
8.2 Standard reference points 9
8.3 Air cooled condensing units 10
8.3.1 General 10
8.3.2 Data for SEPR calculation 10
8.4 Water cooled condensing units 11

9 Tolerances 11

10 Correction factors 11
10.1 Superheat 11
10.2 Compressors speed 12

Annex A(normative) Calculation of SEPR 13

A.1 General 13
A.2 Condensing unit without capacity control 13
A.3 Condensing unit with stepwise capacity control 13
A.4 Calculation of SEPR 14

Annex B(normative) Determination of evaporating temperature with refrigerant mixtures 18

Annex ZA(informative) Relationship between this European Standard and the eco-design requirements of Commission Regulation (EU) No 2015/1095 20

Bibliography 21

Tables Table 1 -- Symbols and abbreviations 6

Table 2 -- Indices 7

Table 3 -- Parameters for the presentation of performance data 7

Table 4 -- Standard reference points 9

Table 5 -- Actual performance in relation to published data 11

Table A.1 -- Required input for SEPR calculation 14

Table A.2 -- Ambient temperatures and duration for SEPR determination 15

Table ZA.1 -- Correspondence between this European Standard and Commission Regulation (EU) No 2015/1095 of 5 May 2015 implementing Directive 2009/125/EC of the European Parliament and of the Council with regard to ecodesign requirements for professional refrigerated storage cabinets, blast cabinets, condensing units and process chillers and Commission's standardization request M/495 (Ecodesign) 20