

DIN EN 13771-2:2007-11 (En glisch)

Compressors and condensing units for refrigeration - Performance testing and test methods - Part 2: Condensing units

Contents		Page
Foreword		4
1	Scope	5
2	Normative references	5
3	Terms, definitions and symbols	5
3.1	Terms and definitions	5
3.2	Symbols	6
3.3	Refrigerant circuit state points	8
4	General requirements	9
4.1	Test equipment	9
4.2	Calculation methods	9
4.2.1	Principle	9
4.2.2	Specific enthalpy	9
4.2.3	Refrigerant mass flow	9
4.2.4	Power absorbed	9
4.2.5	Basic equations	9
4.3	Requirements for the selection of test methods	10
4.4	Test procedure	10
4.4.1	General	10
4.4.2	Steady working conditions	10
4.4.3	Recording of measured data	10
4.5	Pressure and temperature measuring points	11
4.6	Oil circulation	11
4.7	Refrigerant composition	11
4.8	Calibration and requirements regarding measurement uncertainty	11
4.8.1	Calibration of calorimeters for methods A, B and C	11
4.8.2	Determination of the refrigerating capacity	12
4.8.3	Determination of the power absorbed by the condensing unit	12
4.8.4	Measuring instruments	12
4.9	Source of refrigerant data	13
4.10	Allowable deviations from the basic test conditions	13
4.11	Additional information	14
5	Test methods	14
5.1	General	14
5.2	List of test methods	14
5.2.1	Calorimetric methods	14
5.2.2	Flow meter methods	15
5.3	Method A: secondary fluid calorimeter on the suction side	15
5.3.1	Description	15
5.3.2	Calibration	15
5.3.3	Test procedure	16
5.3.4	Requirements	16
5.3.5	Determination of refrigerant mass flow	16
5.4	Method B: dry system refrigerant calorimeter on the suction side	16
5.4.1	Description	16
5.4.2	Calibration	17
5.4.3	Test procedure	17

5.4.4	Requirements	17
5.4.5	Determination of refrigerant mass flow	17
5.5	Method C: water-cooled condenser on the discharge side	18
5.5.1	Description	18
5.5.2	Calibration	18
5.5.3	Test procedure	18
5.5.4	Requirements	19
5.5.5	Determination of refrigerant mass flow	19
5.6	Method D: refrigerant vapour flow meter on the suction side	19
5.6.1	Description	19
5.6.2	Test procedure	19
5.6.3	Requirements	19
5.6.4	Determination of refrigerant mass flow	20
5.7	Method E: refrigerant flow meter in the liquid line	20
5.7.1	Description	20
5.7.2	Test procedure	20
5.7.3	Requirements	21
5.7.4	Determination of the refrigerant mass flow	21
6	Determination of the power absorbed by the condensing unit	21
6.1	General	21
6.1.1	Introduction	21
6.1.2	Measurement for condensing units where the motor is not an integral part of the unit	21
6.1.3	Measurement for condensing units where the motor is an integral part of the condensing unit	21
6.1.4	Measurement of the power absorbed by the auxiliary components	22
6.2	Calculation	22
7	Test report	22
7.1	General	22
7.2	General information in the test report	22
7.3	Basic data	22
7.4	Test results	23
7.5	Additional information	23
	Bibliography	25